

ANANTAPUR, India

WMO: 432370

Lat: 14.583N

Lon: 77.633E

Elev: 364

StdP: 97.03

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	16.5	17.8	4.4	5.4	32.0	6.4	6.2	31.3	5.3	25.9	4.8	26.2	0.2	90	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.9	40.5	23.5	39.6	23.4	38.7	23.1	27.2	34.7	26.3	33.6	25.7	32.7	2.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	21.4	30.9	24.6	20.5	29.7	24.1	19.8	28.8	88.5	34.9	84.6	33.7	81.8	32.8	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	8.1	7.0	13.5	42.0	1.4	1.0	12.5	42.7	11.7	43.3	10.9	43.8	9.8	44.5		
(5)			11.1	29.0	1.3	1.1	10.2	29.8	9.5	30.4	8.8	31.0	7.8	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	24.7	27.2	30.7	32.9	32.7	30.3	29.0	28.4	28.1	27.4	25.5	24.1	(6)
(7)		DBStd	3.16	1.56	1.74	1.85	1.61	1.87	1.58	1.22	1.21	1.27	1.42	1.50	1.43	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6721	456	482	641	688	703	608	589	572	542	538	465	437	(10)
(11)		CDD18.3	3679	197	249	382	438	444	358	331	313	292	280	215	178	(11)
(12)		CDH23.3	45970	1892	3071	5682	6954	6781	4751	3908	3521	3203	2878	1877	1453	(12)
(13)		CDH26.7	23931	723	1586	3495	4603	4368	2492	1721	1452	1307	1137	618	429	(13)
(14)	Wind	WSAvg	2.4	1.5	1.6	1.5	1.7	2.7	4.0	4.7	4.2	2.5	1.3	1.3	1.4	(14)
(15)	Precipitation	PrecAvg	590	4	3	7	25	69	66	59	104	119	97	29	8	(15)
(16)		PrecMax	1071	60	29	64	80	212	215	209	332	306	214	103	56	(16)
(17)		PrecMin	295	0	0	0	2	2	2	0	10	6	1	0	0	(17)
(18)		PrecStd	163	11	6	16	23	52	54	55	75	78	55	34	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	37.5	40.5	42.0	41.6	39.5	36.1	35.5	35.2	34.9	32.7	32.6	(19)
(20)			MCWB	19.7	20.7	22.5	24.4	23.8	24.1	23.7	23.9	23.6	22.3	21.8	21.1	(20)
(21)		2%	DB	32.4	35.9	39.2	40.6	40.5	37.3	34.9	34.2	34.1	33.6	31.7	31.0	(21)
(22)			MCWB	19.6	20.4	22.1	23.3	24.0	24.7	23.6	23.5	23.4	22.6	21.7	20.3	(22)
(23)		5%	DB	31.4	34.8	38.3	39.8	39.5	36.0	33.9	33.3	33.1	32.6	30.8	29.9	(23)
(24)			MCWB	19.5	20.0	21.5	23.1	24.1	24.4	23.6	23.4	23.4	22.8	21.5	19.9	(24)
(25)		10%	DB	30.4	33.6	37.2	38.8	38.4	34.8	32.9	32.4	32.1	31.6	30.0	29.0	(25)
(26)			MCWB	19.2	19.6	21.1	23.0	24.0	24.3	23.5	23.4	23.5	23.0	21.4	19.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	24.6	26.7	27.8	28.7	27.8	25.9	26.0	26.6	26.2	25.0	23.7	(27)
(28)			MCD B	29.2	31.5	35.3	37.3	37.4	33.8	31.7	31.3	31.5	30.8	29.7	28.5	(28)
(29)		2%	WB	22.3	23.3	25.2	26.2	27.4	26.6	25.1	25.2	25.8	25.3	24.1	22.9	(29)
(30)			MCD B	28.2	30.2	33.4	35.8	35.7	32.8	31.4	30.3	30.6	30.0	28.3	27.4	(30)
(31)		5%	WB	21.6	22.5	24.3	25.4	26.4	25.8	24.6	24.8	25.2	24.9	23.6	22.3	(31)
(32)			MCD B	27.5	29.6	32.7	35.0	34.6	32.4	30.9	29.8	29.8	29.4	27.6	26.6	(32)
(33)		10%	WB	21.0	21.7	23.5	24.7	25.6	25.2	24.2	24.3	24.7	24.5	23.2	21.6	(33)
(34)			MCD B	26.9	29.2	32.4	34.4	33.8	31.9	30.4	29.4	29.3	28.8	27.1	26.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.8	13.0	13.2	11.9	11.3	9.1	8.1	7.8	8.0	8.3	8.9	10.6	(35)
(36)			MCD BR	13.1	14.5	14.1	12.9	12.4	10.7	9.4	9.1	9.7	10.2	10.3	12.0	(36)
(37)			MCWBR	4.1	4.8	5.2	4.9	4.1	2.7	2.2	2.1	2.7	3.1	3.3	4.0	(37)
(38)		5% WB	MCD BR	10.5	11.5	12.3	11.9	11.4	9.4	8.4	7.8	8.0	7.9	7.5	8.7	(38)
(39)			MCWBR	4.0	4.5	5.4	5.1	4.6	3.4	2.7	2.7	3.2	3.0	2.9	3.6	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.435	0.446	0.516	0.561	0.586	0.518	0.513	0.497	0.487	0.527	0.474	0.464	(41)	
(42)		taud	2.155	2.132	1.953	1.879	1.842	2.061	2.078	2.135	2.164	2.022	2.130	2.098	(42)	
(43)		Ebn at Noon	855	864	812	773	741	785	791	813	824	781	811	813	(43)	
		Edh at Noon	147	157	192	207	211	168	165	158	153	173	150	152		
(44)	All-Sky Solar Radiation	RadAvg	5.27	6.07	6.54	6.74	6.43	5.34	4.67	4.79	5.07	4.99	4.73	4.74	(44)	
(45)		RadStd	0.20	0.23	0.21	0.18	0.24	0.36	0.31	0.21	0.36	0.43	0.34	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.67	+0.54	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.28	+0.32	N/A	+0.54	+0.23	N/A	N/A	N/A	+171	+172

Nomenclature: See separate page