

MO AMINI, India

WMO: 433110

Lat: 11.1178N

Lon: 72.7168E

Elev: 3

StdP: 101.29

Time Zone: 5.50 (IND)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.6	24.2	19.9	14.6	25.9	20.7	15.4	26.6	4.4	29.6	4.0	29.5	0.4	270	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	4.9	34.5	28.3	33.9	27.9	33.4	27.7	29.4	32.4	29.1	32.0	28.7	31.6	1.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.6	25.1	30.9	28.3	24.5	30.7	28.0	24.2	30.5	96.6	32.8	94.9	32.1	93.4	31.8	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.2	8.5	7.5	21.4	35.7	1.9	0.9	20.0	36.4	18.9	37.0	17.9	37.5	16.5	38.2		
			19.6	29.7	1.1	0.3	18.8	30.0	18.1	30.2	17.5	30.3	16.7	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	28.3	29.0	29.8	30.6	30.6	28.8	28.3	28.2	28.1	28.4	28.5	28.3
	DBStd	1.32	0.87	0.82	0.89	0.86	1.38	1.17	0.93	0.87	0.95	0.95	0.90	0.89
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6904	568	532	614	619	640	563	567	563	544	570	556	568
	CDD18.3	3862	310	298	356	369	382	313	308	305	294	312	306	309
	CDH23.3	46653	3318	3456	4497	4996	5242	3964	3716	3561	3372	3619	3514	3396
	CDH26.7	18840	1249	1387	2059	2602	2781	1598	1277	1132	1030	1231	1278	1216
Wind	WSAvg	2.1	0.9	1.1	1.0	1.1	1.7	4.4	5.5	3.9	2.6	1.4	0.6	0.8
Precipitation	PrecAvg	1564	3	4	1	25	165	397	355	249	159	132	101	45
	PrecMax	2406	25	38	11	90	438	837	745	483	438	431	379	167
	PrecMin	948	0	0	0	0	0	105	94	34	32	33	2	0
	PrecStd	389	7	10	3	23	149	181	168	145	113	100	97	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.7	34.6	35.1	35.3	32.6	31.1	31.0	32.2	32.7	33.1	33.0
		MCWB	26.9	27.2	27.9	28.5	28.8	28.2	28.2	27.5	28.5	27.7	27.5	27.0
	2%	DB	32.6	33.1	33.7	34.4	34.7	31.6	30.5	30.3	31.1	32.0	32.4	32.4
		MCWB	26.6	27.0	27.5	28.1	28.6	28.1	27.8	27.3	27.6	27.4	27.3	26.7
	5%	DB	32.1	32.6	33.2	33.8	34.1	30.8	30.1	29.9	30.3	31.3	31.9	31.8
		MCWB	26.2	26.8	27.3	27.9	28.3	28.0	27.6	27.2	27.1	27.1	27.1	26.4
	10%	DB	31.5	32.1	32.6	33.2	33.3	30.4	29.7	29.5	29.8	30.6	31.3	31.2
		MCWB	25.9	26.6	27.1	27.7	28.1	27.8	27.4	27.1	26.9	26.9	26.9	26.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.9	29.2	29.6	29.7	29.4	29.0	28.7	29.2	28.7	28.7	28.6
		MCDB	32.1	32.6	33.1	33.5	33.1	30.8	30.1	30.0	31.4	31.6	31.8	31.9
	2%	WB	27.5	28.1	28.6	29.1	29.5	28.9	28.5	28.2	28.2	28.1	28.2	27.9
		MCDB	31.6	32.0	32.6	33.0	32.8	30.5	29.7	29.5	30.2	30.8	31.4	31.2
	5%	WB	27.0	27.5	28.1	28.7	29.1	28.6	28.2	27.9	27.7	27.7	27.8	27.3
		MCDB	31.2	31.6	32.0	32.5	32.5	30.2	29.3	29.2	29.6	30.2	30.8	30.5
	10%	WB	26.5	26.9	27.5	28.3	28.8	28.2	27.9	27.6	27.3	27.3	27.4	26.8
		MCDB	30.5	31.2	31.3	32.0	32.0	29.9	29.1	28.9	29.1	29.6	30.3	29.9
Mean Daily Temperature Range	5% DB	MDBR	7.0	6.7	6.1	5.4	4.9	3.0	2.3	2.5	3.1	4.3	5.5	6.1
		MCDBR	7.3	7.1	6.7	6.1	5.9	3.3	2.5	2.8	3.9	5.5	6.4	6.8
		MCWBR	3.2	2.9	2.7	2.4	2.4	2.0	1.8	1.7	2.0	2.5	3.0	3.0
	5% WB	MCDBR	6.7	6.6	6.2	5.4	5.0	2.9	2.4	2.6	3.3	4.5	5.6	5.8
		MCWBR	3.2	3.2	2.9	2.7	2.5	2.0	2.0	1.9	2.1	2.6	2.9	3.0
Clear-Sky Solar Irradiance	taub	0.486	0.492	0.549	0.574	0.542	0.571	0.612	0.555	0.486	0.502	0.511	0.492	
	taud	2.177	2.158	2.022	1.986	2.093	2.014	1.892	2.051	2.275	2.211	2.156	2.184	
	Ebn at Noon	820	831	789	763	773	740	713	767	830	812	792	804	
	Edh at Noon	148	155	181	186	164	175	198	172	138	145	150	144	
All-Sky Solar Radiation	RadAvg	5.51	6.20	6.58	6.49	5.64	4.36	4.67	5.20	5.49	5.00	4.87	5.06	
	RadStd	0.22	0.18	0.25	0.25	0.53	0.42	0.69	0.65	0.56	0.36	0.31	0.28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page