

KOZHIKODE, India

WMO: 433140

Lat: 11.250N

Lon: 75.783E

Elev: 16

StdP: 14.69

Time Zone: 5.50 (IND)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	72.7	73.7	64.2	90.0	78.2	66.1	96.2	79.3	16.6	79.0	13.0	79.0	2.9	90	0.329

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	12.5	95.3	82.7	94.0	82.1	92.9	81.5	84.3	93.0	83.6	91.9	82.9	90.8	4.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.9	165.9	90.0	81.2	162.3	89.3	80.7	159.5	88.8	48.3	93.2	47.7	92.7	46.9	91.3	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.1	9.7	7.7	DB	66.0	96.0	5.7	2.3	61.9	97.7	58.5	99.1	55.3	100.4	51.1	102.0
			WB	63.5	85.3	3.0	0.7	61.4	85.7	59.6	86.1	58.0	86.5	55.8	87.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.1	82.8	84.2	86.2	86.9	85.6	81.3	79.8	80.3	81.6	82.5	83.0	82.6
	DBStd	3.08	1.59	1.76	1.80	2.29	2.85	2.72	2.43	2.27	1.99	2.26	1.68	2.08
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12064	1018	957	1123	1106	1103	939	924	938	949	1006	989	1012
	CDD65	6589	553	537	658	656	638	489	459	473	499	541	539	547
	CDH74	73974	5947	6399	8674	9063	8427	4904	3923	4162	4989	5731	5882	5873
	CDH80	29815	2451	2801	4319	4839	4192	1505	815	939	1436	1986	2191	2341
(14) Wind	WSAvg	2.7	2.6	3.1	3.3	3.4	3.3	2.8	2.4	2.3	2.5	2.4	2.5	2.4
(15) Precipitation	PrecAvg	122.8	0.1	0.2	0.8	3.4	10.2	30.8	31.8	17.7	10.6	10.9	5.2	1.0
	PrecMax	195.0	1.3	2.6	10.5	15.3	34.0	51.1	68.4	32.0	29.6	31.5	18.6	5.4
	PrecMin	70.2	0.0	0.0	0.0	0.0	0.2	8.5	13.5	6.0	0.8	1.0	0.0	0.0
	PrecStd	24.9	0.3	0.5	1.6	2.8	8.3	9.4	12.2	7.0	7.7	5.7	4.1	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.7	95.3	96.8	98.5	96.9	92.1	89.9	90.0	91.6	93.0	92.8	93.7
		MCWB	78.9	80.1	83.2	84.2	84.6	82.7	82.2	82.4	81.8	82.2	81.0	80.2
	2%	DB	91.6	93.2	94.6	95.3	94.2	90.3	87.8	87.8	89.6	91.1	91.2	91.8
		MCWB	77.9	79.4	81.9	83.4	83.6	82.1	81.0	81.2	80.8	81.1	80.3	79.1
	5%	DB	90.4	91.7	93.2	93.9	92.8	88.5	86.0	86.1	88.0	89.5	89.9	90.4
		MCWB	77.5	78.8	81.0	82.9	82.9	81.3	80.5	80.3	80.0	80.5	79.6	78.3
	10%	DB	89.2	90.4	91.9	92.6	91.6	86.7	84.3	84.8	86.4	88.0	88.7	89.0
		MCWB	77.1	78.4	80.6	82.3	82.4	80.7	79.7	79.7	79.6	80.0	79.2	77.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.3	82.7	84.1	85.2	85.2	83.8	82.9	82.8	82.8	83.2	82.6	81.9
		MCDB	90.1	91.6	94.4	95.3	93.8	89.7	88.0	88.5	89.7	91.0	90.5	90.9
	2%	WB	79.8	81.0	82.8	84.3	84.3	82.7	81.7	81.6	81.5	81.9	81.5	80.6
		MCDB	88.7	90.1	92.4	93.7	92.7	88.4	86.4	86.8	87.9	89.3	89.3	89.3
	5%	WB	78.9	80.2	82.0	83.5	83.5	81.8	80.7	80.7	80.6	81.0	80.7	79.7
		MCDB	88.0	89.1	91.1	92.5	91.5	87.1	85.0	85.3	86.6	88.0	88.3	88.0
	10%	WB	78.1	79.4	81.3	82.8	82.8	81.0	79.9	79.9	79.8	80.3	80.0	78.8
		MCDB	87.0	88.2	90.1	91.3	90.2	85.8	83.6	83.9	85.2	86.8	86.9	86.7
(35) Mean Daily Temperature Range	5% DB	MDBR	15.1	14.2	13.0	12.5	11.5	8.9	8.1	8.3	9.8	11.4	12.5	14.6
		MCDBR	15.9	15.3	14.0	13.6	12.7	11.5	10.7	10.5	12.1	13.4	14.0	15.6
		MCWBR	7.0	6.3	5.7	6.4	6.0	5.7	5.9	5.6	5.5	5.8	5.8	6.7
	5% WB	MCDBR	14.7	14.0	13.1	13.0	12.4	10.6	9.9	10.0	11.0	12.5	13.0	14.2
		MCWBR	7.1	6.4	5.7	6.6	6.4	5.9	6.0	5.7	5.6	5.9	5.9	6.5
(40) Clear-Sky Solar Irradiance	taub		0.495	0.522	0.584	0.612	0.568	0.531	0.560	0.523	0.484	0.536	0.524	0.480
	taud		2.124	2.050	1.923	1.883	2.006	2.121	2.018	2.136	2.267	2.086	2.095	2.203
	Ebn at Noon		257	255	242	233	239	245	239	251	264	248	247	259
	Edh at Noon		49	55	63	65	56	50	56	50	44	52	50	45
(44) All-Sky Solar Radiation	RadAvg		1779	1981	2064	1975	1752	1306	1304	1448	1659	1562	1549	1625
	RadStd		60	70	80	77	136	113	148	120	158	96	91	82

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+1.17	+1.13	N/A	+2.00	+0.59	+0.54	N/A	N/A	N/A	N/A

Nomenclature: See separate page