

KOZHIKODE, India

WMO: 433140

Lat: 11.250N

Lon: 75.783E

Elev: 5

StdP: 101.26

Time Zone: 5.50 (IND)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	23.1	17.9	12.9	25.7	18.9	13.7	26.3	7.4	26.1	5.8	26.1	1.3	90	0.329

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.9	35.2	28.2	34.5	27.8	33.8	27.5	29.0	33.9	28.6	33.3	28.3	32.7	1.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.7	32.2	27.3	23.2	31.9	27.1	22.8	31.6	94.6	34.0	93.0	33.7	91.2	32.9	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.3	3.4	18.9	35.6	3.2	1.3	16.6	36.5	14.7	37.3	12.9	38.0	10.6	38.9		
			17.5	29.6	1.7	0.4	16.3	29.9	15.4	30.1	14.4	30.3	13.2	30.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	28.2	29.0	30.1	30.5	29.8	27.4	26.6	26.8	27.6	28.0	28.3	28.1
	DBStd	1.71	0.89	0.98	1.00	1.27	1.58	1.51	1.35	1.26	1.10	1.26	0.93	1.15
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6702	566	532	624	614	613	522	513	521	527	559	549	562
	CDD18.3	3661	307	298	366	364	354	272	255	263	277	301	299	304
	CDH23.3	41097	3304	3555	4819	5035	4682	2724	2179	2312	2772	3184	3268	3263
	CDH26.7	16564	1362	1556	2399	2688	2329	836	453	522	798	1103	1217	1301
(14) Wind	WSAvg	1.2	1.2	1.4	1.5	1.5	1.5	1.2	1.1	1.0	1.1	1.1	1.1	1.1
(15) Precipitation	PrecAvg	3118	2	4	21	86	259	783	807	449	270	278	133	26
	PrecMax	4952	32	65	267	388	864	1299	1738	812	752	800	473	138
	PrecMin	1782	0	0	0	0	6	215	344	152	21	26	0	0
	PrecStd	633	7	12	41	72	210	239	311	178	196	145	104	34
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.3	35.2	36.0	36.9	36.0	33.4	32.2	32.2	33.1	33.9	33.8	34.3
		MCWB	26.0	26.7	28.4	29.0	29.2	28.2	27.9	28.0	27.7	27.9	27.2	26.8
	2%	DB	33.1	34.0	34.8	35.2	34.6	32.4	31.0	31.0	32.0	32.8	32.9	33.2
		MCWB	25.5	26.3	27.7	28.5	28.6	27.8	27.2	27.3	27.1	27.3	26.8	26.2
	5%	DB	32.4	33.2	34.0	34.4	33.8	31.4	30.0	30.1	31.1	32.0	32.2	32.4
		MCWB	25.3	26.0	27.2	28.3	28.3	27.4	26.9	26.8	26.7	27.0	26.5	25.7
	10%	DB	31.8	32.4	33.3	33.7	33.1	30.4	29.1	29.3	30.2	31.1	31.5	31.7
		MCWB	25.1	25.8	27.0	28.0	28.0	27.0	26.5	26.5	26.4	26.7	26.2	25.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	28.2	28.9	29.5	29.6	28.8	28.3	28.2	28.2	28.4	28.1	27.7
		MCDB	32.3	33.1	34.7	35.1	34.4	32.1	31.1	31.4	32.1	32.8	32.5	32.7
	2%	WB	26.6	27.2	28.2	29.0	29.1	28.2	27.6	27.6	27.5	27.7	27.5	27.0
		MCDB	31.5	32.3	33.6	34.3	33.7	31.3	30.2	30.4	31.1	31.8	31.8	31.9
	5%	WB	26.1	26.8	27.8	28.6	28.6	27.7	27.1	27.1	27.0	27.2	27.1	26.5
		MCDB	31.1	31.7	32.8	33.6	33.0	30.6	29.5	29.6	30.3	31.1	31.3	31.1
	10%	WB	25.6	26.3	27.4	28.2	28.2	27.2	26.6	26.6	26.6	26.8	26.6	26.0
		MCDB	30.5	31.2	32.3	32.9	32.4	29.9	28.7	28.9	29.6	30.5	30.5	30.4
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	7.9	7.2	6.9	6.4	5.0	4.5	4.6	5.4	6.3	6.9	8.1
		MCDBR	8.8	8.5	7.8	7.6	7.1	6.4	5.9	5.8	6.7	7.4	7.8	8.7
		MCWBR	3.9	3.5	3.2	3.6	3.3	3.1	3.3	3.1	3.0	3.2	3.2	3.7
	5% WB	MCDBR	8.2	7.8	7.3	7.2	6.9	5.9	5.5	5.5	6.1	7.0	7.2	7.9
		MCWBR	3.9	3.6	3.1	3.7	3.5	3.3	3.3	3.2	3.1	3.3	3.3	3.6
(40) Clear-Sky Solar Irradiance	taub		0.495	0.522	0.584	0.612	0.568	0.531	0.560	0.523	0.484	0.536	0.524	0.480
	taud		2.124	2.050	1.923	1.883	2.006	2.121	2.018	2.136	2.267	2.086	2.095	2.203
	Ebn at Noon		811	804	762	735	753	772	752	792	831	782	778	815
	Edh at Noon		155	173	199	206	178	157	175	158	139	164	159	141
(44) All-Sky Solar Radiation	RadAvg		5.61	6.24	6.51	6.23	5.52	4.12	4.11	4.57	5.23	4.92	4.88	5.12
	RadStd		0.19	0.22	0.25	0.24	0.43	0.36	0.47	0.38	0.50	0.30	0.29	0.26

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+0.65	+0.63	N/A	+1.11	+0.33	+0.30	N/A	N/A	N/A	N/A

Nomenclature: See separate page