

MINICOY, India

WMO: 433690

Lat: 8.281N

Lon: 73.054E

Elev: 2

StdP: 101.30

Time Zone: 5.50 (IND)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.3	23.9	20.2	14.9	27.1	20.9	15.5	27.0	5.3	28.3	4.7	28.9	0.6	270	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	5.2	33.4	27.8	33.0	27.6	32.5	27.4	28.6	32.0	28.2	31.7	28.0	31.5	2.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.5	30.9	27.2	23.0	30.6	27.0	22.7	30.5	92.3	32.4	90.8	32.0	89.6	31.6	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.7	6.2	5.2	20.4	34.4	2.6	1.3	18.6	35.3	17.1	36.1	15.6	36.9	13.8	37.8
			19.4	29.3	2.1	0.4	17.9	29.6	16.7	29.9	15.5	30.1	14.0	30.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	27.9	28.1	29.2	30.0	29.8	28.8	28.4	28.4	28.3	28.2	28.0	28.0	(6)
	DBStd	1.24	0.78	0.89	0.87	0.99	1.21	1.25	1.25	1.13	1.10	1.03	0.91	0.90	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	6788	554	508	597	599	614	563	571	571	548	566	541	557	(10)
	CDD18.3	3746	296	275	338	349	356	313	312	312	298	307	291	299	(11)
	CDH23.3	44013	3176	3063	4189	4622	4661	3768	3623	3602	3358	3437	3209	3303	(12)
	CDH26.7	16602	1022	1070	1795	2250	2211	1448	1263	1238	1089	1121	1026	1068	(13)
(14) Wind	WSAvg	1.9	1.2	1.4	1.3	1.4	2.0	3.4	3.4	2.8	2.3	1.7	1.0	1.2	(14)
(15) Precipitation	PrecAvg	1584	37	20	28	52	154	292	258	198	150	169	154	72	(15)
	PrecMax	1928	127	131	236	182	359	687	422	370	363	308	426	223	(16)
	PrecMin	936	3	0	0	0	49	109	56	30	17	43	37	1	(17)
	PrecStd	250	34	30	55	44	78	105	88	85	82	68	88	71	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	32.1	33.2	33.9	34.1	33.0	32.2	32.2	32.2	32.2	32.0	32.0	(19)
		MCWB	26.0	26.3	27.1	28.1	28.1	28.2	27.7	27.4	27.0	27.0	27.0	26.7	(20)
	2%	DB	31.2	31.7	32.8	33.4	33.4	32.2	31.7	31.7	31.6	31.7	31.5	31.4	(21)
		MCWB	25.8	26.1	26.9	27.8	27.9	27.9	27.5	27.3	26.9	26.9	26.6	26.3	(22)
	5%	DB	30.9	31.3	32.4	33.0	33.0	31.8	31.3	31.2	31.1	31.2	31.1	31.0	(23)
		MCWB	25.6	25.9	26.8	27.6	27.8	27.7	27.3	27.1	26.8	26.8	26.4	26.0	(24)
	10%	DB	30.5	30.9	31.9	32.5	32.4	31.3	30.8	30.7	30.6	30.7	30.6	30.5	(25)
		MCWB	25.5	25.8	26.6	27.4	27.7	27.5	27.1	26.9	26.7	26.6	26.3	25.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.2	28.0	28.8	28.9	28.7	28.2	28.1	28.0	28.1	27.8	28.1	(27)
		MCDB	30.5	31.0	32.2	32.6	32.6	31.9	31.3	31.3	31.1	31.1	30.9	30.7	(28)
	2%	WB	26.7	26.7	27.5	28.4	28.6	28.2	27.8	27.7	27.5	27.6	27.2	27.2	(29)
		MCDB	30.0	30.5	31.7	32.3	32.2	31.4	30.9	30.9	30.6	30.6	30.3	30.1	(30)
	5%	WB	26.3	26.5	27.1	28.0	28.2	28.0	27.5	27.4	27.1	27.2	27.0	26.7	(31)
		MCDB	29.7	30.2	31.3	32.0	31.8	31.2	30.5	30.5	30.3	30.2	30.0	29.6	(32)
	10%	WB	26.0	26.1	26.8	27.7	27.9	27.6	27.2	27.1	26.8	26.9	26.6	26.4	(33)
		MCDB	29.3	29.8	30.8	31.5	31.4	30.6	30.0	30.2	29.8	29.8	29.5	29.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	5.9	5.7	5.2	4.8	4.4	4.2	4.4	4.5	4.9	5.1	5.4	(35)
		MCDBR	6.0	6.2	5.8	5.3	5.2	4.9	4.7	4.9	5.0	5.4	5.6	5.7	(36)
	5% WB	MCWBR	2.3	2.4	2.1	2.2	2.2	2.4	2.4	2.4	2.4	2.5	2.4	2.4	(37)
		MCWBR	5.4	5.7	5.6	5.2	4.9	4.8	4.5	4.7	4.7	4.9	5.1	5.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.475	0.483	0.528	0.529	0.510	0.526	0.550	0.505	0.460	0.460	0.468	0.479	(40)
		taud	2.238	2.213	2.103	2.127	2.205	2.151	2.055	2.213	2.367	2.360	2.315	2.256	(41)
	Ebn at Noon		839	845	809	797	795	772	757	806	854	855	840	827	(42)
		Edh at Noon	141	148	167	161	146	151	168	146	127	126	130	136	(43)
(44) All-Sky Solar Radiation	RadAvg		5.74	6.24	6.49	6.21	5.34	4.70	4.99	5.40	5.58	5.35	4.91	5.19	(44)
	RadStd		0.20	0.25	0.33	0.35	0.59	0.41	0.49	0.44	0.56	0.39	0.34	0.31	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page