

TRINCOMALEE CHINA BAY, Sri Lanka

WMO: 434180

Lat: 8.539N

Lon: 81.182E

Elev: 6

StdP: 14.69

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.2	73.7	65.0	92.5	78.8	66.4	97.2	79.9	14.1	76.4	12.0	77.8	4.5	320	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.5	97.1	78.5	95.8	78.6	94.6	78.6	82.1	90.4	81.6	89.8	81.0	89.1	7.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	155.8	86.6	79.3	152.1	86.0	78.9	150.0	85.6	45.9	90.9	45.2	90.2	44.7	89.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	13.2	11.6	DB	67.7	100.1	3.6	1.4	65.1	101.1	63.0	101.9	61.0	102.7	58.4	103.7	(4)
(5)			WB	65.3	83.9	2.4	0.6	63.6	84.3	62.2	84.7	60.9	85.0	59.2	85.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.5	79.1	80.5	82.6	85.3	86.5	86.7	86.6	85.9	85.7	83.0	80.5	79.3
	DBStd	3.54	2.06	1.92	1.65	1.78	2.31	1.97	1.82	2.19	2.40	2.79	1.80	2.13
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12221	902	854	1009	1058	1131	1100	1135	1113	1070	1023	916	910
	CDD65	6746	437	434	544	608	666	650	670	648	620	558	466	445
	CDH74	76096	3669	4144	6134	7707	8482	8365	8372	7786	7343	5922	4360	3812
	CDH80	30262	507	909	2108	3558	4198	4123	4044	3608	3351	2223	1028	605
Wind	WSAvg	4.9	4.2	3.9	3.5	3.4	5.7	7.6	6.9	6.5	5.8	3.9	3.5	4.3
Precipitation	PrecAvg	62.0	6.3	3.7	1.9	1.8	2.0	1.0	2.4	3.2	4.5	8.1	14.0	13.4
	PrecMax	101.6	25.9	28.3	9.4	8.3	6.5	7.1	8.6	12.9	17.5	22.3	28.8	31.4
	PrecMin	30.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	1.0	2.2	0.4
	PrecStd	14.9	5.6	4.9	2.2	1.7	1.5	1.6	2.4	2.9	3.5	5.0	6.6	7.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.9	88.1	91.7	96.2	97.8	97.9	97.8	97.8	98.5	97.0	89.0	87.0
		MCWB	77.8	78.9	79.4	79.6	80.3	79.2	78.1	77.4	78.1	76.3	79.5	78.5
	2%	DB	84.6	86.5	89.9	93.8	96.0	95.9	95.9	95.6	96.0	93.8	87.4	85.3
		MCWB	76.6	77.9	79.2	80.6	80.2	78.9	78.0	77.9	77.7	77.8	78.8	78.1
	5%	DB	83.6	85.6	88.8	92.2	94.6	94.3	94.5	94.0	94.2	91.5	86.3	84.3
		MCWB	75.9	77.2	79.0	80.6	80.1	78.6	78.0	77.8	77.9	78.0	78.7	77.6
	10%	DB	82.7	84.5	87.6	91.0	93.0	92.7	93.0	92.4	92.4	89.1	85.0	83.2
		MCWB	75.4	76.6	78.7	80.4	80.1	78.4	78.0	77.5	77.9	78.3	78.4	77.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	80.6	81.7	82.8	82.9	81.7	81.3	81.4	82.0	81.5	81.1	80.3
		MCDB	83.7	86.2	88.9	90.8	91.8	91.3	90.2	89.1	90.0	88.0	86.4	84.3
	2%	WB	78.5	79.2	80.8	82.0	82.1	80.3	80.2	80.1	80.7	80.6	80.1	79.5
		MCDB	82.6	84.3	87.6	90.2	91.0	91.7	89.9	89.1	88.6	87.0	85.2	83.3
	5%	WB	77.8	78.6	80.0	81.5	81.5	79.5	79.4	79.3	79.8	79.9	79.6	78.8
		MCDB	81.6	83.4	86.6	89.6	90.6	91.0	90.1	89.0	88.3	86.4	84.4	82.5
	10%	WB	77.1	78.0	79.4	80.9	80.9	78.9	78.7	78.6	79.1	79.3	78.9	78.2
		MCDB	80.6	82.6	85.7	88.9	90.2	90.5	90.1	88.7	88.1	85.8	83.5	81.6
Mean Daily Temperature Range	5% DB	MDBR	7.3	8.0	10.7	13.0	14.1	13.5	14.7	14.8	15.2	12.8	9.0	7.2
		MCDBR	8.3	9.2	12.2	14.3	15.9	15.4	16.3	16.5	17.4	16.7	10.8	8.7
		MCWBR	4.4	4.3	4.7	4.7	5.2	4.0	4.3	4.5	4.9	5.4	5.1	4.5
	5% WB	MCDBR	6.8	8.3	11.1	13.0	14.5	14.4	15.2	15.2	15.4	13.2	9.8	7.7
		MCWBR	4.2	4.3	4.9	4.9	5.9	4.4	5.4	5.5	6.1	5.7	5.1	4.3
Clear-Sky Solar Irradiance	taub	0.448	0.443	0.460	0.463	0.521	0.496	0.513	0.495	0.469	0.470	0.461	0.470	
	taud	2.317	2.314	2.274	2.315	2.133	2.225	2.155	2.218	2.303	2.304	2.325	2.266	
	Ebn at Noon	274	279	275	270	250	252	249	258	268	268	268	265	
	Edh at Noon	41	43	45	43	49	45	48	46	43	43	41	43	
All-Sky Solar Radiation	RadAvg	1466	1721	1927	1925	1833	1790	1794	1815	1828	1648	1343	1274	
	RadStd	137	116	91	82	106	80	61	74	106	72	113	139	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page