

TRINCOMALEE CHINA BAY, Sri Lanka

WMO: 434180

Lat: 8.539N

Lon: 81.182E

Elev: 2

StdP: 101.30

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.4	23.1	18.3	13.2	26.0	19.1	13.9	26.6	6.3	24.6	5.4	25.4	2.0	320	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.5	36.2	25.8	35.5	25.9	34.8	25.9	27.8	32.4	27.6	32.1	27.2	31.7	3.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.3	30.4	26.3	21.7	30.0	26.1	21.4	29.8	88.9	32.7	87.3	32.3	86.1	32.0	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.7	5.9	5.2	19.8	37.8	2.0	0.8	18.4	38.4	17.2	38.8	16.1	39.3	14.7	39.8		
(5)			18.5	28.8	1.3	0.3	17.6	29.1	16.8	29.3	16.1	29.5	15.1	29.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	26.2	26.9	28.1	29.6	30.3	30.4	30.3	29.9	29.8	28.3	27.0	26.3	(6)	(7)
	DBStd	1.97	1.14	1.07	0.92	0.99	1.29	1.09	1.01	1.22	1.33	1.55	1.00	1.18	(7)	(8)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	(9)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	(10)
	CDD10.0	6789	501	474	561	588	628	611	631	618	594	568	509	506	(10)	(11)
	CDD18.3	3748	243	241	302	338	370	361	372	360	344	310	259	247	(11)	(12)
	CDH23.3	42276	2038	2302	3408	4282	4712	4647	4651	4326	4079	3290	2422	2118	(12)	(13)
	CDH26.7	16812	282	505	1171	1977	2332	2291	2247	2004	1862	1235	571	336	(13)	(14)
(14) Wind	WSAvg	2.2	1.9	1.7	1.6	1.5	2.6	3.4	3.1	2.9	2.6	1.7	1.5	1.9	(14)	(15)
(15) Precipitation	PrecAvg	1574	160	94	47	46	51	26	60	81	114	206	355	341	(15)	(16)
	PrecMax	2580	659	720	239	212	165	181	219	328	445	566	732	797	(16)	(17)
	PrecMin	765	1	0	0	0	0	0	0	0	2	26	55	11	(17)	(18)
	PrecStd	378	143	125	55	43	39	41	62	73	89	127	167	188	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.0	31.2	33.2	35.7	36.6	36.6	36.5	36.6	36.9	36.1	31.7	30.5	(19)	(20)
		MCWB	25.4	26.0	26.3	26.4	26.8	26.2	25.6	25.2	25.6	24.6	26.4	25.8	(20)	(21)
	2%	DB	29.2	30.3	32.1	34.3	35.6	35.5	35.5	35.3	35.6	34.3	30.8	29.6	(21)	(22)
		MCWB	24.8	25.5	26.2	27.0	26.8	26.1	25.5	25.5	25.4	25.4	26.0	25.6	(22)	(23)
	5%	DB	28.7	29.8	31.6	33.4	34.8	34.6	34.7	34.4	34.5	33.0	30.2	29.0	(23)	(24)
		MCWB	24.4	25.1	26.1	27.0	26.7	25.9	25.6	25.4	25.5	25.5	26.0	25.3	(24)	(25)
	10%	DB	28.2	29.2	30.9	32.8	33.9	33.7	33.9	33.6	33.5	31.7	29.5	28.4	(25)	(26)
		MCWB	24.1	24.8	25.9	26.9	26.7	25.8	25.5	25.3	25.5	25.7	25.8	25.1	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	27.0	27.6	28.2	28.3	27.6	27.4	27.5	27.8	27.5	27.3	26.8	(27)	(28)
		MCDB	28.7	30.1	31.6	32.7	33.2	32.9	32.3	31.7	32.2	31.1	30.2	29.0	(28)	(29)
	2%	WB	25.8	26.2	27.1	27.8	27.8	26.8	26.8	26.7	27.1	27.0	26.7	26.4	(29)	(30)
		MCDB	28.1	29.0	30.9	32.3	32.8	33.2	32.1	31.7	31.4	30.6	29.6	28.5	(30)	(31)
	5%	WB	25.4	25.9	26.7	27.5	27.5	26.4	26.3	26.3	26.6	26.6	26.4	26.0	(31)	(32)
		MCDB	27.5	28.6	30.3	32.0	32.6	32.8	32.3	31.7	31.3	30.2	29.1	28.0	(32)	(33)
	10%	WB	25.0	25.5	26.3	27.2	27.2	26.1	25.9	25.9	26.1	26.3	26.1	25.6	(33)	(34)
		MCDB	27.0	28.1	29.9	31.6	32.3	32.5	32.3	31.5	31.2	29.9	28.6	27.6	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	4.5	5.9	7.2	7.9	7.5	8.2	8.2	8.5	7.1	5.0	4.0	(35)	(36)
		MCDBR	4.6	5.1	6.8	8.0	8.8	8.6	9.0	9.2	9.6	9.3	6.0	4.8	(36)	(37)
	5% WB	MCWBR	2.4	2.4	2.6	2.6	2.9	2.2	2.4	2.5	2.7	3.0	2.8	2.5	(37)	(38)
		MCWBR	3.8	4.6	6.2	7.2	8.0	8.4	8.5	8.6	8.6	7.3	5.5	4.3	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.448	0.443	0.460	0.463	0.521	0.496	0.513	0.495	0.469	0.470	0.461	0.470	(39)	(40)
		taud	2.317	2.314	2.274	2.315	2.133	2.225	2.155	2.218	2.303	2.304	2.325	2.266	(40)	(41)
	Ebn at Noon		865	881	867	852	787	796	786	814	846	845	846	835	(41)	(42)
		Edh at Noon	130	134	141	134	156	141	152	145	135	134	128	135	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		4.62	5.43	6.07	6.07	5.78	5.64	5.66	5.72	5.76	5.19	4.23	4.01	(43)	(44)
	RadStd		0.43	0.37	0.29	0.26	0.33	0.25	0.19	0.23	0.34	0.23	0.36	0.44	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page