

ANURADHAPURA, Sri Lanka

WMO: 434210

Lat: 8.301N

Lon: 80.428E

Elev: 99

StdP: 100.14

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	21.6	17.7	12.8	27.7	18.6	13.6	26.8	3.2	26.3	2.5	26.8	0.1	50	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.1	35.1	25.2	34.4	25.4	33.8	25.5	27.2	32.1	26.9	31.6	26.6	31.2	1.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	21.6	29.1	25.7	21.2	28.8	25.4	20.9	28.6	86.5	32.4	85.1	31.8	83.9	31.5	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.9	3.3	2.9	19.0	36.8	0.7	0.7	18.5	37.3	18.1	37.6	17.7	38.0	17.2	38.5		
(5)			17.8	28.0	0.9	0.4	17.1	28.3	16.6	28.5	16.1	28.7	15.5	28.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	25.8	26.8	28.8	29.3	29.2	28.9	29.2	28.9	28.9	28.0	26.7	26.0		
	DBStd	1.69	1.08	1.26	1.13	1.19	1.00	0.91	0.83	1.00	1.07	1.29	1.03	1.20		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6588	489	470	582	579	595	568	594	587	566	559	502	495		
	CDD18.3	3546	231	237	324	329	337	318	336	328	316	301	252	237		
	CDH23.3	36724	1674	2058	3578	3838	3996	3724	3888	3686	3499	2951	2082	1749		
(13)	CDH26.7	14167	429	719	1606	1763	1704	1458	1581	1477	1404	1072	553	401		
(14)	Wind	WSAvg	0.9	0.6	0.5	0.5	1.3	1.9	1.6	1.4	1.4	0.7	0.3	0.5		
(15) Precipitation	PrecAvg	1309	79	50	64	153	84	8	31	40	61	280	242	217		
	PrecMax	1949	349	152	180	276	239	62	165	218	144	520	395	489		
	PrecMin	862	0	0	1	30	1	0	1	0	15	65	74	69		
	PrecStd	296	103	46	46	57	67	14	43	59	35	126	99	118		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.4	33.2	36.0	36.0	34.9	34.1	35.0	34.7	35.0	35.0	32.2	31.5		
		MCWB	24.5	24.9	24.0	25.3	26.5	26.1	25.4	25.2	25.1	24.6	25.4	24.5		
	2%	DB	30.6	32.2	34.9	35.1	33.9	33.2	33.8	33.7	34.0	33.6	31.4	30.5		
		MCWB	24.0	24.7	24.5	25.7	26.5	25.9	25.5	25.1	25.1	24.9	25.2	24.7		
	5%	DB	29.8	31.4	33.9	34.3	33.2	32.5	33.0	33.0	33.2	32.6	30.6	29.8		
		MCWB	23.6	24.4	24.8	25.9	26.4	25.7	25.3	25.0	25.0	25.2	25.2	24.6		
	10%	DB	29.2	30.6	33.0	33.4	32.5	31.8	32.3	32.2	32.3	31.6	29.8	29.0		
		MCWB	23.5	24.1	24.8	26.1	26.3	25.6	25.2	25.0	25.0	25.2	25.1	24.3		
	0.4%	WB	25.7	26.2	26.7	27.5	27.7	27.1	26.6	26.7	26.5	26.7	26.5	26.4		
		MCDB	29.3	30.5	31.9	33.0	32.5	32.0	32.5	31.8	31.9	31.2	30.1	29.2		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	25.2	25.7	26.2	27.1	27.2	26.6	26.1	26.1	26.0	26.2	26.1	25.7		
		MCDB	28.4	30.0	31.3	32.3	32.0	31.2	31.9	31.3	31.2	30.5	29.6	28.4		
	5%	WB	24.7	25.3	25.9	26.7	27.0	26.2	25.7	25.7	25.7	25.9	25.7	25.4		
		MCDB	27.7	29.3	30.8	31.6	31.6	30.6	31.1	30.6	30.6	30.0	29.0	27.9		
	10%	WB	24.3	25.0	25.5	26.5	26.6	26.0	25.5	25.3	25.4	25.6	25.4	25.0		
		MCDB	27.1	28.7	30.3	31.2	31.0	30.2	30.5	30.0	30.0	29.5	28.4	27.3		
	5% DB	MDBR	7.0	7.9	9.3	8.7	7.1	6.2	7.2	7.4	7.5	7.4	6.1	5.8		
		MCDBR	8.1	9.1	10.3	9.8	8.2	7.2	8.0	8.2	8.7	9.0	7.6	7.3		
		MCWBR	2.6	2.6	2.5	2.6	2.3	1.6	1.7	1.7	1.8	2.2	2.6	2.6		
		MCWBR	6.2	7.7	9.1	8.9	7.4	6.5	7.7	7.6	7.7	7.5	6.5	5.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.435	0.433	0.462	0.475	0.529	0.505	0.518	0.500	0.471	0.473	0.459	0.457		
		taud	2.322	2.305	2.241	2.246	2.076	2.163	2.106	2.169	2.266	2.260	2.299	2.277		
	Ebn at Noon	Ebn at Noon	878	890	865	842	780	789	782	810	845	842	848	847		
		Edh at Noon	130	135	146	143	166	150	159	153	140	140	132	133		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.61	5.50	6.08	5.93	5.65	5.49	5.53	5.56	5.62	5.03	4.17	3.99		
	RadStd	RadStd	0.44	0.36	0.33	0.28	0.37	0.24	0.19	0.25	0.33	0.26	0.35	0.41		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page