

KANDY, Sri Lanka

WMO: 434440

Lat: 7.3344N

Lon: 80.6266E

Elev: 477

StdP: 95.72

Time Zone: 5.50 (IND)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 17.3	(c) 18.5	(d) 14.6	(e) 11.0	(f) 23.5	(g) 15.9	(h) 12.0	(i) 22.8	(j) 3.8	(k) 26.3	(l) 3.3	(m) 26.3	(n) 0.1	(o) N/A	(p) 0.193

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 8.7	(c) 32.2	(d) 23.3	(e) 31.4	(f) 23.6	(g) 30.7	(h) 23.7	(i) 25.4	(j) 29.8	(k) 25.1	(l) 29.3	(m) 24.7	(n) 28.7	(o) 1.3	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	20.3	27.4	23.9	19.8	27.0	23.6	19.5	26.7	81.0	29.9	79.4	29.4	78.1	29.1	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
4.1	3.4	2.8		14.4	33.8	0.7	1.2	13.9	34.6	13.4	35.3	13.0	36.0	12.5	36.9	
			DB	14.1	26.6	0.8	0.5	13.5	26.9	13.1	27.2	12.6	27.5	12.0	27.9	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	23.6	24.7	26.1	26.4	25.9	25.3	25.2	24.9	24.8	24.9	24.6	23.9
	DBStd	1.28	1.36	1.23	1.07	0.96	0.97	0.84	0.74	0.84	0.80	0.86	0.98	1.18
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5484	423	413	498	492	494	458	471	461	445	462	438	429
	CDD18.3	2442	164	179	240	242	236	208	212	202	195	204	188	171
	CDH23.3	15468	925	1207	1938	1815	1766	1322	1315	1168	1130	1156	945	782
Wind	WSAvg	0.7	0.6	0.7	0.6	0.4	0.7	1.2	1.3	0.9	0.8	0.6	0.4	0.5
	PrecAvg	1894	76	81	66	193	151	121	127	112	156	294	323	198
Precipitation	PrecMax	2366	259	315	123	339	412	194	237	254	405	512	500	393
	PrecMin	1437	0	0	27	57	1	30	25	41	20	138	89	58
	PrecStd	255	67	77	29	61	105	43	58	55	93	102	127	87
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.6	31.8	33.9	32.9	32.0	30.2	30.6	30.4	30.4	31.0	30.4	30.0
		MCWB	22.4	22.6	21.8	24.2	25.2	24.4	23.9	24.1	23.7	23.1	23.9	23.1
	2%	DB	29.5	30.9	32.6	31.9	30.9	29.4	29.2	29.3	29.4	30.1	29.5	29.1
		MCWB	22.5	22.7	22.3	24.6	24.8	24.1	23.6	23.7	23.6	23.3	23.6	22.9
	5%	DB	28.6	30.0	31.6	31.1	30.2	28.5	28.5	28.5	28.7	29.3	28.9	28.2
		MCWB	22.1	22.5	22.7	24.6	24.6	23.8	23.4	23.3	23.4	23.4	23.4	22.8
	10%	DB	27.8	29.1	30.7	30.2	29.4	27.8	27.7	27.7	28.0	28.3	28.0	27.3
		MCWB	21.9	22.4	22.8	24.4	24.4	23.5	23.2	23.1	23.2	23.3	23.4	22.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.2	24.5	25.0	26.1	26.0	25.1	24.6	24.7	24.7	24.9	24.8	24.7
		MCDB	28.4	29.6	29.9	30.9	30.5	29.1	28.6	28.8	28.7	28.7	28.5	27.8
	2%	WB	23.6	23.9	24.5	25.5	25.4	24.5	24.1	24.1	24.2	24.2	24.3	24.2
		MCDB	27.5	28.8	29.3	30.0	29.7	28.2	28.0	28.1	28.0	27.9	27.9	27.2
	5%	WB	23.1	23.5	24.1	25.1	25.0	24.1	23.7	23.7	23.8	24.0	24.0	23.6
		MCDB	26.7	28.0	28.9	29.4	29.2	27.5	27.4	27.4	27.4	27.6	27.4	26.6
	10%	WB	22.6	23.0	23.7	24.7	24.7	23.8	23.4	23.3	23.4	23.6	23.6	23.2
		MCDB	26.0	27.1	28.2	28.7	28.4	26.9	26.9	26.8	26.8	26.9	26.7	25.9
Mean Daily Temperature Range	5% DB	MDBR	8.5	9.3	10.2	8.7	7.2	5.3	5.4	6.0	6.6	7.4	7.1	6.7
		MCDBR	10.1	11.0	11.6	9.7	8.8	6.6	7.0	7.6	8.1	9.1	8.4	8.8
		MCWBR	4.1	3.9	3.6	3.3	3.4	2.6	2.7	3.0	3.2	3.3	3.3	3.6
	5% WB	MCDBR	7.9	8.7	9.8	8.6	7.8	5.8	6.0	6.6	7.2	7.5	7.4	6.9
		MCWBR	3.5	3.6	3.6	3.3	3.3	2.6	2.7	2.8	3.1	3.2	3.3	3.3
Clear-Sky Solar Irradiance	taub		0.401	0.407	0.438	0.455	0.475	0.453	0.470	0.454	0.431	0.439	0.426	0.415
	taud		2.393	2.357	2.283	2.276	2.222	2.306	2.232	2.286	2.361	2.332	2.371	2.377
	Ebn at Noon		913	917	887	859	823	831	821	848	880	875	882	892
	Edh at Noon		121	129	140	139	143	129	140	136	128	130	123	121
All-Sky Solar Radiation	RadAvg		4.70	5.51	6.03	5.76	5.35	5.11	5.13	5.21	5.33	5.04	4.35	4.14
	RadStd		0.46	0.35	0.34	0.28	0.37	0.26	0.24	0.24	0.35	0.27	0.35	0.43

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page