

NUWARA ELIYA, Sri Lanka

WMO: 434730

Lat: 6.9698N

Lon: 80.7789E

Elev: 6168

StdP: 11.70

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.7	48.1	27.9	27.4	53.8	32.3	33.7	55.5	18.0	55.8	15.5	57.0	0.2	50	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.4	73.6	60.8	72.1	60.6	71.0	60.7	65.4	70.3	64.5	69.3	63.8	68.4	3.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	111.3	68.2	62.8	108.0	67.2	62.1	105.2	66.3	34.0	70.6	33.3	69.6	32.7	68.8	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.9	17.8	14.9	DB	41.6	81.9	2.2	2.3	40.0	83.6	38.7	84.9	37.5	86.2	35.8	87.8	
			WB	35.5	72.7	1.3	4.0	34.5	75.6	33.8	77.9	33.1	80.1	32.1	83.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	59.0	60.4	61.7	62.7	63.4	61.6	61.2	61.4	61.3	61.2	60.9	59.8	(6)
	DBStd	2.18	2.47	2.40	1.95	1.49	1.47	1.70	1.91	1.80	1.50	1.50	1.49	2.25	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	1395	187	130	105	69	51	103	120	115	112	117	124	162	(9)
	CDD50	4095	278	291	362	382	417	348	346	352	339	348	327	305	(10)
	CDD65	16	1	1	2	1	3	1	2	2	0	1	1	1	(11)
	CDH74	38	3	7	6	4	6	1	4	4	0	1	1	1	(12)
	CDH80	2	0	1	0	0	0	0	0	1	0	0	0	0	(13)
(14) Wind	WSAvg	4.5	2.6	3.5	2.7	1.9	3.3	9.3	8.6	7.1	6.1	3.1	2.7	3.2	(14)
(15) Precipitation	PrecAvg	76.0	4.1	3.4	2.4	6.3	6.6	5.8	6.7	5.9	7.2	8.9	8.8	8.1	(15)
	PrecMax	102.6	7.5	9.4	5.7	12.9	16.7	15.9	14.0	12.6	16.8	17.8	22.0	14.9	(16)
	PrecMin	51.1	0.0	0.0	0.1	0.7	0.9	1.6	1.4	1.4	1.4	2.9	3.0	0.7	(17)
	PrecStd	13.5	2.2	2.9	1.6	2.7	3.9	3.1	3.3	2.7	4.5	4.0	4.1	3.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.8	74.2	74.8	74.5	74.9	71.5	71.7	71.4	71.5	70.9	69.9	70.4	(19)
		MCWB	57.7	58.9	58.6	62.6	63.1	64.2	62.5	62.6	62.5	61.8	61.1	58.4	(20)
	2%	DB	69.4	71.3	72.8	72.9	72.7	68.5	68.9	68.8	68.9	68.9	68.3	68.1	(21)
		MCWB	57.3	56.3	57.4	61.8	63.3	62.8	61.6	61.9	62.1	62.2	61.4	60.1	(22)
	5%	DB	67.4	69.3	71.3	71.6	71.0	66.5	66.8	66.9	67.2	67.5	67.1	66.7	(23)
		MCWB	58.5	57.9	57.9	62.3	63.3	61.7	61.0	61.2	61.3	61.7	61.2	60.2	(24)
	10%	DB	65.8	67.5	69.8	70.1	69.6	64.8	64.9	65.2	65.6	66.2	65.8	65.0	(25)
		MCWB	58.8	58.6	58.7	62.2	63.2	60.8	60.2	60.5	60.6	61.3	60.9	59.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.3	63.9	64.7	66.4	66.4	65.2	64.0	64.1	64.1	64.7	63.9	63.9	(27)
		MCDB	67.4	69.0	70.3	71.2	71.6	69.8	69.0	68.7	68.7	68.8	67.4	67.1	(28)
	2%	WB	61.9	62.6	63.6	65.0	65.3	63.3	62.7	62.9	63.0	63.4	62.9	62.7	(29)
		MCDB	65.6	67.1	68.8	70.1	70.3	67.3	67.3	67.3	67.3	67.2	66.5	65.9	(30)
	5%	WB	61.0	61.6	62.7	64.2	64.5	62.1	61.6	62.0	62.1	62.6	62.2	61.7	(31)
		MCDB	64.5	65.8	67.6	69.2	69.4	65.3	65.3	65.8	65.9	66.2	65.6	64.6	(32)
	10%	WB	60.2	60.6	61.7	63.3	63.7	61.2	60.6	61.0	61.2	61.8	61.6	60.9	(33)
		MCDB	63.4	64.5	66.5	68.3	68.2	63.7	63.5	64.0	64.4	65.1	64.7	63.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	15.2	17.0	16.1	12.4	6.3	7.2	8.0	8.8	10.8	10.8	10.9	(35)
		MCDBR	19.2	19.6	20.2	18.9	16.3	10.1	11.8	12.0	13.0	13.8	13.7	15.1	(36)
	5% WB	MCWBR	13.2	14.1	13.2	12.2	10.7	6.4	6.9	7.3	8.4	9.0	9.3	10.7	(37)
		MCWBR	13.9	14.7	16.6	16.1	14.2	8.6	9.8	10.9	11.7	12.6	11.7	11.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.323	0.330	0.351	0.364	0.376	0.361	0.371	0.361	0.346	0.352	0.346	0.333	(40)
		taud	2.530	2.489	2.429	2.437	2.430	2.496	2.444	2.472	2.520	2.485	2.504	2.522	(41)
	Ebn at Noon		315	315	307	298	289	290	288	295	304	304	305	310	(42)
		Edh at Noon	33	36	38	37	37	34	36	36	35	36	34	33	(43)
(44) All-Sky Solar Radiation	RadAvg		1513	1744	1888	1806	1685	1636	1644	1669	1693	1600	1388	1340	(44)
	RadStd		132	112	112	92	118	89	71	75	108	89	104	136	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page