

GALLE, Sri Lanka

WMO: 434950

Lat: 6.0296N

Lon: 80.2143E

Elev: 13

StdP: 101.17

Time Zone: 5.50 (IND)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	23.9	20.1	14.8	26.5	21.0	15.6	25.9	6.0	28.3	5.0	28.0	1.5	50	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	2.9	32.0	26.6	31.4	26.7	30.9	26.7	27.8	30.4	27.6	30.1	27.3	29.8	2.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	22.9	29.7	26.8	22.5	29.4	26.6	22.2	29.3	89.2	30.8	87.8	30.2	86.8	29.9	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.6	6.4	DB	21.3	33.5	1.1	0.7	20.5	34.0	19.8	34.4	19.2	34.8	18.4	35.3	(4)
(5)			WB	19.6	28.4	1.4	0.5	18.6	28.8	17.8	29.1	17.0	29.4	16.0	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	26.8	27.2	28.2	28.5	28.4	28.0	27.6	27.4	27.5	27.4	27.2	26.9
	DBStd	1.00	0.86	0.77	0.81	0.97	0.88	0.83	0.88	0.84	0.83	0.87	0.75	0.85
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6420	521	481	563	554	571	539	546	541	525	540	515	525
	CDD18.3	3378	262	247	305	304	312	289	287	282	275	282	265	267
	CDH23.3	37025	2562	2559	3546	3711	3825	3366	3161	3067	2995	3019	2639	2574
CDH26.7	10636	578	672	1267	1448	1399	1014	784	703	719	791	656	604	
Wind	WSAvg	2.5	1.4	1.4	1.4	1.9	3.0	4.0	3.9	3.3	3.5	2.5	1.9	1.6
Precipitation	PrecAvg	2432	80	80	105	210	296	168	194	180	266	352	316	185
	PrecMax	3864	167	266	224	408	589	362	467	392	610	637	750	553
	PrecMin	1883	1	5	24	74	49	87	50	37	51	45	121	29
	PrecStd	411	41	62	57	95	135	72	126	88	150	153	156	119
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.4	32.1	33.0	33.2	31.6	30.6	30.2	29.9	30.0	30.7	31.6	31.6
		MCWB	25.6	25.5	26.4	28.2	27.7	27.1	26.7	26.6	26.6	26.6	26.4	26.0
	2%	DB	30.2	30.8	32.1	31.9	30.8	30.0	29.7	29.4	29.6	30.1	30.5	30.5
		MCWB	25.5	25.9	26.2	27.4	27.4	27.1	26.5	26.4	26.4	26.4	26.3	26.0
	5%	DB	29.5	30.1	31.4	31.3	30.4	29.6	29.3	29.1	29.2	29.6	29.9	29.7
		MCWB	25.4	25.7	26.3	27.1	27.2	26.9	26.4	26.3	26.3	26.2	26.2	25.8
	10%	DB	29.0	29.5	30.7	30.7	30.0	29.2	29.0	28.7	28.8	29.2	29.3	29.2
		MCWB	25.3	25.6	26.3	27.0	27.0	26.8	26.3	26.2	26.1	26.1	25.9	25.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.1	27.7	28.6	28.2	27.7	27.2	27.2	27.2	27.1	27.0	
		MCDB	29.7	30.1	31.6	32.2	30.4	29.5	29.2	29.1	29.1	29.6	30.4	30.0
	2%	WB	26.3	26.6	27.2	27.9	27.9	27.5	27.0	26.8	26.8	26.7	26.7	26.6
		MCDB	29.1	29.6	30.8	30.9	30.1	29.2	28.9	28.7	28.8	29.2	29.6	29.5
	5%	WB	26.0	26.2	26.9	27.6	27.6	27.2	26.7	26.6	26.6	26.6	26.4	26.2
		MCDB	28.8	29.1	30.4	30.6	29.8	29.0	28.6	28.6	28.6	29.0	29.2	29.1
	10%	WB	25.7	26.0	26.6	27.3	27.4	27.0	26.6	26.4	26.4	26.3	26.1	25.9
		MCDB	28.4	28.9	30.0	30.2	29.5	28.9	28.5	28.4	28.4	28.7	28.9	28.7
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.0	5.6	4.6	2.9	2.3	2.3	2.3	2.5	3.4	4.7	4.8
		MCDBR	5.5	5.7	6.5	5.2	3.5	2.5	2.4	2.5	2.7	3.9	5.4	5.6
		MCWBR	2.6	2.8	3.1	2.6	2.1	1.5	1.4	1.4	1.6	2.1	2.7	2.8
	5% WB	MCDBR	4.9	5.1	5.7	4.9	3.1	2.3	2.4	2.4	2.7	3.7	5.1	5.1
		MCWBR	2.7	2.8	3.0	2.7	2.1	1.7	1.6	1.6	1.7	2.2	2.8	2.9
Clear-Sky Solar Irradiance	taub	0.441	0.458	0.487	0.476	0.499	0.490	0.509	0.485	0.455	0.456	0.465	0.465	0.453
	taud	2.372	2.309	2.246	2.308	2.228	2.258	2.174	2.264	2.368	2.367	2.326	2.350	
	Ebn at Noon	879	871	845	840	802	798	787	821	859	862	849	859	
	Edh at Noon	125	136	145	134	142	135	148	139	127	126	130	126	
All-Sky Solar Radiation	RadAvg	5.37	5.95	6.21	5.84	5.31	5.27	5.37	5.46	5.53	5.33	4.70	4.82	
	RadStd	0.34	0.35	0.34	0.32	0.42	0.34	0.24	0.29	0.41	0.34	0.35	0.42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page