

HAMBANTOTA, Sri Lanka

WMO: 434970

Lat: 6.1225N

Lon: 81.1287E

Elev: 20

StdP: 101.08

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.2	22.1	16.0	11.4	28.9	17.2	12.3	29.6	10.1	28.4	8.9	28.3	1.9	0	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	35.0	24.7	34.1	24.9	33.3	25.1	28.2	31.1	27.8	30.7	27.4	30.3	7.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.1	29.7	27.1	22.8	29.6	26.8	22.5	29.3	91.2	31.6	89.2	30.9	87.4	30.4	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.4	8.5	DB	18.6	36.3	1.1	1.2	17.8	37.2	17.1	37.9	16.5	38.6	15.7	39.5	(4)
(5)			WB	17.6	28.6	1.6	0.9	16.4	29.2	15.5	29.7	14.6	30.2	13.4	30.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	26.8	27.3	28.1	28.6	28.5	28.7	28.9	28.5	28.0	27.8	27.2	26.7	(6)	
	DBStd	1.29	1.03	1.15	0.91	0.84	1.05	1.24	1.24	1.17	1.16	1.09	0.78	0.95	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6544	522	484	561	558	575	561	586	574	540	552	515	517	(10)	
	CDD18.3	3503	264	251	302	308	317	311	327	316	290	293	265	258	(11)	
	CDH23.3	36748	2413	2480	3324	3557	3616	3528	3744	3494	3024	2925	2431	2213	(12)	
	CDH26.7	13144	820	909	1349	1439	1311	1300	1474	1276	970	957	714	624	(13)	
(14) Wind	WSAvg	3.7	3.4	3.4	2.9	2.4	3.9	5.3	5.4	5.2	4.6	3.3	2.3	2.8	(14)	
(15) Precipitation	PrecAvg	1102	68	49	53	90	83	55	36	52	77	129	215	131	(15)	
	PrecMax	1827	247	177	237	271	319	230	193	186	289	360	555	486	(16)	
	PrecMin	579	0	0	0	14	2	1	0	0	0	1	30	19	(17)	
	PrecStd	251	61	51	51	56	63	50	35	46	62	87	103	89	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	34.0	35.0	34.8	34.8	35.0	35.2	35.2	35.1	35.0	32.7	32.2	(19)	
		MCWB	24.3	25.0	24.6	25.3	26.1	25.7	24.8	24.5	23.6	22.6	25.1	24.6	(20)	
	2%	DB	32.1	33.0	33.9	33.3	33.2	34.0	34.8	34.1	33.9	33.1	31.8	31.2	(21)	
		MCWB	24.0	24.8	24.7	25.8	26.0	25.6	24.8	24.4	24.3	24.5	25.4	25.1	(22)	
	5%	DB	31.2	32.0	32.8	32.8	32.1	33.0	33.8	33.1	32.2	31.8	30.9	30.6	(23)	
		MCWB	24.3	24.8	25.1	26.0	26.2	25.6	24.9	24.7	24.8	24.9	25.6	25.2	(24)	
	10%	DB	30.8	31.1	31.9	31.9	31.1	32.0	32.6	31.9	30.9	30.7	30.1	29.9	(25)	
		MCWB	24.4	24.8	25.7	26.3	26.5	25.8	25.0	24.9	25.4	25.7	25.6	25.3	(26)	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.5	27.9	28.7	29.0	28.6	28.1	27.8	27.7	27.7	27.6	(27)	
			MCDB	30.5	30.5	31.8	31.6	32.0	32.3	31.6	30.2	30.2	30.0	29.7	(28)	
		2%	WB	26.2	26.8	27.3	28.0	28.2	27.7	27.1	27.0	27.1	27.1	26.9	(29)	
			MCDB	29.8	30.5	31.0	31.3	30.9	30.7	29.8	29.7	29.8	29.8	29.4	(30)	
		5%	WB	25.8	26.3	26.8	27.6	27.6	27.1	26.5	26.5	26.6	26.5	26.3	(31)	
			MCDB	29.3	30.1	30.4	30.8	30.2	29.9	29.9	29.4	29.3	29.5	29.4	(32)	
	10%	WB	25.3	25.9	26.4	27.2	27.2	26.7	26.0	26.1	26.2	26.2	26.1	25.9	(33)	
		MCDB	28.7	29.5	30.0	30.3	29.7	29.3	29.3	29.2	28.8	29.1	28.9	28.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	8.4	8.4	7.2	5.7	6.1	6.9	6.5	6.1	6.4	6.4	6.7	(35)	
		MCDBR	9.4	9.7	10.3	8.9	7.7	8.2	9.2	8.9	8.9	8.4	7.6	8.0	(36)	
		MCWBR	4.1	3.9	3.9	3.9	3.4	2.7	2.6	2.6	3.0	3.2	3.5	3.9	(37)	
	5% WB	MCDBR	7.7	7.9	7.8	7.0	5.8	6.3	7.0	6.1	5.8	6.3	6.6	7.1	(38)	
		MCWBR	3.8	3.9	3.7	3.6	3.2	2.8	2.7	2.7	2.8	3.2	3.6	3.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.431	0.442	0.466	0.464	0.493	0.481	0.499	0.480	0.453	0.454	0.455	0.442	(40)	
	taud		2.397	2.350	2.294	2.334	2.241	2.283	2.201	2.277	2.367	2.363	2.350	2.382	(41)	
	Ebn at Noon		888	885	863	851	807	806	795	826	861	863	858	870	(42)	
	Edh at Noon		121	130	139	131	140	132	144	137	127	127	126	122	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.09	5.70	6.10	5.83	5.52	5.47	5.55	5.62	5.64	5.35	4.59	4.57	(44)	
	RadStd		0.38	0.40	0.36	0.32	0.40	0.30	0.23	0.26	0.36	0.33	0.36	0.47	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page