

MALE, Maldives

WMO: 435550

Lat: 4.1927N

Lon: 73.5281E

Elev: 6

StdP: 14.69

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	76.6	77.2	69.6	108.9	82.3	71.2	114.9	82.5	25.8	81.2	23.2	81.5	12.5	270	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.7	90.0	80.9	89.7	80.7	89.3	80.5	82.7	87.1	82.2	86.8	81.8	86.5	9.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	161.0	86.6	80.8	160.0	86.4	80.5	158.2	86.2	46.6	88.8	46.1	87.7	45.6	86.7	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.8	21.2	19.3	DB	73.5	91.6	2.1	1.4	71.9	92.6	70.7	93.4	69.5	94.2	67.9	95.2
			WB	71.1	84.1	1.6	0.6	69.9	84.6	69.0	84.9	68.1	85.3	66.9	85.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.9	83.3	83.9	85.0	85.5	84.9	84.5	83.8	83.6	83.3	83.2	82.8	83.0
	DBStd	1.85	1.23	1.22	1.35	1.63	1.96	1.70	1.78	1.94	1.82	1.77	1.69	1.51
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12375	1032	948	1085	1065	1082	1036	1048	1043	998	1030	985	1023
	CDD65	6900	567	528	620	615	617	586	583	578	548	565	535	558
	CDH74	85969	6653	6435	8058	8206	8114	7589	7361	7168	6688	6824	6327	6546
	CDH80	34216	2251	2436	3613	3904	3692	3305	2960	2793	2466	2467	2139	2190
Wind	WSAvg	10.2	12.2	10.7	7.7	7.7	12.0	11.5	10.6	10.3	10.5	10.8	8.4	10.6
Precipitation	PrecAvg	69.6	3.2	1.4	1.7	4.6	7.2	5.5	6.7	7.0	7.9	8.3	7.9	7.5
	PrecMax	91.3	10.9	6.8	6.7	12.5	19.4	10.3	14.3	16.3	15.8	16.7	22.0	16.0
	PrecMin	45.3	0.0	0.0	0.2	0.7	3.1	1.5	1.9	2.0	1.5	0.8	1.0	1.9
	PrecStd	11.1	3.0	1.6	1.6	2.8	3.8	2.7	3.0	3.5	3.8	3.9	4.9	4.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.2	89.7	90.0	91.5	91.1	89.9	89.7	89.8	89.4	89.5	88.3	88.2
		MCWB	79.3	80.1	80.3	81.8	82.0	81.1	80.4	80.3	80.6	79.9	79.8	79.6
	2%	DB	87.8	88.2	89.8	90.0	89.8	89.2	88.2	88.2	88.0	88.1	87.9	87.8
		MCWB	79.0	79.5	80.1	81.0	81.3	80.8	80.2	80.1	80.1	79.7	79.8	79.5
	5%	DB	86.8	87.9	89.2	89.6	89.3	88.1	87.8	87.8	87.6	87.6	86.8	86.6
		MCWB	78.5	79.4	80.0	80.9	81.1	80.6	80.2	80.1	79.8	79.6	79.3	78.9
	10%	DB	86.2	87.3	88.1	88.8	88.0	87.7	87.1	86.8	86.3	86.3	86.1	86.1
		MCWB	78.3	79.0	79.8	80.7	80.8	80.5	79.8	79.6	79.2	79.1	78.9	78.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.5	82.4	82.7	83.4	83.3	82.7	82.7	82.4	82.2	81.7	81.5	81.6
		MCDB	85.6	86.5	87.7	88.4	87.6	86.7	86.6	86.2	86.4	85.9	86.0	85.5
	2%	WB	80.6	81.0	81.8	82.5	82.6	81.9	81.5	81.2	81.0	80.8	80.6	80.6
		MCDB	85.3	86.1	87.3	87.7	87.0	86.2	86.0	85.9	85.6	85.4	85.4	85.1
	5%	WB	79.9	80.2	80.9	81.9	82.0	81.4	80.7	80.6	80.4	80.1	80.0	80.0
		MCDB	84.8	85.6	86.9	87.3	86.6	86.0	85.7	85.7	85.2	84.9	84.8	84.6
	10%	WB	79.3	79.7	80.2	81.3	81.6	80.9	80.1	80.0	79.9	79.8	79.6	79.6
		MCDB	84.3	85.2	86.4	87.0	86.4	85.8	85.2	85.3	84.8	84.6	84.4	84.2
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.9	6.8	6.7	6.5	6.3	6.4	6.4	6.4	6.6	6.7	6.7
		MCDBR	6.8	7.3	7.3	7.1	6.6	6.5	6.6	6.7	6.8	7.0	7.2	7.0
		MCWBR	3.8	3.9	3.6	3.7	3.7	3.6	3.7	3.7	3.8	3.7	3.8	3.9
	5% WB	MCDBR	6.6	7.0	6.8	6.9	6.4	6.4	6.5	6.6	6.7	6.6	7.0	7.0
		MCWBR	4.1	4.1	3.8	4.1	4.0	4.0	4.1	4.0	4.0	4.0	4.0	4.1
Clear-Sky Solar Irradiance	taub	0.448	0.444	0.459	0.445	0.447	0.463	0.472	0.442	0.429	0.421	0.417	0.444	
	taud	2.371	2.362	2.340	2.417	2.436	2.370	2.315	2.433	2.469	2.498	2.499	2.406	
	Ebn at Noon	278	281	276	275	268	259	259	272	280	285	285	277	
	Edh at Noon	40	41	42	38	36	38	41	37	36	35	35	38	
All-Sky Solar Radiation	RadAvg	1871	2040	2111	1958	1711	1658	1645	1728	1758	1810	1600	1626	
	RadStd	79	83	99	101	104	122	103	106	154	128	161	159	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.56	+0.36	N/A	+0.58	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page