

GAN ISLAND, Maldives

WMO: 435990

Lat: 0.6905S

Lon: 73.1501E

Elev: 2

StdP: 101.30

Time Zone: 5.00 (E05)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	24.0	24.5	22.1	16.8	27.4	22.4	17.1	27.5	10.4	26.1	9.4	26.8	3.6	270	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	4.0	31.7	26.9	31.4	26.8	31.2	26.7	27.7	30.6	27.5	30.4	27.2	30.2	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.4	29.8	26.6	22.1	29.6	26.3	21.7	29.4	88.1	30.8	87.0	30.6	86.1	30.5	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.3	7.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			20.6	28.4	2.4	0.5	18.9	28.7	17.5	28.9	16.2	29.2	14.4	29.5		

Monthly Climatic Design Conditions

		Annual												
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.2	28.1	28.5	28.8	28.9	28.5	28.6	28.1	27.9	27.8	27.8	27.8
(7)		DBStd	1.02	0.93	0.84	0.82	0.90	1.03	0.86	0.98	0.96	1.09	0.88	0.92
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0
(10)		CDD10.0	6650	562	519	582	568	573	558	562	554	534	553	534
(11)		CDD18.3	3608	303	286	323	318	315	308	304	296	284	294	284
(12)		CDH23.3	42750	3527	3489	4051	4025	3898	3763	3569	3396	3212	3324	3202
(13)		CDH26.7	14783	1159	1301	1623	1666	1484	1424	1208	1068	972	981	944
(14)	Wind	WSAvg	3.4	2.7	2.8	2.3	3.6	4.1	3.3	3.1	3.2	3.6	4.0	4.1
(15)	Precipitation	PrecAvg	2380	221	111	141	168	237	180	178	196	219	273	196
(16)		PrecMax	3180	539	281	368	326	522	356	356	375	384	716	478
(17)		PrecMin	1549	7	8	10	53	72	4	12	54	56	33	15
(18)		PrecStd	395	128	86	87	74	122	102	82	91	90	139	123
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.5	32.0	32.1	31.7	31.7	31.6	31.4	31.2	31.1	31.1
(20)			MCWB	26.5	26.7	26.9	27.1	27.0	26.9	26.7	26.6	26.6	26.5	26.7
(21)		2%	DB	30.6	31.1	31.6	31.7	31.2	31.3	31.1	30.8	30.7	30.6	30.5
(22)			MCWB	26.3	26.5	26.7	27.0	26.9	26.7	26.6	26.4	26.4	26.3	26.5
(23)		5%	DB	30.3	30.7	31.2	31.3	30.9	31.0	30.7	30.5	30.3	30.2	30.2
(24)			MCWB	26.1	26.4	26.6	26.8	26.8	26.6	26.4	26.3	26.3	26.1	26.4
(25)		10%	DB	30.0	30.4	30.8	31.0	30.5	30.6	30.3	30.1	29.9	29.9	29.8
(26)			MCWB	25.9	26.2	26.4	26.7	26.7	26.5	26.3	26.1	26.2	26.0	26.2
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.7	27.9	28.1	27.9	27.7	27.6	27.5	27.6	27.2	27.5
(28)			MCDB	30.0	30.2	31.0	31.0	30.7	30.7	30.5	30.2	30.1	30.0	29.8
(29)		2%	WB	26.9	27.2	27.4	27.6	27.5	27.3	27.1	27.0	27.1	26.8	27.1
(30)			MCDB	29.8	30.1	30.6	30.8	30.4	30.4	30.2	30.0	29.9	29.6	29.8
(31)		5%	WB	26.6	26.9	27.1	27.2	27.2	27.1	26.8	26.7	26.7	26.6	26.7
(32)			MCDB	29.5	30.0	30.3	30.5	30.1	30.2	29.9	29.7	29.5	29.4	29.5
(33)		10%	WB	26.3	26.6	26.8	27.0	26.9	26.7	26.6	26.4	26.4	26.2	26.5
(34)			MCDB	29.1	29.7	30.0	30.3	29.9	29.8	29.6	29.3	29.2	29.0	29.2
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.6	3.5	4.1	4.0	4.0	3.9	4.0	4.0	3.9	3.9	3.7
(36)			MCDBR	3.7	3.8	4.4	4.3	4.2	4.1	4.4	4.4	4.3	4.2	4.0
(37)			MCWBR	1.7	1.8	1.9	2.0	2.0	1.9	1.9	2.0	2.0	2.1	1.9
(38)		5% WB	MCDBR	3.7	3.7	4.2	4.2	3.9	4.0	4.2	4.2	4.1	4.1	3.8
(39)			MCWBR	1.9	1.9	2.0	2.1	2.1	2.0	2.1	2.1	2.2	2.2	2.0
(40)	Clear-Sky Solar Irradiance	taub	0.407	0.412	0.409	0.399	0.400	0.415	0.427	0.413	0.405	0.405	0.397	0.395
(41)		taud	2.530	2.494	2.519	2.579	2.590	2.527	2.480	2.530	2.545	2.554	2.579	2.581
(42)		Ebn at Noon	924	921	915	903	880	852	847	879	905	917	927	932
(43)		Edh at Noon	109	114	111	102	97	101	107	105	107	106	103	103
(44)	All-Sky Solar Radiation	RadAvg	5.93	6.42	6.61	6.08	5.47	5.26	4.97	5.35	5.57	5.76	5.58	5.62
(45)		RadStd	0.45	0.37	0.40	0.39	0.28	0.41	0.24	0.35	0.42	0.45	0.45	0.47

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page