

DURVULJIN, Mongolia

WMO: 442190

Lat: 47.6464N

Lon: 94.9989E

Elev: 2181

StdP: 77.72

Time Zone: 7.00 (E07)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-37.9	-35.6	-40.6	0.1	-37.6	-38.4	0.1	-35.3	8.4	-16.0	7.8	-15.7	1.4	110	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	30.9	15.0	29.2	14.3	27.6	13.8	16.9	27.1	15.9	25.8	15.0	24.6	3.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.7	12.8	19.5	12.3	11.7	20.3	11.0	10.7	19.9	56.3	27.3	52.8	26.1	49.8	24.8	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.1	7.1	-37.7	34.4	4.3	1.7	-40.8	35.6	-43.3	36.6	-45.7	37.6	-48.9	38.8
			-37.8	18.5	4.3	2.0	-40.9	20.0	-43.4	21.1	-45.8	22.3	-48.9	23.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.4	-24.2	-19.4	-4.9	5.8	11.9	18.8	21.2	18.9	12.0	3.1	-8.5	-19.2	
	DBStd	16.48	6.59	8.12	7.46	5.40	4.70	3.60	3.07	3.42	4.46	4.77	6.09	5.87	
	HDD10.0	4235	1062	823	463	142	36	1	0	0	31	215	556	907	
	HDD18.3	6392	1320	1057	722	376	203	36	9	34	193	471	806	1165	
	CDD10.0	1093	0	0	0	17	95	264	346	277	91	3	0	0	
	CDD18.3	208	0	0	0	0	4	50	97	53	3	0	0	0	
	CDH23.3	2014	0	0	0	2	68	505	882	509	48	0	0	0	
	CDH26.7	554	0	0	0	0	8	129	273	138	6	0	0	0	
Wind	WSAvg	2.6	1.6	2.0	2.7	3.0	3.3	3.0	2.9	2.8	2.7	2.5	2.4	1.9	
Precipitation	PrecAvg	186	5	4	6	11	15	27	45	30	15	9	11	7	
	PrecMax	295	10	7	14	22	26	56	121	66	36	22	24	14	
	PrecMin	106	1	2	0	2	4	11	11	8	5	2	4	2	
	PrecStd	45	2	1	3	5	6	10	24	15	7	5	5	3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-5.5	2.3	14.8	22.2	28.0	31.9	33.9	32.6	27.2	18.0	8.4	-1.8	
		MCWB	-8.3	-2.8	4.6	9.0	11.0	16.0	16.5	14.9	12.4	7.1	1.4	-5.6	
	2%	DB	-9.3	-1.5	11.2	19.6	25.2	29.9	31.4	30.0	24.5	15.5	5.4	-5.7	
		MCWB	-11.3	-5.5	2.8	7.9	11.4	14.2	15.4	14.4	11.7	6.2	-0.2	-8.3	
	5%	DB	-11.8	-4.6	8.6	17.3	23.2	28.1	29.6	28.1	22.2	13.4	2.7	-8.1	
		MCWB	-13.4	-7.5	1.4	6.9	10.2	13.5	15.0	13.8	10.5	4.7	-2.0	-10.1	
	10%	DB	-14.3	-7.7	6.2	15.0	20.9	26.3	27.9	26.2	20.1	11.1	0.2	-10.5	
		MCWB	-15.4	-10.0	-0.2	5.4	9.0	12.9	14.4	13.5	9.6	3.5	-3.5	-12.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-8.3	-2.7	4.7	10.2	13.4	17.2	18.5	17.6	14.7	8.1	1.8	-5.2
			MCDB	-5.6	2.1	13.7	20.7	25.3	30.2	28.5	27.1	24.8	16.5	7.8	-1.6
		2%	WB	-11.4	-5.4	3.0	8.5	11.8	15.5	17.3	16.3	12.8	6.6	0.0	-8.3
			MCDB	-9.4	-1.8	10.4	18.6	23.4	26.5	27.4	25.2	21.3	14.7	5.2	-5.9
5%		WB	-13.4	-7.5	1.5	7.2	10.6	14.6	16.3	15.2	11.5	5.1	-1.6	-10.0	
		MCDB	-11.8	-4.5	8.3	16.4	21.9	24.9	26.6	24.5	20.0	12.7	2.8	-8.1	
10%		WB	-15.5	-9.9	0.0	5.9	9.5	13.9	15.5	14.2	10.3	3.6	-3.2	-12.0	
		MCDB	-14.3	-7.6	5.9	14.3	20.0	23.9	25.2	24.3	19.3	10.8	0.4	-10.5	
Mean Daily Temperature Range	5% DB	MDBR	10.4	12.6	13.8	13.2	12.9	11.8	11.1	11.8	12.8	12.9	10.6	9.4	
		MCDBR	12.5	14.4	14.9	15.5	15.4	13.8	13.2	14.0	14.7	14.9	12.5	10.3	
		MCWBR	10.8	11.4	9.3	8.9	8.0	6.0	5.4	5.7	7.0	8.6	8.2	8.3	
	5% WB	MCDBR	12.4	14.5	14.5	14.7	14.4	12.4	11.4	11.7	13.2	14.6	12.1	10.2	
		MCWBR	10.7	11.5	9.4	9.0	8.1	5.8	5.3	5.6	6.8	8.7	8.2	8.4	
Clear-Sky Solar Irradiance	taub		0.211	0.233	0.268	0.300	0.302	0.312	0.313	0.296	0.266	0.248	0.227	0.214	
	taud		2.412	2.374	2.337	2.321	2.348	2.396	2.423	2.451	2.494	2.478	2.437	2.390	
	Ebn at Noon		919	957	962	955	960	949	943	949	956	927	883	866	
	Edh at Noon		63	84	103	117	119	114	110	102	88	75	62	57	
All-Sky Solar Radiation	RadAvg		1.46	2.56	4.41	5.96	7.06	7.19	6.87	6.02	4.97	3.35	1.86	1.21	
	RadStd		0.20	0.27	0.29	0.23	0.37	0.26	0.31	0.22	0.15	0.14	0.24	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	-2.09	N/A	-1.23	-1.51	N/A	N/A	N/A	N/A

Nomenclature: See separate page