

KHORGOTARIAT, Mongolia

WMO: 442290

Lat: 48.1567N

Lon: 99.8767E

Elev: 7156

StdP: 11.27

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.1	-25.2	-33.2	1.1	-27.3	-29.7	1.4	-23.3	20.7	-5.2	19.1	-6.8	3.5	270	0.750

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	75.2	53.7	71.9	52.6	69.0	51.9	58.0	67.4	56.0	65.6	54.4	63.9	7.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
55.1	84.6	59.9	52.9	77.9	58.2	51.0	72.5	56.9	28.4	67.5	26.9	65.5	25.7	63.8	65.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.8	18.6	16.2		DB	-32.4	81.2	4.9	3.0	-35.9	83.3	-38.8	85.1	-41.5	86.8	-45.0	88.9
				WB	-32.5	59.9	4.9	2.5	-36.0	61.7	-38.9	63.2	-41.7	64.6	-45.2	66.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	-8.6	-2.7	14.7	32.1	42.3	53.5	57.6	53.9	44.0	29.9	11.7	-2.9	
	DBStd	24.55	9.57	10.40	11.19	9.35	7.93	6.28	4.55	5.47	7.18	8.51	10.21	9.75	
	HDD50	8856	1818	1475	1094	537	256	36	3	25	199	622	1150	1641	
	HDD65	13773	2283	1895	1559	986	704	348	233	343	629	1087	1600	2106	
	CDD50	563	0	0	0	1	17	140	238	147	20	0	0	0	
	CDD65	6	0	0	0	0	0	2	3	1	0	0	0	0	
	CDH74	142	0	0	0	0	2	44	62	33	1	0	0	0	
	CDH80	10	0	0	0	0	0	3	4	3	0	0	0	0	
Wind	WSAvg	6.5	5.8	6.4	7.4	8.5	8.1	6.0	5.2	4.9	5.7	6.4	6.8	6.3	
Precipitation	PrecAvg	9.7	0.0	0.1	0.2	0.4	0.7	1.9	2.9	2.2	0.6	0.3	0.2	0.1	
	PrecMax	14.1	0.3	0.3	0.6	1.7	1.8	3.5	5.4	4.9	2.0	1.1	0.5	0.2	
	PrecMin	6.9	0.0	0.0	0.0	0.0	0.1	0.6	1.4	0.4	0.0	0.0	0.0	0.0	
	PrecStd	1.8	0.1	0.1	0.1	0.3	0.5	0.7	0.8	1.0	0.4	0.3	0.1	0.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.9	28.1	46.2	61.1	72.4	78.9	79.9	78.1	71.5	55.7	41.3	26.8	
		MCWB	18.8	22.9	33.5	42.0	48.8	54.2	56.7	53.4	48.4	39.3	32.8	22.1	
	2%	DB	15.5	22.2	40.8	56.0	67.1	74.0	75.4	72.7	65.4	50.9	34.6	19.5	
		MCWB	12.8	18.4	30.4	39.8	46.9	52.2	55.1	52.9	46.5	37.4	28.0	16.7	
	5%	DB	9.8	17.8	36.5	51.6	62.7	70.5	72.0	69.0	61.4	46.8	29.8	14.6	
		MCWB	7.8	14.6	28.1	37.8	44.7	51.4	54.1	51.6	45.1	35.4	24.9	12.3	
	10%	DB	5.0	13.1	32.3	47.8	58.5	67.0	69.0	65.6	57.7	42.8	25.6	10.7	
		MCWB	3.5	10.6	25.8	35.5	42.4	50.2	53.7	51.1	43.6	33.4	21.8	8.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.3	23.6	35.3	43.8	51.9	57.3	61.2	59.4	51.7	40.9	33.5	21.9
			MCDB	21.3	27.6	46.0	57.1	68.2	72.4	68.3	66.2	61.0	52.4	40.9	26.5
2%		WB	12.6	18.7	31.1	41.0	48.4	55.2	59.0	56.4	49.2	38.5	28.4	16.8	
		MCDB	15.2	22.1	39.4	52.8	62.8	67.3	68.7	64.6	60.3	48.9	33.9	19.4	
5%		WB	7.7	14.8	28.4	38.6	45.7	53.7	57.3	54.6	47.3	36.1	25.1	12.4	
		MCDB	9.6	17.9	36.0	50.1	60.7	64.6	66.6	63.3	58.0	45.6	29.6	14.5	
10%		WB	3.5	10.8	25.9	36.3	43.3	52.3	55.5	53.0	45.2	33.7	22.1	8.8	
		MCDB	4.9	13.2	32.4	46.6	56.5	63.1	64.5	61.5	55.1	41.5	25.4	10.7	
Mean Daily Temperature Range	5% DB	MDBR	14.7	19.1	23.1	20.5	21.8	20.9	19.5	20.0	21.8	18.4	15.8	13.1	
		MCDBR	20.3	23.0	26.4	26.4	30.5	27.8	26.5	26.9	27.9	24.2	19.5	16.9	
		MCWBR	18.2	19.6	17.9	13.8	14.0	10.2	9.0	9.0	11.1	12.3	13.9	14.9	
	5% WB	MCDBR	20.2	22.9	25.2	24.3	28.3	21.5	20.8	20.3	24.5	22.8	18.8	17.1	
		MCWBR	18.1	19.7	17.3	13.8	14.0	8.9	8.7	8.2	10.6	12.3	13.5	15.1	
Clear-Sky Solar Irradiance	taub	0.214	0.238	0.279	0.316	0.324	0.331	0.328	0.310	0.279	0.258	0.234	0.217		
	taud	2.398	2.356	2.306	2.316	2.334	2.419	2.466	2.490	2.524	2.501	2.434	2.381		
	Ebn at Noon	287	300	300	297	297	295	294	296	298	289	275	270		
	Edh at Noon	20	27	34	37	38	36	33	31	27	23	19	18		
All-Sky Solar Radiation	RadAvg	583	926	1401	1803	2036	2010	1907	1696	1447	971	602	462		
	RadStd	30	38	59	76	129	104	117	74	70	56	27	18		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	N/A	N/A	-3.89	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page