

BADRAXH TARIALAN, Mongolia

WMO: 442300

Lat: 49.6092N

Lon: 101.9847E

Elev: 4052

StdP: 12.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.0	-22.2	-32.2	1.0	-25.6	-28.9	1.3	-21.3	17.2	5.7	14.3	2.4	5.2	20	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	84.3	62.0	80.4	60.8	77.0	59.7	65.7	78.1	63.8	75.4	62.0	73.1	7.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.4	94.7	71.7	59.5	88.4	69.5	57.8	82.8	67.8	32.9	78.3	31.3	75.5	29.9	73.3	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	16.3	13.8	-28.1	90.8	5.0	4.2	-31.7	93.8	-34.7	96.3	-37.5	98.6	-41.1	101.6		
(5)			-28.2	69.4	5.0	3.4	-31.8	71.8	-34.7	73.8	-37.5	75.8	-41.2	78.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.2	-5.1	4.0	22.4	39.4	50.8	61.1	64.8	60.8	49.9	34.5	14.5	-0.1		
	DBStd	25.86	9.24	10.61	11.48	9.07	8.66	6.85	5.66	5.93	7.62	8.78	11.32	10.01		
	HDD50	7483	1708	1289	857	332	97	5	0	3	94	482	1064	1552		
	HDD65	11726	2173	1709	1322	769	445	151	72	155	453	946	1514	2017		
	CDD50	1362	0	0	0	13	122	339	458	338	91	1	0	0		
	CDD65	131	0	0	0	0	4	35	66	25	1	0	0	0		
	CDH74	1468	0	0	0	2	124	462	625	239	16	0	0	0		
	CDH80	366	0	0	0	0	22	114	172	57	1	0	0	0		
	WSAvg	6.6	5.6	6.3	7.3	8.3	8.3	7.3	6.0	5.9	6.7	6.6	5.8	5.5		
	PrecAvg	11.9	0.1	0.0	0.1	0.3	0.8	2.2	4.0	2.9	0.9	0.3	0.1	0.1		
	PrecMax	17.2	0.6	0.3	0.4	1.1	2.4	5.7	6.7	5.6	2.1	0.8	0.5	0.4		
(15) Precipitation	PrecMin	8.1	0.0	0.0	0.0	0.0	0.0	0.1	0.9	0.7	0.1	0.0	0.0	0.0		
	PrecStd	2.5	0.1	0.1	0.1	0.2	0.6	1.3	1.3	1.3	0.6	0.2	0.1	0.1		
	DB	21.3	33.9	56.9	71.4	83.2	88.3	90.0	86.4	76.1	62.4	44.9	25.4			
	MCWB	17.5	26.4	42.2	48.9	57.3	61.4	66.3	64.7	56.8	46.5	35.8	20.9			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	15.3	28.2	49.9	64.4	77.2	83.4	84.9	79.7	71.3	57.4	39.8	20.1			
	2% MCWB	12.5	22.4	37.2	45.8	54.0	60.0	64.6	62.7	55.1	43.7	32.3	16.7			
	5% DB	11.4	23.7	45.0	60.0	72.7	79.3	80.5	75.7	67.4	52.9	35.0	16.2			
	5% MCWB	9.1	19.3	34.4	43.4	52.1	59.0	62.6	61.3	52.9	41.1	28.9	13.5			
	10% DB	7.6	19.3	39.7	55.8	68.2	75.7	76.9	72.4	63.2	48.5	30.5	12.5			
	10% MCWB	5.8	15.7	31.2	41.2	50.0	57.8	62.0	60.1	50.9	38.6	25.9	10.4			
	0.4% WB	17.9	26.9	42.6	50.2	59.4	64.9	70.1	67.4	60.2	47.4	36.5	21.0			
	0.4% MCDB	21.2	32.9	56.1	67.3	78.5	80.7	86.5	78.8	71.4	60.9	43.8	25.1			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	12.5	22.6	37.9	46.9	55.9	62.4	66.8	64.6	56.8	44.4	32.6	16.9			
	2% MCDB	15.1	28.0	49.0	62.4	73.9	78.4	79.7	76.0	67.8	56.4	39.4	20.1			
	5% WB	9.1	19.4	34.5	44.2	53.2	60.8	64.8	62.6	54.2	41.7	29.3	13.5			
	5% MCDB	11.3	23.6	44.2	58.4	71.0	74.7	76.5	73.4	64.9	52.3	34.6	16.0			
	10% WB	5.8	15.7	31.4	41.7	50.5	59.1	63.1	60.9	51.8	39.0	25.9	10.5			
	10% MCDB	7.5	19.2	39.4	54.7	66.6	72.3	73.7	70.8	61.9	48.1	30.6	12.5			
	MDBR	14.5	20.0	23.5	23.4	24.6	22.2	19.6	19.9	22.6	21.9	17.1	13.7			
	5% DB	18.0	23.9	26.7	29.4	31.5	28.3	26.0	25.0	27.1	27.0	20.8	16.8			
(36) Mean Daily Temperature Range	MCWBR	16.1	19.5	17.3	16.8	16.4	13.1	11.7	12.4	14.4	16.5	15.2	14.4			
	MCDBR	17.7	23.4	25.9	27.5	29.1	23.7	22.2	21.9	24.4	25.8	20.1	16.6			
	MCWBR	15.9	19.2	17.2	16.9	16.8	12.5	11.7	12.0	13.7	16.4	15.1	14.3			
	MCDBR	15.9	19.2	17.2	16.9	16.8	12.5	11.7	12.0	13.7	16.4	15.1	14.3			
(40) Clear-Sky Solar Irradiance	taub	0.238	0.262	0.307	0.347	0.375	0.375	0.365	0.343	0.301	0.282	0.260	0.241			
	taud	2.342	2.307	2.269	2.279	2.231	2.336	2.412	2.451	2.509	2.487	2.385	2.312			
	Ebn at Noon	266	284	286	285	280	280	281	284	287	274	253	245			
	Edh at Noon	20	27	35	38	42	38	35	32	27	23	20	18			
(44) All-Sky Solar Radiation	RadAvg	520	877	1343	1710	2004	2026	1927	1665	1391	929	555	404			
	RadStd	22	43	48	88	107	127	97	86	68	38	26	23			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	-1.26	N/A	N/A	N/A	N/A

Nomenclature: See separate page