

YERUU, Mongolia

WMO: 442430

Lat: 49.7492N

Lon: 106.6611E

Elev: 2181

StdP: 77.72

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.1	-37.9	-43.2	0.1	-39.6	-41.0	0.1	-37.7	7.2	-11.7	5.3	-15.0	0.3	70	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	32.0	17.3	29.9	16.8	27.9	16.3	20.1	27.2	18.9	25.4	18.0	24.2	2.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	17.2	23.1	17.1	16.0	21.9	16.0	14.9	21.2	68.6	27.3	64.1	25.5	60.5	24.1	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.2	5.9	-42.5	36.1	2.9	2.3	-44.6	37.7	-46.3	39.1	-48.0	40.4	-50.1	42.0		
			-42.2	21.7	3.1	1.8	-44.4	23.0	-46.2	24.0	-47.9	25.0	-50.2	26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.1	-27.8	-22.9	-8.3	3.5	10.3	17.4	20.3	17.6	10.5	0.9	-12.5	-24.0	(6)
(7)		DBStd	17.48	5.09	6.58	8.02	4.68	4.58	3.97	3.04	3.41	4.41	4.94	7.06	5.98	(7)
(8)		HDD10.0	4971	1171	921	566	199	53	1	0	1	46	283	676	1053	(8)
(9)		HDD18.3	7251	1429	1154	824	445	251	64	13	56	235	541	926	1311	(9)
(10)		CDD10.0	907	0	0	0	5	62	222	319	236	62	1	0	0	(10)
(11)		CDD18.3	144	0	0	0	0	2	35	74	32	1	0	0	0	(11)
(12)		CDH23.3	2012	0	0	0	6	130	569	838	412	57	0	0	0	(12)
(13)		CDH26.7	694	0	0	0	1	37	205	309	132	10	0	0	0	(13)
(14)	Wind	WSAvg	1.6	0.5	0.7	1.7	2.5	2.8	2.3	1.8	1.7	1.8	1.7	0.9	0.6	(14)
(15)	Precipitation	PrecAvg	298	3	2	2	6	14	55	87	80	31	11	4	3	(15)
(16)		PrecMax	459	9	12	14	29	46	177	147	206	77	52	14	10	(16)
(17)		PrecMin	163	0	0	0	0	3	6	30	37	6	0	0	0	(17)
(18)		PrecStd	84	3	3	4	7	9	41	39	41	19	11	4	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.9	-1.7	13.9	23.4	30.9	34.7	35.0	33.5	28.3	19.5	8.2	-5.6	(19)
(20)		0.4%	MCWB	-10.6	-4.6	4.5	9.8	13.8	16.6	19.6	18.9	15.6	9.3	2.2	-7.1	(20)
(21)		2%	DB	-13.7	-5.9	9.8	19.3	27.1	31.2	32.2	30.0	24.8	15.4	3.5	-9.5	(21)
(22)		2%	MCWB	-14.7	-7.7	2.9	7.5	12.2	16.0	18.3	17.7	14.2	6.6	-0.3	-10.7	(22)
(23)		5%	DB	-16.7	-9.3	6.5	16.1	24.1	28.9	30.1	27.7	22.2	12.3	0.9	-12.2	(23)
(24)		5%	MCWB	-17.4	-10.6	1.1	6.2	10.9	15.6	17.8	17.4	13.1	5.4	-2.1	-13.0	(24)
(25)		10%	DB	-19.2	-12.2	3.3	13.3	21.0	26.6	27.9	25.3	19.4	9.5	-1.6	-14.8	(25)
(26)		10%	MCWB	-19.8	-13.1	-0.9	5.1	9.6	14.9	17.3	16.7	11.9	4.0	-3.8	-15.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.6	-4.7	5.3	10.7	15.2	19.5	22.5	21.0	17.5	9.3	2.8	-7.0	(27)
(28)		0.4%	MCDWB	-9.2	-1.9	12.8	19.7	27.5	29.4	31.9	28.4	25.4	18.7	7.2	-5.8	(28)
(29)		2%	WB	-14.7	-7.6	3.2	8.3	13.1	18.1	20.8	19.5	15.5	7.2	0.0	-10.5	(29)
(30)		2%	MCDWB	-13.8	-6.0	9.2	17.3	25.3	26.8	27.8	26.2	22.1	14.0	3.0	-9.5	(30)
(31)		5%	WB	-17.3	-10.5	1.1	6.7	11.7	17.0	19.5	18.4	14.0	5.6	-1.9	-13.0	(31)
(32)		5%	MCDWB	-16.7	-9.3	6.0	15.5	22.0	25.2	25.9	24.6	20.2	11.4	0.8	-12.1	(32)
(33)		10%	WB	-19.7	-13.1	-0.8	5.2	10.3	16.0	18.5	17.4	12.5	4.1	-3.8	-15.4	(33)
(34)		10%	MCDWB	-19.3	-12.2	3.3	12.9	19.6	23.6	24.4	23.1	18.6	9.0	-1.6	-14.8	(34)
(35)	Mean Daily Temperature Range		MDBR	11.5	14.6	15.4	15.0	15.9	14.6	12.9	12.9	14.8	14.2	12.6	10.9	(35)
(36)		5% DB	MCDBR	14.0	16.7	17.5	21.4	22.8	19.0	17.2	17.8	20.1	20.0	14.8	12.8	(36)
(37)			MCWBR	13.2	14.9	10.8	11.2	10.1	6.6	6.0	6.9	9.7	11.7	11.2	11.8	(37)
(38)			MCDBR	14.1	16.7	16.8	19.7	20.2	15.1	13.7	14.2	17.2	18.2	14.7	12.8	(38)
(39)		5% WB	MCWBR	13.3	14.9	10.4	11.0	9.8	6.4	6.1	6.4	8.7	11.0	11.3	11.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.205	0.219	0.246	0.279	0.309	0.317	0.310	0.293	0.261	0.238	0.220	0.207	(40)	
(41)		taud	2.399	2.399	2.452	2.472	2.402	2.459	2.509	2.551	2.607	2.602	2.490	2.392	(41)	
(42)		Ebn at Noon	901	964	984	974	949	941	942	948	957	933	874	844	(42)	
(43)		Edh at Noon	59	77	89	99	111	106	100	91	77	63	54	52	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.69	2.89	4.26	5.17	6.08	6.29	5.85	5.03	4.05	2.71	1.69	1.29	(44)	
(45)		RadStd	0.05	0.08	0.21	0.27	0.40	0.30	0.37	0.34	0.31	0.13	0.08	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page