

DALANZADGAD, Mongolia

WMO: 443730

Lat: 43.5772N

Lon: 104.4181E

Elev: 4806

StdP: 12.32

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.4	-8.9	-24.1	1.7	-4.7	-20.5	2.1	-3.0	31.3	14.6	24.5	18.5	4.6	290	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	90.5	60.3	87.6	59.2	85.0	58.2	66.1	81.4	63.7	79.1	61.7	77.3	9.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.2	96.6	73.3	58.6	87.8	69.8	56.1	80.2	68.9	33.8	81.2	31.7	79.1	30.1	77.7	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.2	23.4	21.4	DB	-16.3	95.4	4.3	3.3	-19.4	97.7	-22.0	99.6	-24.4	101.4	-27.5	103.8
			WB	-17.0	67.2	4.2	4.2	-20.0	70.2	-22.5	72.7	-24.9	75.0	-27.9	78.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	7.5	15.4	30.1	46.5	58.0	68.4	73.7	70.2	58.9	42.9	25.6	11.8
	DBStd	24.55	8.91	10.24	10.99	10.00	9.09	7.03	6.05	6.30	8.31	9.35	10.00	8.63
	HDD50	5310	1319	968	620	179	32	0	0	0	22	252	733	1185
	HDD65	8865	1784	1388	1083	556	250	45	6	23	214	684	1182	1650
	CDD50	2593	0	0	2	75	281	553	735	625	289	33	0	0
	CDD65	672	0	0	0	2	34	147	276	183	30	0	0	0
	CDH74	6400	0	0	0	19	349	1442	2763	1598	229	0	0	0
	CDH80	2120	0	0	0	1	73	446	1071	499	30	0	0	0
Wind	WSAvg	8.2	5.9	7.1	9.3	11.0	11.1	9.1	8.0	8.0	7.9	7.9	7.5	6.2
Precipitation	PrecAvg	4.8	0.0	0.1	0.2	0.2	0.4	0.8	1.2	1.2	0.5	0.2	0.1	0.1
	PrecMax	8.7	0.3	0.4	0.6	0.7	2.1	3.1	3.9	3.0	2.0	0.9	0.4	0.7
	PrecMin	2.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.3	0.0	0.1	0.2	0.2	0.4	0.7	0.9	0.8	0.5	0.2	0.1	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	45.9	61.9	76.6	86.5	91.8	95.7	92.4	83.6	72.0	55.6	40.6
		MCWB	28.6	32.6	41.6	49.9	55.3	59.3	64.1	60.1	55.8	48.2	38.8	29.1
	2%	DB	30.9	40.2	56.9	71.8	81.9	88.2	91.9	88.3	79.7	66.7	50.2	33.8
		MCWB	23.8	29.3	38.7	47.2	53.1	58.4	61.8	59.4	54.0	45.8	35.9	25.6
	5%	DB	25.5	36.3	52.1	67.6	78.0	85.1	88.9	85.2	76.4	62.4	45.9	29.0
		MCWB	19.8	27.1	36.3	45.4	51.5	57.3	60.4	58.2	52.5	44.0	33.8	22.5
	10%	DB	21.3	32.0	47.5	63.4	74.2	81.9	85.9	82.3	73.0	58.4	41.4	25.1
		MCWB	16.7	24.5	33.8	43.5	49.7	55.8	59.4	57.5	51.2	42.1	31.3	19.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.9	33.5	43.3	52.5	62.1	67.0	70.6	68.3	62.6	50.6	39.9	29.5
		MCDB	36.0	44.5	57.8	71.1	79.1	84.3	86.8	79.8	77.6	65.5	54.1	39.6
	2%	WB	24.2	29.9	39.6	48.9	56.5	62.8	67.3	64.7	58.6	47.2	36.8	25.8
		MCDB	30.7	39.3	55.0	68.0	73.9	78.9	83.7	78.0	70.5	64.5	49.1	33.4
	5%	WB	20.0	27.2	36.7	46.3	53.5	60.7	64.6	62.4	55.3	44.9	34.2	22.7
		MCDB	25.4	35.8	51.3	65.2	72.6	76.5	80.6	76.8	70.4	61.0	45.4	28.8
	10%	WB	16.9	24.7	34.0	43.9	51.1	58.6	62.5	60.3	52.9	42.8	31.6	19.8
		MCDB	21.4	31.8	47.1	62.9	71.9	75.7	78.8	75.5	69.5	57.1	41.2	24.9
Mean Daily Temperature Range	5% DB	MDBR	19.2	21.0	21.3	20.7	20.5	19.6	18.7	18.6	19.4	20.4	19.8	18.8
		MCDBR	24.7	26.1	25.7	24.0	23.5	21.8	21.5	21.1	21.4	24.3	24.7	23.4
		MCWBR	19.4	18.6	15.3	12.9	11.3	9.3	7.9	8.1	9.7	13.2	15.2	17.4
	5% WB	MCDBR	24.2	24.9	24.3	22.4	21.2	19.1	18.5	17.8	19.3	22.5	23.7	22.8
		MCWBR	19.1	18.1	15.2	13.2	12.3	10.4	9.5	9.0	10.8	13.1	15.0	17.3
Clear-Sky Solar Irradiance	taub	0.256	0.289	0.333	0.377	0.398	0.413	0.397	0.382	0.345	0.312	0.275	0.255	
	taud	2.376	2.299	2.195	2.129	2.125	2.172	2.282	2.303	2.357	2.375	2.403	2.382	
	Ebn at Noon	282	287	285	281	277	272	276	276	279	275	271	271	
	Edh at Noon	24	31	40	47	48	46	41	39	34	29	23	22	
All-Sky Solar Radiation	RadAvg	693	1042	1534	1960	2225	2152	2025	1876	1624	1237	801	608	
	RadStd	71	107	90	88	112	117	99	82	69	41	66	69	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	-4.00	N/A	-2.65	-3.28	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	-3.98	N/A	-2.41	-2.81	N/A	N/A	N/A	N/A	

Nomenclature: See separate page