

TRIBHUVAN INTL, Nepal

WMO: 444540

Lat: 27.697N

Lon: 85.359E

Elev: 4390

StdP: 12.51

Time Zone: 5.75 (NPL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.9	37.6	29.8	28.0	64.9	32.5	31.8	53.1	12.2	59.9	11.3	60.2	1.1	90	0.279

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	15.6	87.4	69.1	85.8	69.5	84.3	70.3	75.6	83.1	74.6	81.9	73.9	80.8	8.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.5	147.2	81.0	72.4	141.7	79.1	71.8	138.7	78.0	42.8	83.3	41.8	82.6	40.9	81.3	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.9	10.3	DB	32.2	90.5	3.5	2.0	29.7	92.0	27.6	93.2	25.7	94.3	23.2	95.8	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.3	51.3	56.7	62.7	68.5	72.3	75.5	75.5	75.7	74.1	68.7	60.7	53.4
	DBStd	9.14	2.74	3.66	3.76	3.37	3.24	2.44	1.93	1.87	2.25	3.84	3.33	2.94
	HDD50	23	15	1	0	0	0	0	0	0	0	0	0	7
	HDD65	1258	424	234	90	9	1	0	0	0	0	10	131	359
	CDD50	5972	56	189	393	554	691	766	790	796	722	580	322	113
	CDD65	1733	0	1	18	113	227	317	325	331	272	126	3	0
	CDH74	9976	2	26	290	1209	1667	1892	1468	1531	1184	649	58	0
	CDH80	2067	0	1	29	305	443	453	241	300	201	93	1	0
Wind	WSAvg	3.3	2.7	3.3	4.1	4.3	4.4	3.9	3.2	3.1	3.0	3.1	2.4	2.4
Precipitation	PrecAvg	60.7	0.5	0.9	1.4	2.3	5.5	10.5	15.1	14.1	8.1	2.7	0.2	0.5
	PrecMax	83.0	1.2	2.1	3.9	7.2	8.4	25.9	20.4	27.2	14.8	8.0	1.0	2.4
	PrecMin	42.6	0.0	0.0	0.0	0.0	1.5	3.4	10.1	8.7	2.2	0.0	0.0	0.0
	PrecStd	12.5	0.4	0.6	1.2	1.7	2.0	5.6	3.3	4.3	3.7	2.2	0.3	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.8	78.2	83.9	88.1	89.5	89.4	86.4	87.4	86.3	85.2	78.6	71.8
		MCWB	55.9	59.9	61.4	61.7	69.4	69.6	75.0	75.9	74.0	71.7	64.4	57.0
	2%	DB	67.9	73.7	80.2	85.9	86.7	86.2	84.4	84.6	84.4	82.6	75.5	69.6
		MCWB	53.4	56.6	60.8	61.5	67.1	71.7	74.4	74.6	72.9	69.5	62.2	55.7
	5%	DB	64.8	71.6	77.2	83.8	84.6	84.4	82.7	83.1	82.6	80.5	73.4	67.2
		MCWB	51.6	55.6	58.8	61.5	67.3	71.4	73.8	74.2	72.3	68.6	60.8	54.4
	10%	DB	62.7	68.4	75.1	80.9	82.5	82.6	80.9	81.8	80.8	77.5	71.3	64.5
		MCWB	50.5	54.2	57.8	61.7	67.3	71.6	73.0	73.7	71.5	66.5	59.8	53.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.0	63.7	67.4	70.2	75.1	75.8	76.5	77.0	75.8	73.8	66.9	59.1
		MCDB	66.1	74.9	76.3	82.6	85.0	83.6	83.7	84.0	83.8	83.3	75.7	68.8
	2%	WB	54.8	59.9	64.4	68.1	72.3	74.4	75.3	75.5	74.2	71.3	63.7	56.9
		MCDB	64.6	69.8	72.4	78.6	82.0	82.2	82.4	83.0	81.9	79.9	73.5	66.5
	5%	WB	53.1	57.7	62.0	66.4	70.6	73.4	74.5	74.6	73.2	69.8	61.9	55.5
		MCDB	62.5	67.1	71.8	76.7	80.1	81.2	81.0	81.6	80.5	77.4	71.1	64.4
	10%	WB	51.5	55.8	59.9	64.7	69.3	72.5	73.6	73.8	72.2	68.4	60.6	54.0
		MCDB	60.5	65.2	71.0	74.3	78.4	79.7	79.7	80.3	78.8	74.7	69.1	62.5
Mean Daily Temperature Range	5% DB	MDBR	25.8	25.7	25.6	25.2	20.4	15.6	12.7	13.8	14.8	20.0	23.4	25.4
		MCDBR	28.9	28.9	28.3	29.6	24.3	18.1	14.9	15.8	17.3	22.1	25.2	28.0
		MCWBR	15.7	13.7	11.8	11.5	10.4	7.3	6.9	6.7	7.5	9.8	12.0	14.7
	5% WB	MCDBR	27.2	26.0	24.0	23.5	20.7	15.7	13.8	14.5	16.0	19.3	23.9	25.5
		MCWBR	16.0	13.5	11.3	11.1	10.1	7.1	6.7	6.7	7.5	9.6	12.6	14.6
Clear-Sky Solar Irradiance	taub	0.370	0.408	0.458	0.554	0.580	0.575	0.485	0.448	0.446	0.446	0.455	0.394	
	taud	2.205	2.118	1.991	1.796	1.799	1.867	2.174	2.297	2.257	2.133	1.986	2.137	
	Ebn at Noon	273	271	264	243	236	236	258	267	265	256	239	257	
	Edh at Noon	39	46	56	70	70	65	48	42	42	45	49	40	
All-Sky Solar Radiation	RadAvg	1209	1447	1775	1957	1908	1679	1390	1424	1407	1514	1355	1205	
	RadStd	98	120	84	152	151	116	97	79	93	93	79	61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page