

HONG KONG INTL, Hong Kong

WMO: 450070

Lat: 22.3094N

Lon: 113.9219E

Elev: 23

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.9	50.3	23.3	17.6	57.1	29.9	24.0	58.0	24.5	63.2	22.2	63.1	11.5	10	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	93.3	79.8	91.8	79.5	91.2	79.3	81.9	88.6	81.3	88.0	80.8	87.5	11.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	157.7	86.8	79.2	151.6	85.9	79.0	150.5	85.8	46.0	89.0	45.2	88.8	44.6	88.2	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years					
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	20.9	18.7	DB	45.2	96.8	3.5	1.4	42.7	97.8	40.7	98.6	38.8	99.3	36.3	100.3
			WB	37.3	83.6	3.6	1.0	34.6	84.3	32.5	84.9	30.5	85.5	27.8	86.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.0	62.4	64.0	68.7	75.5	81.3	84.8	85.9	85.5	84.2	80.3	73.4	65.4
	DBStd	9.70	5.84	6.82	5.66	5.07	3.89	2.99	2.63	2.71	2.87	3.43	5.10	5.58
	HDD50	5	2	2	0	0	0	0	0	0	0	0	0	1
	HDD65	311	117	92	30	3	0	0	0	0	0	0	6	63
	CDD50	9494	387	394	580	764	970	1044	1112	1100	1025	939	702	477
	CDD65	4328	38	64	145	318	505	594	647	635	575	474	258	75
	CDH74	45475	29	114	441	2114	5297	7535	8599	8308	7072	4549	1300	117
CDH80	18056	0	3	23	409	1780	3379	4193	3924	2965	1207	169	4	
Wind	WSAvg	9.9	9.8	10.3	10.8	10.6	10.0	10.0	9.8	9.0	9.3	9.8	9.8	9.5
Precipitation	PrecAvg	68.9	1.2	1.6	2.1	5.2	9.0	14.3	11.8	11.9	8.7	3.0	1.8	1.2
	PrecMax	94.3	10.0	6.8	7.3	24.7	19.4	51.1	37.0	32.1	20.6	12.6	16.5	7.9
	PrecMin	43.0	0.0	0.0	0.0	0.0	1.3	2.7	2.4	2.0	2.1	0.0	0.0	0.0
	PrecStd	15.7	1.9	1.8	1.9	5.1	4.6	9.8	7.2	7.9	5.2	3.3	3.2	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.1	79.6	82.5	88.0	91.8	93.5	95.2	95.1	93.5	90.9	86.2	80.2
		MCWB	67.6	70.8	73.4	76.4	79.0	79.8	80.6	79.7	79.0	76.5	73.3	70.0
	2%	DB	73.8	77.2	80.4	85.7	89.9	91.7	93.3	93.2	91.7	88.2	84.0	77.0
		MCWB	65.1	70.0	72.2	75.9	78.6	79.6	80.1	79.9	78.5	75.5	72.5	68.8
	5%	DB	71.8	75.1	78.6	84.1	88.1	90.6	91.7	91.6	90.0	86.4	82.1	75.0
		MCWB	64.1	68.1	71.5	75.4	78.4	79.5	79.8	79.7	78.0	74.7	71.5	66.8
	10%	DB	69.9	73.1	76.8	82.4	86.4	89.4	90.4	90.0	89.2	85.6	80.3	73.0
		MCWB	62.8	66.3	70.3	74.7	77.9	79.4	79.7	79.4	77.8	74.2	70.6	64.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.5	73.7	75.3	78.8	81.1	82.4	83.1	82.8	81.9	79.6	76.1	73.2
		MCDB	73.9	77.7	79.8	84.3	87.7	88.6	90.6	89.6	88.7	86.2	82.3	77.4
	2%	WB	67.4	71.4	73.9	77.6	80.2	81.5	81.9	81.8	80.8	78.3	74.9	70.6
		MCDB	72.3	76.0	78.7	83.2	86.5	87.8	88.9	88.4	87.4	84.5	81.1	75.1
	5%	WB	65.6	69.1	72.6	76.8	79.7	80.9	81.1	81.0	80.0	77.4	73.8	68.2
		MCDB	70.5	73.9	77.3	82.4	85.8	87.2	88.1	87.7	86.6	83.9	79.9	73.8
	10%	WB	63.9	67.1	71.0	75.7	79.0	80.4	80.6	80.5	79.5	76.4	72.5	65.7
		MCDB	68.9	71.8	75.5	81.2	85.1	86.8	87.6	87.3	86.0	83.3	78.6	71.7
Mean Daily Temperature Range	5% DB	MDBR	9.0	8.8	9.0	8.9	8.6	8.1	8.8	9.0	8.9	8.9	9.3	9.3
		MCDBR	10.6	11.2	10.7	10.4	9.5	9.1	10.0	10.5	10.1	9.6	10.2	10.2
		MCWBR	5.7	5.8	5.2	4.5	3.9	3.7	3.9	4.5	4.5	4.5	5.0	5.4
	5% WB	MCDBR	9.7	10.0	9.7	9.4	8.5	8.1	9.0	9.3	9.1	8.5	8.4	9.1
		MCWBR	6.3	6.1	5.8	5.0	4.1	3.8	4.0	4.5	4.4	4.2	4.8	6.1
Clear-Sky Solar Irradiance	taub	0.592	0.641	0.767	0.742	0.580	0.545	0.532	0.601	0.638	0.692	0.588	0.581	
	taud	1.793	1.727	1.521	1.605	1.990	2.102	2.132	1.924	1.816	1.663	1.866	1.841	
	Ebn at Noon	213	213	193	203	237	243	246	231	219	197	212	209	
	Edh at Noon	63	72	92	86	58	51	50	62	67	75	58	59	
All-Sky Solar Radiation	RadAvg	959	988	1069	1198	1437	1479	1709	1592	1493	1384	1116	1002	
	RadStd	159	157	143	183	180	214	181	138	117	136	128	149	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) +0.38	(e) N/A	(f) N/A	(g) +0.83	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) +146
Regional (13 neighbors)	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page