

HONG KONG INTL, Hong Kong

WMO: 450070

Lat: 22.3094N

Lon: 113.9219E

Elev: 7

StdP: 101.24

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.9	10.2	-4.8	2.5	13.9	-1.2	3.4	14.5	11.0	17.3	9.9	17.3	5.2	10	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	34.1	26.5	33.2	26.4	32.9	26.3	27.7	31.4	27.4	31.1	27.1	30.8	5.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.5	30.5	26.2	21.7	30.0	26.1	21.5	29.9	89.1	31.7	87.3	31.5	85.9	31.2	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.7	9.3	8.4	DB	7.3	36.0	1.9	0.8	6.0	36.5	4.8	37.0	3.8	37.4	2.4	37.9	(4)
			WB	2.9	28.7	2.0	0.6	1.5	29.1	0.3	29.4	-0.9	29.7	-2.3	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.4	16.9	17.8	20.4	24.2	27.4	29.3	29.9	29.7	29.0	26.8	23.0	18.5
	DBStd	5.39	3.25	3.79	3.14	2.82	2.16	1.66	1.46	1.50	1.59	1.91	2.83	3.10
	HDD10.0	3	1	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	173	65	51	17	2	0	0	0	0	0	0	3	35
	CDD10.0	5274	215	219	322	424	539	580	618	611	569	522	390	265
	CDD18.3	2404	21	36	81	177	281	330	359	353	319	263	143	42
	CDH23.3	25264	16	63	245	1174	2943	4186	4777	4616	3929	2527	722	65
	CDH26.7	10031	0	2	13	227	989	1877	2329	2180	1647	671	94	2
Wind	WSAvg	4.4	4.4	4.6	4.8	4.7	4.5	4.5	4.4	4.0	4.1	4.4	4.4	4.3
Precipitation	PrecAvg	1750	30	40	54	132	229	363	300	301	220	75	45	30
	PrecMax	2394	255	172	185	627	492	1299	939	815	523	320	420	201
	PrecMin	1093	0	0	1	0	33	68	62	52	54	1	0	0
	PrecStd	399	49	46	49	130	116	250	184	200	131	85	81	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.0	26.4	28.0	31.1	33.2	34.2	35.1	34.1	32.7	30.1	26.8	
		MCWB	19.8	21.5	23.0	24.7	26.1	26.6	27.0	26.5	26.1	24.7	22.9	21.1
	2%	DB	23.2	25.1	26.9	29.9	32.1	33.2	34.0	34.0	33.1	31.2	28.9	25.0
		MCWB	18.4	21.1	22.3	24.4	25.9	26.5	26.7	26.6	25.8	24.2	22.5	20.4
	5%	DB	22.1	24.0	25.9	28.9	31.2	32.5	33.2	33.1	32.2	30.2	27.8	23.9
		MCWB	17.8	20.1	21.9	24.1	25.8	26.4	26.6	26.5	25.5	23.7	21.9	19.4
	10%	DB	21.1	22.8	24.9	28.0	30.2	31.9	32.4	32.2	31.8	29.8	26.8	22.8
		MCWB	17.1	19.1	21.3	23.7	25.5	26.3	26.5	26.4	25.4	23.5	21.4	18.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.8	23.2	24.1	26.0	27.3	28.0	28.4	28.2	27.7	26.4	24.5	22.9
		MCDB	23.3	25.4	26.5	29.1	30.9	31.5	32.6	32.0	31.5	30.1	27.9	25.2
	2%	WB	19.7	21.9	23.3	25.4	26.8	27.5	27.7	27.7	27.1	25.7	23.8	21.4
		MCDB	22.4	24.5	25.9	28.5	30.3	31.0	31.6	31.3	30.8	29.1	27.3	23.9
	5%	WB	18.7	20.6	22.5	24.9	26.5	27.2	27.3	27.2	26.7	25.2	23.2	20.1
		MCDB	21.4	23.3	25.2	28.0	29.9	30.7	31.1	31.0	30.3	28.8	26.6	23.2
	10%	WB	17.7	19.5	21.7	24.3	26.1	26.9	27.0	27.0	26.4	24.7	22.5	18.7
		MCDB	20.5	22.1	24.2	27.3	29.5	30.4	30.9	30.7	30.0	28.5	25.9	22.0
Mean Daily Temperature Range	5% DB	MDBR	5.0	4.9	5.0	4.9	4.8	4.5	4.9	5.0	4.9	4.9	5.2	5.2
		MCDBR	5.9	6.2	5.9	5.8	5.3	5.0	5.6	5.8	5.6	5.4	5.7	5.6
		MCWBR	3.2	3.2	2.9	2.5	2.2	2.1	2.2	2.5	2.5	2.5	2.8	3.0
	5% WB	MCDBR	5.4	5.5	5.4	5.2	4.7	4.5	5.0	5.2	5.1	4.7	4.7	5.0
		MCWBR	3.5	3.4	3.2	2.8	2.3	2.1	2.2	2.5	2.4	2.3	2.6	3.4
Clear-Sky Solar Irradiance	taub	0.592	0.641	0.767	0.742	0.580	0.545	0.532	0.601	0.638	0.692	0.588	0.581	
	taud	1.793	1.727	1.521	1.605	1.990	2.102	2.132	1.924	1.816	1.663	1.866	1.841	
	Ebn at Noon	670	670	610	639	747	767	777	727	690	622	669	660	
	Edh at Noon	200	226	289	270	182	162	157	194	212	238	184	185	
All-Sky Solar Radiation	RadAvg	3.02	3.12	3.37	3.78	4.53	4.66	5.39	5.02	4.71	4.36	3.52	3.16	
	RadStd	0.50	0.50	0.45	0.58	0.57	0.68	0.57	0.44	0.37	0.43	0.41	0.47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	+0.25	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page