

LAU FAU SHAN, Hong Kong

WMO: 450350

Lat: 22.469N

Lon: 113.984E

Elev: 36

StdP: 100.90

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.3	8.6	-4.1	2.7	12.1	-1.3	3.4	12.3	8.7	11.9	7.9	11.9	4.6	30	0.377

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	33.4	27.0	32.7	26.8	32.1	26.7	28.2	31.6	27.7	31.0	27.4	30.6	4.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.1	30.2	26.8	22.6	29.8	26.5	22.1	29.5	91.1	31.8	89.0	31.2	87.4	30.9	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.7	6.8	5.5	35.3	2.5	0.6	3.7	35.7	2.2	36.1	0.8	36.4	-1.1	36.9		
			1.8	30.2	2.0	1.4	0.4	31.2	-0.7	32.1	-1.9	32.9	-3.3	33.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.5	15.7	17.3	19.7	23.2	26.5	28.2	28.9	28.6	28.0	25.7	22.0	17.3
	DBStd	5.44	3.41	4.30	3.42	2.89	2.19	1.73	1.42	1.46	1.56	1.94	3.10	3.29
	HDD10.0	7	3	3	0	0	0	0	0	0	0	0	0	1
	HDD18.3	253	94	63	26	4	0	0	0	0	0	0	8	58
	CDD10.0	4920	179	208	301	396	512	547	586	578	541	487	359	228
	CDD18.3	2123	12	34	68	150	253	297	328	319	291	228	117	26
	CDH23.3	19574	13	76	201	819	2261	3289	3862	3688	3111	1708	505	42
CDH26.7	6486	1	6	15	132	668	1185	1536	1397	1069	403	72	2	
Wind	WSAvg	3.5	3.3	3.4	3.5	3.6	3.6	3.7	3.7	3.3	3.4	3.4	3.4	3.5
Precipitation	PrecAvg	1806	27	46	73	164	241	302	299	312	189	73	33	29
	PrecMax	2988	103	228	545	377	722	768	591	878	491	614	156	178
	PrecMin	947	0	0	1	3	8	0	2	50	7	0	0	0
	PrecStd	499	29	63	110	101	200	163	164	175	129	124	44	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.8	27.6	28.2	30.2	33.1	33.8	34.5	34.2	33.9	32.1	30.2	26.3
		MCWB	19.6	21.8	22.3	24.8	26.3	27.1	27.5	27.3	26.4	24.8	23.3	20.5
	2%	DB	22.8	25.5	26.8	29.1	31.8	32.7	33.2	33.1	32.7	30.8	28.4	24.4
		MCWB	18.6	20.9	21.7	24.3	26.2	26.9	27.4	27.1	26.2	24.5	22.7	19.4
	5%	DB	21.4	23.9	25.5	28.1	30.8	31.9	32.4	32.3	31.8	29.7	27.3	23.0
		MCWB	17.5	20.2	21.3	23.9	25.8	26.9	27.1	27.0	26.2	23.7	22.1	18.3
	10%	DB	20.2	22.6	24.3	27.2	29.9	31.0	31.6	31.5	30.9	28.8	26.1	21.7
		MCWB	16.7	19.4	20.8	23.5	25.3	26.7	26.8	26.9	25.8	23.0	21.5	17.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.6	22.8	23.6	25.7	27.6	28.6	28.6	28.8	28.5	27.1	24.7	22.0
		MCDB	23.4	25.9	26.5	28.5	31.1	32.1	32.5	32.3	31.2	29.8	28.0	25.2
	2%	WB	19.4	21.9	22.9	25.2	27.0	27.7	28.0	28.1	27.6	25.9	24.0	20.6
		MCDB	21.9	24.8	25.6	27.8	30.3	31.0	31.7	31.5	30.8	28.4	27.1	23.0
	5%	WB	18.3	20.9	22.2	24.6	26.6	27.4	27.6	27.6	27.0	25.1	23.3	19.5
		MCDB	20.6	23.3	24.7	27.2	29.7	30.5	31.1	30.9	30.3	27.8	26.1	22.2
	10%	WB	17.4	19.8	21.5	24.1	26.1	27.1	27.2	27.2	26.6	24.4	22.6	18.3
		MCDB	19.6	22.1	23.8	26.6	29.0	30.0	30.5	30.3	29.6	27.4	25.2	21.2
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.0	6.1	5.9	5.6	5.1	5.4	5.3	5.6	6.1	6.4	6.4
		MCDBR	7.2	7.5	7.3	6.7	6.6	6.0	6.2	6.3	6.7	6.9	7.2	7.4
		MCWBR	3.8	3.6	3.5	3.1	2.7	2.4	2.5	2.7	2.8	2.9	3.2	3.8
	5% WB	MCDBR	6.5	6.6	6.3	6.0	5.6	5.4	5.8	5.8	5.9	5.8	6.1	6.7
		MCWBR	3.7	3.5	3.4	3.2	2.6	2.6	2.7	2.9	2.8	2.8	3.6	4.0
Clear-Sky Solar Irradiance	taub	0.587	0.639	0.767	0.745	0.586	0.552	0.538	0.606	0.641	0.688	0.582	0.573	
	taud	1.794	1.724	1.515	1.595	1.967	2.074	2.106	1.904	1.803	1.662	1.868	1.849	
	Ebn at Noon	673	671	609	637	743	762	772	724	688	624	673	666	
	Edh at Noon	199	227	291	272	187	166	161	197	215	238	184	183	
All-Sky Solar Radiation	RadAvg	3.08	3.13	3.34	3.67	4.43	4.56	5.33	4.99	4.69	4.37	3.56	3.23	
	RadStd	0.50	0.49	0.45	0.58	0.58	0.68	0.57	0.44	0.34	0.44	0.41	0.48	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	N/A	N/A	+0.25	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page