

CHIANG KAI SHEK INTL, Taiwan

WMO: 466860

Lat: 25.078N

Lon: 121.233E

Elev: 107

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.6	51.4	37.2	32.7	52.7	40.0	36.5	54.2	30.2	57.5	29.2	57.6	16.0	40	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	94.9	80.4	93.2	80.6	91.6	80.2	83.6	90.2	82.6	88.9	81.7	88.0	18.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.2	168.1	88.3	80.8	160.6	86.7	80.3	157.9	86.2	47.7	90.7	46.7	89.0	45.5	88.7	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.3	26.9	24.9	45.6	98.6	2.5	1.7	43.8	99.8	42.4	100.8	41.0	101.8	39.2	103.0
			41.5	84.2	2.7	1.8	39.5	85.5	38.0	86.6	36.5	87.6	34.5	88.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.6	60.8	60.9	64.3	71.8	77.6	82.4	85.7	85.2	81.9	76.6	71.2	64.3
	DBStd	9.97	4.96	5.31	5.63	5.52	4.35	3.65	2.25	2.55	3.78	4.00	4.56	5.20
	HDD50	2	1	1	0	0	0	0	0	0	0	0	0	0
	HDD65	452	144	133	82	11	0	0	0	0	0	0	6	76
	CDD50	8627	337	307	443	654	854	973	1106	1091	958	824	637	443
	CDD65	3600	15	19	60	214	389	523	641	626	508	359	193	53
	CDH74	34859	16	45	181	1113	3086	5855	8266	7862	5423	2272	658	82
	CDH80	13509	1	4	22	215	852	2293	3958	3591	1971	498	97	7
Wind	WSAvg	12.4	14.6	13.5	12.1	10.4	9.7	10.3	10.5	9.9	11.7	15.0	14.9	15.6
Precipitation	PrecAvg	95.1	5.0	7.3	7.2	7.0	8.7	10.8	5.9	9.3	13.9	9.1	6.2	4.8
	PrecMax	143.1	10.8	17.1	12.1	20.4	25.9	27.3	13.5	21.8	67.8	37.0	20.7	11.3
	PrecMin	41.9	1.7	1.0	3.1	1.3	0.6	2.2	0.5	0.7	0.5	0.0	0.2	0.4
	PrecStd	26.0	2.1	4.4	2.1	4.6	5.3	6.3	3.8	6.8	15.0	8.1	5.0	3.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.6	79.0	82.6	88.0	91.4	93.6	97.0	97.0	95.3	91.3	86.1	80.4
		MCWB	67.7	68.9	72.9	77.5	79.7	80.6	80.0	80.1	79.1	79.0	73.8	70.2
	2%	DB	71.9	74.9	78.7	84.6	89.3	91.7	94.8	94.8	91.8	87.7	82.6	75.6
		MCWB	64.8	66.5	69.7	75.6	78.4	80.6	80.5	80.6	79.3	77.5	72.6	67.7
	5%	DB	69.8	71.3	75.4	82.4	86.4	90.6	93.2	93.0	89.9	84.5	80.3	73.4
		MCWB	63.9	65.0	68.4	74.4	77.5	80.3	80.8	80.8	79.0	75.7	72.0	66.7
	10%	DB	67.8	68.1	73.1	80.2	84.4	89.3	91.5	91.3	88.1	82.5	77.4	71.4
		MCWB	62.9	63.3	67.5	73.3	76.6	79.9	80.4	80.2	78.7	74.5	70.8	65.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	70.9	74.6	79.2	81.7	84.6	85.1	84.5	83.4	80.6	76.8	72.4
		MCDB	72.8	76.5	80.2	84.6	87.8	90.3	91.9	91.5	89.7	87.1	81.5	77.8
	2%	WB	67.0	68.3	72.2	77.6	80.0	82.8	83.6	83.2	81.8	79.1	74.7	70.1
		MCDB	70.5	72.5	76.5	82.6	85.6	88.6	90.2	90.2	87.9	84.6	79.3	73.5
	5%	WB	65.2	65.9	70.2	76.0	79.0	81.6	82.5	82.2	80.5	77.8	73.3	68.6
		MCDB	68.5	69.3	74.0	80.7	84.4	87.5	88.8	89.0	86.7	82.8	77.9	71.8
	10%	WB	63.6	63.9	68.1	74.4	78.0	80.5	81.5	81.2	79.5	76.4	72.1	66.9
		MCDB	66.7	67.4	71.7	78.9	83.2	86.5	88.0	87.7	85.4	80.8	76.5	70.2
Mean Daily Temperature Range	5% DB	MDBR	9.0	9.3	10.4	10.8	10.8	10.7	12.2	11.9	10.8	9.3	9.2	8.8
		MCDBR	13.3	15.5	15.5	14.3	13.4	12.6	13.9	14.1	13.2	12.5	12.9	13.2
		MCWBR	8.4	9.3	9.3	8.3	6.9	6.1	5.9	5.7	6.1	6.3	7.0	8.2
	5% WB	MCDBR	11.2	13.8	14.0	13.0	11.6	11.6	12.5	12.4	11.7	11.2	11.2	11.3
		MCWBR	7.7	9.3	9.4	8.2	6.7	6.5	6.3	6.1	6.2	6.3	6.9	7.7
Clear-Sky Solar Irradiance	taub	0.556	0.597	0.701	0.703	0.602	0.561	0.545	0.565	0.547	0.544	0.541	0.551	
	taud	1.843	1.781	1.594	1.639	1.897	2.021	2.065	2.003	2.028	1.976	1.959	1.868	
	Ebn at Noon	217	220	205	210	232	239	243	238	239	231	220	211	
	Edh at Noon	59	67	84	82	63	56	53	56	54	54	52	55	
All-Sky Solar Radiation	RadAvg	707	798	999	1136	1324	1541	1915	1733	1474	1171	827	699	
	RadStd	145	159	144	171	239	187	108	153	158	142	106	121	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+259	+218
Regional (20 neighbors)		N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	+146

Nomenclature: See separate page