

TAIPEI, Taiwan

WMO: 466920

Lat: 25.033N

Lon: 121.515E

Elev: 30

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.7	51.7	39.8	36.1	53.8	42.0	39.4	55.2	18.2	64.7	16.6	63.0	5.1	160	0.349

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	94.6	79.4	93.1	79.1	91.7	78.8	81.3	90.8	80.5	90.0	79.8	88.9	8.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	149.6	86.1	78.0	145.5	85.5	77.3	142.0	85.0	45.1	91.5	44.2	90.5	43.4	89.2	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.8	14.3	DB	47.2	97.2	1.9	1.9	45.8	98.6	44.7	99.7	43.6	100.8	42.2	102.2	(4)
(5)			WB	42.9	82.8	2.2	0.9	41.3	83.4	40.0	84.0	38.8	84.5	37.2	85.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.7	61.0	61.3	65.6	71.9	77.7	82.4	85.7	84.8	80.9	75.2	71.5	65.5	(6)	
	DBStd	9.73	4.98	5.63	6.03	6.58	5.07	4.08	2.42	2.43	3.90	4.02	4.94	4.98	(7)	
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	419	140	132	67	19	0	0	0	0	0	0	8	53	(9)	
	CDD50	8656	343	316	485	657	857	973	1108	1080	928	783	645	481	(10)	
	CDD65	3601	17	28	87	227	393	523	643	615	478	318	203	69	(11)	
	CDH74	33956	10	41	301	1334	3183	5794	8262	7581	4840	1723	769	118	(12)	
(13)	CDH80	12967	0	1	42	307	985	2356	3986	3328	1555	311	91	5	(13)	
(14)	Wind	WSAvg	6.8	6.9	6.7	6.8	6.6	6.6	5.3	5.6	6.2	7.1	8.2	8.4	7.8	(14)
(15) Precipitation	PrecAvg	87.3	3.5	5.9	6.9	6.4	9.1	12.0	9.1	11.3	12.0	5.3	3.0	2.9	(15)	
	PrecMax	173.4	9.4	20.4	19.9	19.6	21.8	29.8	20.7	24.8	28.1	39.3	10.4	5.9	(16)	
	PrecMin	57.6	0.2	0.6	1.5	0.0	2.4	1.1	0.7	1.5	1.5	0.7	0.1	0.3	(17)	
	PrecStd	20.2	2.0	5.1	4.0	4.4	4.6	6.6	4.2	5.7	7.4	6.7	1.9	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	78.4	84.2	89.0	93.6	95.5	96.5	96.2	93.5	88.8	84.9	80.1	(19)	
		MCWB	64.3	67.9	72.1	75.7	78.1	79.0	79.9	80.0	78.2	77.1	73.0	70.7	(20)	
	2%	DB	71.9	74.8	80.5	86.0	90.4	93.4	95.0	93.5	91.4	86.2	82.6	77.3	(21)	
		MCWB	64.3	66.0	70.9	74.5	77.3	79.0	79.7	79.5	77.9	75.6	72.1	68.4	(22)	
	5%	DB	69.6	71.8	77.3	83.6	87.7	91.5	93.4	92.1	89.4	83.4	80.4	74.6	(23)	
		MCWB	63.0	64.7	69.3	74.2	76.7	78.8	79.4	79.1	77.8	74.2	71.1	67.6	(24)	
	10%	DB	67.4	69.2	74.5	81.2	85.3	89.7	91.8	90.6	87.2	81.0	78.3	72.4	(25)	
		MCWB	62.1	63.5	67.7	73.0	75.7	78.4	79.0	78.8	77.2	72.8	70.4	66.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.1	69.2	73.0	77.2	79.9	81.7	82.6	82.2	81.2	78.2	75.0	72.0	(27)	
		MCDB	72.2	75.8	81.8	86.5	89.9	91.1	91.4	92.0	88.1	86.8	82.7	77.9	(28)	
	2%	WB	65.5	67.2	71.5	75.7	78.5	80.5	81.4	81.0	79.7	76.7	73.3	70.1	(29)	
		MCDB	70.1	73.3	79.0	84.2	88.2	90.3	91.2	90.4	86.8	83.2	79.4	75.1	(30)	
	5%	WB	64.1	65.5	70.0	74.6	77.3	79.7	80.5	80.1	78.9	75.7	72.2	68.7	(31)	
		MCDB	68.4	70.8	76.7	82.4	86.1	88.9	90.7	89.2	86.2	81.3	78.4	73.6	(32)	
	10%	WB	62.8	63.9	68.3	73.5	76.3	78.9	79.7	79.5	78.1	74.5	71.3	66.9	(33)	
		MCDB	66.7	68.6	74.0	80.4	84.2	87.5	89.4	88.1	85.0	79.6	77.4	71.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	7.8	9.5	10.2	10.6	11.6	12.3	11.2	9.4	7.0	7.5	7.2	(35)	
		MCDBR	11.5	13.0	15.0	14.5	14.3	14.7	13.9	13.2	12.3	11.2	10.5	11.2	(36)	
	5% WB	MCWBR	6.5	7.0	7.6	7.4	6.9	6.4	5.7	5.5	4.9	5.4	4.9	6.0	(37)	
		MCWBR	10.3	11.7	14.2	13.7	13.2	13.3	13.0	12.1	10.8	9.2	8.7	10.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.555	0.592	0.694	0.697	0.603	0.563	0.537	0.555	0.539	0.541	0.541	0.552	(40)	
		taud	1.854	1.801	1.615	1.659	1.901	2.019	2.094	2.036	2.057	1.990	1.967	1.877	(41)	
	Ebn at Noon		217	221	207	211	231	239	245	241	241	232	220	211	(42)	
		Edh at Noon	58	65	82	81	63	56	52	55	52	53	51	55	(43)	
(44) All-Sky Solar Radiation	RadAvg		701	792	979	1107	1287	1508	1872	1692	1439	1142	818	689	(44)	
	RadStd		138	157	149	171	235	187	102	149	154	139	101	118	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	+146

Nomenclature: See separate page