

TAIPEI, Taiwan

WMO: 466920

Lat: 25.033N

Lon: 121.515E

Elev: 9

StdP: 101.22

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	10.9	4.3	5.2	12.1	5.6	5.6	12.9	8.1	18.2	7.4	17.2	2.3	160	0.349

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	34.8	26.3	34.0	26.2	33.2	26.0	27.4	32.6	26.9	32.2	26.5	31.6	3.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	30.1	25.5	20.8	29.7	25.1	20.3	29.4	87.0	33.0	84.9	32.5	83.2	31.8	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.8	7.1	6.4	8.4	36.2	1.1	1.1	7.7	37.0	7.0	37.6	6.4	38.2	5.7	39.0
			6.1	28.2	1.2	0.5	5.2	28.6	4.5	28.9	3.8	29.2	2.9	29.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.2	16.1	16.3	18.7	22.2	25.4	28.0	29.9	29.4	27.2	24.0	22.0	18.6
	DBStd	5.41	2.77	3.13	3.35	3.66	2.82	2.26	1.35	1.35	2.16	2.23	2.75	2.77
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	233	78	73	37	11	0	0	0	0	0	0	4	29
	CDD10.0	4809	191	176	269	365	476	541	616	600	516	435	358	267
	CDD18.3	2001	9	16	48	126	218	291	357	342	266	177	113	38
	CDH23.3	18864	6	23	167	741	1768	3219	4590	4212	2689	957	427	66
(13)	CDH26.7	7204	0	1	23	171	547	1309	2214	1849	864	173	51	3
(14)	Wind	WSAvg	3.1	3.1	3.0	3.0	2.9	2.4	2.5	2.8	3.2	3.7	3.7	3.5
(15) Precipitation	PrecAvg	2218	88	151	176	163	231	305	232	286	306	135	76	73
	PrecMax	4405	239	518	506	498	553	758	525	630	715	998	263	150
	PrecMin	1463	5	16	39	1	60	29	17	38	37	18	2	8
	PrecStd	514	51	130	101	112	117	167	107	144	187	170	49	38
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	25.8	29.0	31.7	34.2	35.3	35.8	35.7	34.2	31.6	29.4	26.7
		MCWB	18.0	19.9	22.3	24.3	25.6	26.1	26.6	26.7	25.7	25.1	22.8	21.5
	2%	DB	22.2	23.8	27.0	30.0	32.5	34.1	35.0	34.2	33.0	30.1	28.1	25.1
		MCWB	18.0	18.9	21.6	23.6	25.2	26.1	26.5	26.4	25.5	24.2	22.3	20.2
	5%	DB	20.9	22.1	25.2	28.7	30.9	33.1	34.1	33.4	31.9	28.6	26.9	23.7
		MCWB	17.2	18.1	20.7	23.4	24.8	26.0	26.3	26.2	25.4	23.5	21.7	19.8
	10%	DB	19.7	20.7	23.6	27.3	29.6	32.0	33.2	32.5	30.7	27.2	25.7	22.5
		MCWB	16.7	17.5	19.8	22.8	24.3	25.8	26.1	26.0	25.1	22.7	21.3	19.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	20.7	22.8	25.1	26.6	27.6	28.1	27.9	27.3	25.7	23.9	22.2
		MCDB	22.3	24.3	27.7	30.3	32.2	32.8	33.0	33.3	31.2	30.5	28.2	25.5
	2%	WB	18.6	19.5	22.0	24.3	25.8	26.9	27.4	27.2	26.5	24.8	23.0	21.2
		MCDB	21.2	22.9	26.1	29.0	31.2	32.4	32.9	32.5	30.4	28.5	26.4	23.9
	5%	WB	17.9	18.6	21.1	23.7	25.2	26.5	26.9	26.7	26.0	24.3	22.4	20.4
		MCDB	20.2	21.6	24.8	28.0	30.1	31.6	32.6	31.8	30.1	27.4	25.8	23.1
	10%	WB	17.1	17.7	20.2	23.0	24.6	26.1	26.5	26.4	25.6	23.6	21.8	19.4
		MCDB	19.3	20.3	23.3	26.9	29.0	30.8	31.9	31.1	29.5	26.4	25.2	22.2
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.3	5.3	5.7	5.9	6.4	6.8	6.2	5.2	3.9	4.2	4.0
		MCDBR	6.4	7.2	8.3	8.1	7.9	8.2	7.7	7.3	6.9	6.2	5.8	6.2
		MCWBR	3.6	3.9	4.2	4.1	3.8	3.5	3.1	3.0	2.7	3.0	2.7	3.3
	5% WB	MCDBR	5.7	6.5	7.9	7.6	7.3	7.4	7.2	6.7	6.0	5.1	4.8	5.7
		MCWBR	3.6	3.7	4.4	4.2	3.7	3.6	3.4	3.1	2.8	2.7	2.6	3.3
(40) Clear-Sky Solar Irradiance	taub		0.555	0.592	0.694	0.697	0.603	0.563	0.537	0.555	0.539	0.541	0.541	0.552
	taud		1.854	1.801	1.615	1.659	1.901	2.019	2.094	2.036	2.057	1.990	1.967	1.877
	Ebn at Noon		685	696	651	665	729	753	773	759	761	731	695	666
	Edh at Noon		183	206	260	254	199	176	163	172	165	168	162	173
(44) All-Sky Solar Radiation	RadAvg		2.21	2.50	3.08	3.49	4.06	4.75	5.90	5.33	4.54	3.60	2.58	2.17
	RadStd		0.43	0.50	0.47	0.54	0.74	0.59	0.32	0.47	0.49	0.44	0.32	0.37

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (17 neighbors)	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	N/A	+81

Nomenclature: See separate page