

TAIPEI SONGSHAN, Taiwan

WMO: 466960

Lat: 25.069N

Lon: 121.552E

Elev: 18

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.6	51.7	37.1	32.5	53.8	40.6	37.2	55.7	20.3	64.6	18.8	64.1	5.8	100	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	96.4	80.2	94.7	79.8	93.2	79.6	82.7	91.4	81.8	90.0	81.0	88.7	11.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.6	159.2	87.2	79.2	151.8	86.1	79.0	150.4	85.9	46.5	91.9	45.6	91.0	44.8	89.1	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	18.1	16.4	DB	45.5	99.4	3.0	1.8	43.4	100.7	41.6	101.8	40.0	102.8	37.8	104.1
			WB	41.8	84.0	2.8	2.0	39.9	85.5	38.2	86.6	36.7	87.8	34.7	89.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	62.0	63.1	66.1	72.8	78.8	83.6	86.2	82.5	76.9	71.9	65.2	(6)	
(7)		DBStd	10.00	5.63	6.22	6.35	5.97	4.85	4.01	2.37	2.53	3.92	4.24	5.04	5.59	(7)
(8)		HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	375	126	102	65	9	0	0	0	0	0	0	6	67	(9)
(10)		CDD50	9028	373	366	500	684	893	1009	1144	1122	975	834	656	472	(10)
(11)		CDD65	3928	34	48	100	244	428	559	679	657	525	369	211	74	(11)
(12)		CDH74	38563	61	151	425	1500	3669	6377	8896	8350	5636	2454	875	169	(12)
(13)		CDH80	15904	3	20	68	405	1235	2744	4520	4016	2121	579	172	21	(13)
(14)	Wind	WSAvg	7.8	8.2	7.8	7.7	7.2	7.1	6.0	6.9	7.2	8.3	9.0	9.2	8.8	(14)
(15)	Precipitation	PrecAvg	87.3	3.5	5.9	6.9	6.4	9.1	12.0	9.1	11.3	12.0	5.3	3.0	2.9	(15)
(16)		PrecMax	173.4	9.4	20.4	19.9	19.6	21.8	29.8	20.7	24.8	28.1	39.3	10.4	5.9	(16)
(17)		PrecMin	57.6	0.2	0.6	1.5	0.0	2.4	1.1	0.7	1.5	0.7	0.1	0.3	0.3	(17)
(18)		PrecStd	20.2	2.0	5.1	4.0	4.4	4.6	6.6	4.2	5.7	7.4	6.7	1.9	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.1	82.7	85.8	91.3	94.6	96.6	98.7	98.2	95.3	91.6	88.1	82.6	(19)
(20)			MCWB	67.5	69.5	72.6	75.6	78.8	80.5	80.8	81.0	79.5	78.2	74.7	71.0	(20)
(21)		2%	DB	75.3	78.7	82.0	87.5	91.5	94.6	96.6	95.2	93.3	88.2	84.4	78.6	(21)
(22)			MCWB	65.8	67.4	69.9	75.1	77.8	79.8	80.2	80.1	79.3	76.6	73.1	69.0	(22)
(23)		5%	DB	72.0	75.1	78.8	84.4	89.4	92.8	94.8	93.5	91.4	85.9	81.0	75.2	(23)
(24)			MCWB	64.2	66.3	68.5	73.7	77.1	79.6	79.9	79.9	78.8	75.7	72.2	67.9	(24)
(25)		10%	DB	69.7	71.6	75.5	82.2	86.3	91.0	93.1	91.8	89.4	82.7	78.8	73.0	(25)
(26)			MCWB	63.9	64.9	67.7	72.9	76.0	79.2	79.8	79.6	78.0	74.2	71.9	66.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.9	71.4	74.2	78.4	81.4	83.2	84.0	83.7	82.5	80.0	77.1	72.9	(27)
(28)			MCD B	76.0	79.4	81.3	87.2	89.8	92.5	93.7	93.4	91.0	87.2	84.3	79.0	(28)
(29)		2%	WB	67.4	69.0	72.0	76.6	79.7	81.8	82.7	82.6	81.1	78.3	75.3	70.9	(29)
(30)			MCD B	72.5	75.6	78.8	84.2	87.3	90.3	91.5	91.0	88.5	84.5	80.9	75.8	(30)
(31)		5%	WB	65.7	67.2	70.3	75.4	78.5	80.8	81.7	81.7	80.1	77.0	73.9	69.2	(31)
(32)			MCD B	70.5	73.2	76.6	82.2	85.9	88.6	90.0	89.4	87.0	83.3	79.0	73.6	(32)
(33)		10%	WB	64.4	65.3	68.7	74.1	77.3	79.9	80.8	80.8	79.2	75.9	72.6	67.4	(33)
(34)			MCD B	68.7	70.7	74.4	80.1	84.2	87.3	88.8	88.1	85.9	81.5	77.5	72.0	(34)
(35)	Mean Daily Temperature Range	MDBR	9.6	10.4	11.8	12.2	12.0	12.2	13.0	12.4	11.0	9.6	9.5	9.3	(35)	
(36)		5% DB	MCD BR	14.9	17.4	17.1	16.5	15.7	14.6	14.8	14.0	13.6	13.2	13.2	13.8	(36)
(37)			MCWBR	7.9	8.5	8.6	7.6	6.8	5.7	5.6	5.4	5.2	5.5	6.1	7.1	(37)
(38)		5% WB	MCD BR	12.5	15.6	15.5	14.8	13.8	13.3	13.5	12.8	12.0	11.2	11.6	11.9	(38)
(39)			MCWBR	7.3	8.5	8.8	7.7	6.8	5.9	6.0	5.7	5.4	5.5	6.4	7.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.557	0.593	0.693	0.695	0.602	0.563	0.535	0.552	0.537	0.541	0.541	0.553	(40)	
(41)		taud	1.853	1.802	1.618	1.663	1.904	2.024	2.104	2.047	2.064	1.992	1.967	1.876	(41)	
(42)		Ebn at Noon	217	221	207	211	232	239	246	241	242	232	220	211	(42)	
(43)		Edh at Noon	58	65	82	80	63	56	51	54	52	53	51	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	690	781	974	1108	1294	1518	1889	1706	1447	1140	811	679	(44)	
(45)		RadStd	139	158	151	172	236	187	102	149	154	141	102	118	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	+0.68	N/A	-1.08	N/A	N/A	N/A	N/A	(46)
(47)	Regional (17 neighbors)	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	+146	(47)

Nomenclature: See separate page