

TAOYUAN, Taiwan

WMO: 466970

Lat: 25.056N

Lon: 121.243E

Elev: 46

StdP: 100.77

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.7	9.8	5.0	5.4	9.7	6.3	6.0	10.8	12.0	15.8	11.3	15.2	5.2	60	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	34.0	28.2	33.2	27.9	32.7	27.6	29.2	32.8	28.5	32.3	28.0	31.8	6.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.2	24.5	32.2	27.3	23.3	31.5	26.9	22.7	31.1	96.2	32.8	92.7	32.6	90.2	31.9	34.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.7	9.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	4.6	31.1	2.2	1.7	3.0	32.3	1.7	33.3	0.5	34.2	-1.2	35.4	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.4	15.4	15.3	17.2	21.3	24.6	27.4	29.3	29.2	26.8	23.8	20.4	17.4
	DBStd	5.64	2.67	3.09	3.41	3.40	2.70	2.22	1.14	1.25	2.37	2.21	3.17	2.71
	HDD10.0	2	1	1	1	0	0	0	0	0	0	0	0	0
	HDD18.3	329	95	93	62	13	1	0	0	0	0	0	15	51
	CDD10.0	4521	169	150	224	339	452	521	597	594	505	429	312	229
	CDD18.3	1807	6	9	27	102	194	271	339	336	255	171	77	21
	CDH23.3	16770	9	26	91	501	1433	2842	4174	4019	2443	914	278	39
	CDH26.7	6114	0	1	13	87	393	1046	1841	1678	814	194	45	2
Wind	WSAvg	4.6	5.3	5.0	4.5	3.8	3.3	3.6	3.5	3.9	4.3	6.0	6.2	5.6
Precipitation	PrecAvg	2416	127	185	183	178	221	274	149	235	353	231	157	123
	PrecMax	3635	275	434	307	517	657	693	343	553	1721	940	527	287
	PrecMin	1064	42	26	78	32	15	57	12	18	12	1	6	11
	PrecStd	661	53	113	54	118	134	160	97	173	382	206	126	89
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	26.1	28.2	30.1	32.2	33.2	35.2	35.1	34.2	31.9	30.0	26.2
		MCWB	20.1	22.1	24.3	25.6	27.3	28.2	28.7	28.2	27.4	26.1	24.4	21.7
	2%	DB	22.2	23.9	25.9	28.9	31.1	32.8	34.1	34.0	33.0	30.1	28.0	24.2
		MCWB	18.5	20.3	22.5	24.7	26.9	27.9	28.5	28.1	27.1	25.5	23.4	20.6
	5%	DB	20.8	21.6	23.8	27.8	30.1	32.0	33.2	33.1	32.0	28.9	26.2	22.9
		MCWB	17.6	18.7	21.3	24.0	26.2	27.4	28.2	27.7	26.8	24.6	22.5	19.8
	10%	DB	19.1	19.8	21.9	26.2	29.0	31.2	32.7	32.2	30.9	27.5	24.9	21.2
		MCWB	17.0	17.7	19.8	23.0	25.5	27.0	27.9	27.3	26.4	23.7	21.9	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.9	22.6	25.1	26.2	28.6	29.5	30.4	29.7	28.7	26.8	25.4	23.0
		MCDB	23.7	25.7	28.0	29.4	31.5	32.4	33.6	33.3	32.2	30.4	28.2	25.4
	2%	WB	19.2	20.6	22.9	25.1	27.2	28.5	29.5	28.8	27.7	26.0	24.1	21.4
		MCDB	21.7	23.0	25.3	28.1	30.4	31.8	33.1	32.9	31.7	29.3	27.1	23.6
	5%	WB	18.2	19.0	21.5	24.2	26.4	27.7	28.7	28.2	27.1	25.1	23.1	20.3
		MCDB	20.0	21.2	23.5	26.9	29.5	31.3	32.5	32.2	31.0	28.1	25.7	22.2
	10%	WB	17.2	17.7	20.2	23.5	25.8	27.1	28.0	27.6	26.5	24.3	22.2	19.2
		MCDB	18.8	19.6	21.7	25.9	28.7	30.7	32.0	31.5	29.9	26.8	24.4	21.1
Mean Daily Temperature Range	5% DB	MDBR	6.0	5.8	5.9	6.3	6.4	6.5	7.1	6.6	6.5	6.0	5.7	6.1
		MCDBR	9.0	9.3	9.3	8.0	7.9	7.2	7.7	7.6	7.8	7.7	7.8	8.0
		MCWBR	6.2	6.5	6.6	5.2	5.3	4.4	4.9	4.3	4.4	4.8	4.9	5.6
	5% WB	MCDBR	8.0	8.9	8.9	7.4	7.4	7.1	7.4	7.1	7.1	6.9	7.2	7.5
		MCWBR	5.9	6.5	6.5	5.1	5.2	4.7	5.2	4.5	4.4	4.9	4.9	5.7
Clear-Sky Solar Irradiance	taub		0.554	0.595	0.700	0.702	0.602	0.562	0.545	0.565	0.547	0.543	0.539	0.550
	taud		1.846	1.783	1.594	1.638	1.895	2.017	2.061	1.999	2.026	1.977	1.961	1.870
	Ebn at Noon		686	694	646	661	730	754	766	751	755	729	696	668
	Edh at Noon		184	210	266	260	200	176	168	179	170	170	163	174
All-Sky Solar Radiation	RadAvg		2.24	2.53	3.15	3.58	4.17	4.85	6.02	5.45	4.64	3.69	2.62	2.21
	RadStd		0.45	0.50	0.45	0.54	0.75	0.59	0.34	0.48	0.50	0.45	0.33	0.38

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	N/A	+81

Nomenclature: See separate page