

SU'AO, Taiwan

WMO: 467060

Lat: 24.597N

Lon: 121.857E

Elev: 25

StdP: 101.03

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 10.8	(c) 11.6	(d) 4.4	(e) 5.2	(f) 11.9	(g) 6.1	(h) 5.9	(i) 13.3	(j) 7.5	(k) 16.8	(l) 6.9	(m) 16.8	(n) 4.0	(o) 280	(p) 0.304

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	32.0	26.5	31.5	26.3	31.0	26.2	27.4	30.5	27.0	30.4	26.7	30.1	4.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	29.5	26.1	21.5	29.4	25.6	21.0	29.2	87.3	30.5	85.5	30.4	83.9	30.3	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.2	(b) 7.0	(c) 6.1	(e) 9.2	(f) 33.3	(g) 1.1	(h) 0.6	(i) 8.3	(j) 33.7	(k) 7.7	(l) 34.1	(m) 7.0	(n) 34.4	(o) 6.2	(p) 34.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.6	16.3	16.6	18.9	21.8	24.3	27.0	28.4	28.2	26.2	23.3	21.3	18.4		
	DBStd	4.78	2.54	2.95	3.05	3.19	2.31	1.96	0.94	0.99	1.62	2.10	2.40	2.60		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	213	72	64	31	9	1	0	0	0	0	0	5	32		
	CDD10.0	4593	196	186	274	353	442	509	572	563	486	413	341	259		
	CDD18.3	1764	9	16	47	112	184	259	313	305	236	154	96	32		
	CDH23.3	15641	6	13	119	558	1267	2738	3953	3728	2202	749	276	31		
(14) Wind	WSAvg	2.7	3.1	3.0	2.5	2.2	2.1	2.2	3.0	3.0	3.0	3.0	2.9	3.0		
	PrecAvg	3724	286	246	161	173	239	221	161	264	466	617	536	353		
	PrecMax	6196	782	668	332	568	618	402	416	687	1170	1972	1281	869		
	PrecMin	2142	58	44	37	32	40	64	3	58	108	128	58	81		
	PrecStd	938	189	137	61	127	159	90	120	163	239	437	351	231		
	DB	24.2	24.7	27.2	29.5	30.8	32.4	32.7	32.7	31.1	29.5	28.1	25.2	25.2		
	MCWB	19.5	20.4	22.7	24.3	25.5	26.6	26.6	26.4	26.2	25.0	23.4	21.3	21.3		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	22.5	23.6	25.9	28.4	29.9	31.7	32.1	31.9	30.2	28.5	26.8	24.2	24.2		
	2% MCWB	18.6	19.7	21.9	24.0	25.3	26.3	26.5	26.6	25.7	24.4	23.0	20.6	20.6		
	5% DB	21.3	22.5	24.7	27.4	29.0	31.0	31.5	31.3	29.7	27.5	25.9	23.1	23.1		
	5% MCWB	18.1	19.0	21.3	23.7	25.0	26.2	26.4	26.3	25.5	23.8	22.5	20.0	20.0		
	10% DB	20.3	21.3	23.5	26.4	28.0	30.3	31.0	30.7	29.1	26.6	24.9	22.1	22.1		
	10% MCWB	17.6	18.4	20.7	23.2	24.4	26.0	26.2	26.1	25.2	23.3	21.7	19.4	19.4		
	WB	20.5	21.4	23.2	25.2	26.4	27.7	27.8	28.1	27.1	25.9	24.4	22.3	22.3		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	22.4	23.7	26.3	27.9	29.5	30.6	31.0	30.6	29.5	28.3	26.8	24.3	24.3		
	2% WB	19.6	20.6	22.5	24.6	25.8	27.1	27.2	27.5	26.6	25.2	23.6	21.4	21.4		
	2% MCDB	21.7	22.8	25.3	27.4	28.8	30.4	30.9	30.3	29.1	27.4	25.9	23.2	23.2		
	5% WB	18.7	19.6	21.9	24.0	25.2	26.6	26.9	27.1	26.1	24.6	23.1	20.6	20.6		
	5% MCDB	20.7	21.8	24.3	26.8	28.2	30.0	30.7	30.2	28.8	26.7	25.3	22.6	22.6		
	10% WB	17.9	18.7	21.0	23.4	24.7	26.2	26.5	26.7	25.6	24.0	22.4	19.7	19.7		
	10% MCDB	19.9	21.0	23.2	26.0	27.6	29.6	30.4	29.9	28.3	26.2	24.6	21.9	21.9		
(35) Mean Daily Temperature Range	MDBR	4.1	4.1	4.6	4.8	4.8	4.8	5.0	4.6	4.2	3.7	4.1	3.8	3.8		
	5% DB MCDBR	6.2	6.3	6.3	6.3	5.9	5.7	5.7	5.4	5.0	5.2	5.7	5.5	5.5		
	5% DB MCWBR	3.8	3.9	3.7	3.5	3.1	2.7	2.9	2.7	2.9	3.1	3.1	3.5	3.5		
	5% WB MCDBR	5.2	5.4	6.0	5.7	5.5	5.3	5.4	4.9	4.4	4.2	4.7	4.7	4.7		
	5% WB MCWBR	3.6	3.6	3.8	3.5	3.3	2.9	3.0	2.8	2.7	2.7	2.9	3.2	3.2		
(40) Clear-Sky Solar Irradiance	taub	0.534	0.562	0.657	0.663	0.585	0.541	0.507	0.524	0.516	0.521	0.522	0.536	0.536		
	taud	1.921	1.892	1.701	1.741	1.959	2.088	2.193	2.131	2.137	2.063	2.030	1.939	1.939		
	Ebn at Noon	709	724	679	689	742	770	797	784	782	752	716	686	686		
	Edh at Noon	172	189	239	234	188	164	147	157	153	157	153	163	163		
(44) All-Sky Solar Radiation	RadAvg	2.25	2.62	3.15	3.55	4.19	4.91	5.84	5.29	4.58	3.66	2.64	2.23	2.23		
	RadStd	0.39	0.47	0.46	0.54	0.69	0.56	0.35	0.48	0.47	0.44	0.30	0.37	0.37		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	N/A	N/A	N/A	+0.32	N/A	N/A	N/A	N/A	N/A	+81

Nomenclature: See separate page