

MAGONG, Taiwan

WMO: 467340

Lat: 23.569N

Lon: 119.628E

Elev: 31

StdP: 100.95

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.8	12.8	7.9	6.6	12.9	9.0	7.2	13.5	16.9	13.5	15.2	14.7	11.3	20	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	32.2	27.7	31.8	27.6	31.1	27.5	28.7	31.0	28.2	30.6	27.9	30.3	5.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.1	24.3	30.6	27.5	23.5	30.1	27.1	23.0	29.7	93.6	31.2	91.3	31.0	89.7	30.7	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.2	14.3	13.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			7.1	29.7	2.6	0.5	5.3	30.0	3.8	30.3	2.4	30.6	0.5	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	17.3	17.2	19.3	22.8	25.5	27.5	28.6	28.4	27.5	25.0	22.0	19.0
	DBStd	4.59	2.23	2.62	2.84	2.70	1.83	1.56	0.96	0.95	1.28	1.52	2.03	2.03
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	140	47	50	22	3	0	0	0	0	0	0	2	17
	CDD10.0	4874	226	201	287	383	481	525	577	569	525	464	358	278
	CDD18.3	1972	14	17	51	136	222	275	318	311	275	206	110	36
	CDH23.3	16933	18	36	137	668	1658	2854	3754	3557	2783	1196	244	28
	CDH26.7	4823	0	1	11	97	351	871	1389	1209	748	133	12	1
Wind	WSAvg	6.8	8.7	8.1	7.0	5.7	4.7	4.8	4.3	4.4	5.7	9.0	9.5	9.2
Precipitation	PrecAvg	950	21	47	57	85	116	168	131	167	87	29	22	21
	PrecMax	1458	83	315	268	436	272	349	423	640	400	205	138	84
	PrecMin	531	3	0	2	6	2	10	6	3	1	0	0	0
	PrecStd	291	17	61	57	81	76	109	111	141	93	51	27	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.7	26.2	28.0	29.8	31.9	32.6	33.1	32.9	32.2	30.1	28.1	26.0
		MCWB	21.8	22.7	24.0	25.8	27.1	27.8	28.2	27.2	27.7	25.9	24.3	22.0
	2%	DB	23.1	24.2	26.5	28.9	30.4	31.8	32.2	32.0	31.2	29.0	26.7	23.9
		MCWB	20.1	21.5	23.5	25.2	26.7	27.7	27.9	27.4	27.3	25.4	23.6	21.1
	5%	DB	21.2	22.7	25.0	27.9	29.5	31.1	31.8	31.2	30.8	28.1	25.7	22.8
		MCWB	18.6	20.4	22.6	24.8	26.3	27.6	27.8	27.3	27.1	24.8	22.9	20.2
	10%	DB	20.2	20.9	23.4	26.8	28.8	30.3	31.1	30.9	29.9	27.2	24.8	21.8
		MCWB	17.9	19.0	21.5	24.1	25.8	27.3	27.6	27.3	26.7	24.1	22.4	19.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	23.9	25.0	26.5	28.0	29.0	29.2	29.2	28.7	26.7	25.1	23.0
		MCDB	24.8	25.8	26.7	28.6	29.9	31.3	31.7	31.3	31.1	28.5	27.4	24.9
	2%	WB	20.4	22.0	23.7	25.8	27.1	28.4	28.7	28.3	28.1	26.1	24.1	21.3
		MCDB	22.5	23.9	26.0	27.9	29.6	30.7	31.2	30.5	30.4	28.0	26.0	23.2
	5%	WB	19.1	20.5	22.7	25.1	26.5	27.9	28.2	27.9	27.5	25.6	23.4	20.4
		MCDB	21.0	22.4	24.7	27.3	28.8	30.3	30.8	30.2	29.7	27.4	25.2	22.4
	10%	WB	18.3	19.0	21.6	24.4	26.0	27.4	27.9	27.5	27.0	24.9	22.7	19.5
		MCDB	20.1	20.9	23.3	26.5	28.0	29.7	30.4	29.8	29.1	26.7	24.4	21.4
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.8	5.2	5.3	5.2	5.1	5.3	5.0	4.8	4.4	4.4	4.3
		MCDBR	6.2	7.5	7.6	6.5	6.1	5.7	6.0	5.6	5.8	5.0	5.4	5.6
		MCWBR	4.4	5.5	5.5	4.1	3.7	3.4	3.3	3.1	3.4	3.3	3.6	3.7
	5% WB	MCDBR	6.2	7.1	7.3	6.1	5.7	5.5	5.5	5.3	5.3	4.8	5.0	5.3
		MCWBR	4.6	5.5	5.7	4.2	3.8	3.7	3.4	3.3	3.5	3.4	3.7	3.8
Clear-Sky Solar Irradiance	taub	0.545	0.600	0.708	0.698	0.569	0.513	0.516	0.560	0.591	0.588	0.553	0.553	
	taud	1.894	1.791	1.608	1.672	2.008	2.200	2.183	2.037	1.921	1.873	1.942	1.889	
	Ebn at Noon	705	697	646	666	755	792	790	757	723	697	693	677	
	Edh at Noon	178	210	264	252	179	147	149	172	190	191	169	174	
All-Sky Solar Radiation	RadAvg	2.75	3.16	3.77	4.41	5.09	5.52	6.18	5.47	5.17	4.41	3.21	2.77	
	RadStd	0.43	0.52	0.44	0.56	0.66	0.56	0.44	0.64	0.48	0.41	0.41	0.34	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.28	N/A	N/A	N/A	+0.20	+0.25	+0.25	N/A	N/A	+127	+119

Nomenclature: See separate page