

KINMEN, Taiwan

WMO: 467360

Lat: 24.428N

Lon: 118.359E

Elev: 93

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 90-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	44.8	46.6	37.3	32.9	47.4	39.8	36.2	49.4	23.2	53.5	20.8	54.6	9.0	30	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.9	91.3	83.2	89.8	82.7	88.9	82.3	85.0	89.2	84.0	88.5	82.8	87.2	8.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
84.1	179.5	88.3	82.7	170.8	87.2	81.9	166.7	86.4	49.6	89.1	48.4	88.8	47.1	87.6	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
20.9	18.6	16.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			37.6	95.8	4.3	2.5	34.5	97.6	31.9	99.1	29.5	100.5	26.3	102.3
			36.4	87.7	3.2	1.6	34.1	88.9	32.2	89.8	30.4	90.7	28.0	91.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	56.5	56.1	59.2	66.3	73.3	79.7	83.0	83.2	81.1	75.1	68.9	61.5
	DBStd	10.69	4.71	4.94	4.55	5.28	4.08	3.67	2.11	2.20	3.17	4.07	4.47	4.57
	HDD50	16	6	8	0	0	0	0	0	0	0	0	0	2
	HDD65	894	266	251	186	48	2	0	0	0	0	0	16	125
	CDD50	7464	207	179	286	488	723	890	1024	1029	932	780	568	358
	CDD65	2865	1	1	7	86	260	440	559	564	482	315	134	16
	CDH74	25400	2	1	14	158	1221	4089	6386	6431	4789	1883	406	20
	CDH80	7844	0	0	1	7	171	1107	2296	2329	1507	387	39	0
(14) Wind	WSAvg	7.4	8.4	8.0	7.0	5.7	5.2	7.1	6.6	6.6	7.5	9.4	9.0	9.0
(15) Precipitation	PrecAvg	50.2	1.4	2.6	3.7	5.1	6.4	7.6	5.7	8.0	5.0	1.8	1.4	1.8
	PrecMax	78.7	7.4	8.5	11.7	12.4	19.0	19.3	17.3	17.0	16.9	11.1	8.1	7.8
	PrecMin	32.4	0.0	0.0	0.9	1.6	0.3	1.6	0.1	1.0	0.2	0.0	0.0	0.1
	PrecStd	11.8	1.5	2.3	2.8	2.7	3.5	3.9	4.1	4.4	4.4	2.9	2.0	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	73.0	76.1	80.8	86.4	90.7	93.3	93.1	91.7	89.5	83.8	76.7
		MCWB	65.6	65.0	68.9	74.9	79.9	83.3	84.0	83.8	82.7	80.3	75.5	70.4
	2%	DB	68.4	68.4	71.3	78.4	83.9	88.4	91.0	91.2	89.9	86.1	80.7	73.2
		MCWB	62.9	63.3	66.5	72.6	78.4	82.3	83.2	83.7	82.0	77.8	73.6	67.0
	5%	DB	66.1	66.2	68.2	75.5	82.1	87.0	89.6	89.7	88.9	84.0	78.5	70.2
		MCWB	60.8	61.8	64.4	71.0	77.1	81.6	82.7	83.0	81.7	76.2	71.9	64.7
	10%	DB	63.5	64.0	66.1	73.5	79.7	85.7	88.1	88.2	87.4	82.1	76.1	68.3
		MCWB	59.3	59.8	62.8	69.7	75.1	81.1	82.2	82.3	81.0	75.0	70.1	63.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.1	66.9	70.0	76.6	81.5	84.6	86.1	86.5	86.6	81.2	78.2	71.1
		MCDB	71.2	70.2	74.2	79.4	84.6	88.6	90.0	90.1	89.4	87.5	81.9	74.8
	2%	WB	63.7	64.6	67.6	74.2	79.2	83.5	84.7	84.9	83.8	79.0	74.7	68.1
		MCDB	67.9	68.1	70.6	76.9	82.4	87.2	89.3	89.3	87.9	84.5	79.3	71.7
	5%	WB	61.5	62.3	65.5	72.2	77.9	82.4	83.6	83.9	82.3	77.3	73.0	66.0
		MCDB	65.0	65.5	67.8	74.6	80.8	86.0	88.3	88.6	87.2	82.3	77.0	69.6
	10%	WB	59.7	60.0	63.3	70.6	76.4	81.3	82.6	82.7	81.0	75.8	71.3	64.3
		MCDB	63.0	63.3	65.6	72.8	79.1	84.3	87.0	87.2	85.4	80.7	75.0	67.9
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	11.4	10.7	11.1	10.5	10.0	10.5	10.9	11.2	12.5	13.4	12.5
		MCDBR	16.2	15.1	14.0	13.6	13.2	11.4	12.2	12.6	13.1	14.0	15.7	15.2
		MCWBR	12.1	11.6	10.8	10.4	9.2	7.2	7.7	7.8	8.3	8.9	10.9	10.9
	5% WB	MCDBR	15.1	13.9	13.5	12.9	12.2	10.9	11.4	12.0	12.4	13.3	14.5	14.3
		MCWBR	12.0	11.3	11.2	10.4	9.4	7.6	7.9	8.4	8.8	9.6	11.1	10.9
(40) Clear-Sky Solar Irradiance	taub		0.556	0.622	0.720	0.718	0.602	0.547	0.522	0.578	0.594	0.584	0.550	0.540
	taud		1.832	1.731	1.573	1.625	1.908	2.070	2.142	1.967	1.899	1.862	1.917	1.893
	Ebn at Noon		218	214	201	207	232	243	249	235	228	221	219	216
	Edh at Noon		60	70	86	83	63	53	49	59	62	61	55	54
(44) All-Sky Solar Radiation	RadAvg		916	966	1122	1269	1411	1561	1879	1691	1535	1302	1008	906
	RadStd		135	163	142	192	213	173	130	151	134	151	105	110

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.58	N/A	N/A	+0.76	N/A	+0.36	N/A	N/A	+238	+194

Nomenclature: See separate page