

KINMEN, Taiwan

WMO: 467360

Lat: 24.428N

Lon: 118.359E

Elev: 28

StdP: 100.99

Time Zone: 8.00 (E08)

Period: 90-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.1	8.1	3.0	4.7	8.6	4.3	5.2	9.7	10.4	12.0	9.3	12.6	4.0	30	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.1	32.9	28.5	32.1	28.1	31.6	27.9	29.5	31.8	28.9	31.4	28.2	30.7	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
29.0	25.6	31.3	28.1	24.4	30.7	27.7	23.8	30.2	97.5	31.7	94.6	31.6	91.6	30.9	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.3	7.4	3.1	35.4	2.4	1.4	1.4	36.4	0.0	37.3	-1.4	38.0	-3.1	39.1		
(5)			2.4	31.0	1.8	0.9	1.1	31.6	0.1	32.1	-0.9	32.6	-2.2	33.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	13.6	13.4	15.1	19.0	23.0	26.5	28.4	27.3	24.0	20.5	16.4	(6)	(7)	
(7)		DBStd	5.94	2.61	2.74	2.53	2.94	2.27	2.04	1.17	1.22	1.76	2.26	2.48	2.54	(7)	(8)
(8)		HDD10.0	9	3	4	0	0	0	0	0	0	0	0	0	1	(8)	(9)
(9)		HDD18.3	497	148	139	103	27	1	0	0	0	0	0	9	69	(9)	(10)
(10)		CDD10.0	4147	115	99	159	271	402	494	569	572	518	433	316	199	(10)	(11)
(11)		CDD18.3	1592	1	1	4	48	144	244	311	313	268	175	74	9	(11)	(12)
(12)		CDH23.3	14111	1	1	8	88	678	2272	3548	3573	2661	1046	226	11	(12)	(13)
(13)		CDH26.7	4358	0	0	1	4	95	615	1276	1294	837	215	22	0	(13)	(14)
(14)	Wind	WSAvg	3.3	3.7	3.6	3.1	2.5	2.3	3.2	2.9	3.3	4.2	4.0	4.0	(14)	(15)	
(15)	Precipitation	PrecAvg	1274	36	65	93	129	162	192	144	203	126	45	36	45	(15)	(16)
(16)		PrecMax	2000	188	215	298	316	482	491	439	432	430	281	206	197	(16)	(17)
(17)		PrecMin	824	0	0	22	40	7	40	3	25	6	0	0	2	(17)	(18)
(18)		PrecStd	299	37	58	70	68	89	100	104	112	113	74	52	41	(18)	(19)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	22.8	24.5	27.1	30.2	32.6	34.1	33.9	33.2	32.0	28.8	24.8	(19)	(20)
(20)			MCWB	18.7	18.4	20.5	23.8	26.6	28.5	28.9	28.8	28.2	26.8	24.1	21.3	(20)	(21)
(21)		2%	DB	20.2	20.2	21.8	25.8	28.8	31.3	32.8	32.9	32.2	30.0	27.1	22.9	(21)	(22)
(22)			MCWB	17.2	17.4	19.2	22.6	25.8	27.9	28.4	28.7	27.8	25.4	23.1	19.5	(22)	(23)
(23)		5%	DB	18.9	19.0	20.1	24.2	27.8	30.5	32.0	32.1	31.6	28.9	25.8	21.2	(23)	(24)
(24)			MCWB	16.0	16.5	18.0	21.7	25.1	27.6	28.2	28.3	27.6	24.6	22.2	18.1	(24)	(25)
(25)		10%	DB	17.5	17.8	18.9	23.0	26.5	29.8	31.2	31.2	30.8	27.9	24.5	20.2	(25)	(26)
(26)			MCWB	15.2	15.4	17.1	20.9	24.0	27.3	27.9	27.9	27.2	23.9	21.1	17.5	(26)	(27)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	19.4	21.1	24.8	27.5	29.2	30.1	30.3	30.3	27.3	25.6	21.7	(27)	(28)
(28)			MCDWB	21.8	21.2	23.5	26.3	29.2	31.4	32.2	32.3	31.9	30.9	27.7	23.8	(28)	(29)
(29)		2%	WB	17.6	18.1	19.8	23.5	26.2	28.6	29.3	29.4	28.8	26.1	23.7	20.0	(29)	(30)
(30)			MCDWB	20.0	20.0	21.4	24.9	28.0	30.7	31.8	31.8	31.1	29.2	26.3	22.1	(30)	(31)
(31)		5%	WB	16.4	16.8	18.6	22.4	25.5	28.0	28.7	28.8	28.0	25.2	22.8	18.9	(31)	(32)
(32)			MCDWB	18.3	18.6	19.9	23.7	27.1	30.0	31.3	31.4	30.7	28.0	25.0	20.9	(32)	(33)
(33)		10%	WB	15.4	15.5	17.4	21.4	24.7	27.4	28.1	28.2	27.2	24.3	21.8	17.9	(33)	(34)
(34)			MCDWB	17.2	17.4	18.6	22.7	26.1	29.1	30.5	30.7	29.7	27.1	23.9	20.0	(34)	(35)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.3	6.0	6.2	5.9	5.5	5.8	6.1	6.2	7.0	7.4	7.0	(35)	(36)
(36)			MCDBR	9.0	8.4	7.8	7.6	7.3	6.3	6.8	7.0	7.3	7.8	8.7	8.5	(36)	(37)
(37)			MCWBR	6.7	6.4	6.0	5.8	5.1	4.0	4.3	4.3	4.6	4.9	6.1	6.1	(37)	(38)
(38)		5% WB	MCDWB	8.4	7.7	7.5	7.1	6.8	6.1	6.3	6.7	6.9	7.4	8.0	7.9	(38)	(39)
(39)			MCWBR	6.7	6.3	6.2	5.8	5.2	4.2	4.4	4.7	4.9	5.3	6.2	6.1	(39)	(40)
(40)	Clear-Sky Solar Irradiance	taub	0.556	0.622	0.720	0.718	0.602	0.547	0.522	0.578	0.594	0.584	0.550	0.540	(40)	(41)	
(41)		taud	1.832	1.731	1.573	1.625	1.908	2.070	2.142	1.967	1.899	1.862	1.917	1.893	(41)	(42)	
(42)		Ebn at Noon	687	675	635	651	730	766	785	742	718	697	689	682	(42)	(43)	
(43)		Edh at Noon	188	222	272	263	198	167	155	185	194	192	172	171	(43)	(44)	
(44)	All-Sky Solar Radiation	RadAvg	2.89	3.04	3.54	4.00	4.45	4.92	5.92	5.33	4.84	4.10	3.18	2.86	(44)	(45)	
(45)		RadStd	0.42	0.51	0.45	0.61	0.67	0.55	0.41	0.47	0.42	0.48	0.33	0.35	(45)	(46)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.32	N/A	N/A	+0.42	N/A	+0.20	N/A	N/A	+132	+108

Nomenclature: See separate page