

KAOHSIUNG INTL, Taiwan

WMO: 467400

Lat: 22.577N

Lon: 120.350E

Elev: 26

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	53.8	56.9	43.1	41.1	59.3	46.5	46.8	60.4	16.7	62.9	15.2	65.3	6.6	0	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	92.4	80.3	91.5	80.2	90.3	79.8	82.5	87.9	81.8	87.5	81.3	87.2	12.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	160.6	86.1	80.6	158.8	85.8	79.2	151.8	85.1	46.3	89.2	45.6	88.6	45.1	87.4	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	15.8	13.8	DB	50.1	95.1	3.4	1.4	47.6	96.2	45.6	97.0	43.7	97.8	41.2	98.9	(4)
(5)			WB	45.8	84.3	3.9	1.3	43.0	85.2	40.7	86.0	38.6	86.7	35.7	87.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.0	68.3	69.9	73.7	78.6	82.1	83.8	84.7	83.8	83.2	80.6	76.7	70.7		
	DBStd	6.74	4.48	5.11	4.76	3.74	2.67	2.65	2.20	2.23	2.04	2.58	3.36	4.53		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	51	21	15	5	0	0	0	0	0	0	0	0	10		
	CDD50	10236	567	557	734	858	996	1015	1075	1048	997	949	800	640		
	CDD65	4813	123	152	274	408	531	565	610	583	547	484	351	185		
	CDH74	48909	483	786	1782	3693	5937	6994	7737	7048	6342	4830	2463	814		
	CDH80	17765	49	124	377	1059	2151	3005	3481	2908	2469	1477	555	110		
(14) Wind	WSAvg	6.6	6.2	6.4	6.4	6.5	6.5	7.5	7.9	7.7	6.9	6.0	5.6	6.0		
(15) Precipitation	PrecAvg	70.8	0.6	0.8	0.9	2.7	6.1	15.6	14.6	16.3	9.0	2.4	1.1	0.7		
	PrecMax	108.4	2.2	3.7	3.9	9.5	24.8	38.7	31.6	47.2	30.9	10.9	8.0	6.1		
	PrecMin	37.4	0.0	0.0	0.0	0.0	0.1	1.3	0.2	4.2	2.1	0.0	0.0	0.0		
	PrecStd	19.4	0.6	1.0	1.2	2.8	5.0	10.7	8.4	11.7	6.9	3.0	1.8	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.1	86.2	88.1	90.0	91.7	93.5	93.6	93.1	92.7	90.8	88.1	85.8		
		MCWB	71.0	73.0	75.1	77.0	79.1	80.3	80.4	80.8	80.6	79.1	75.9	72.5		
	2%	DB	80.9	83.8	86.0	88.1	90.0	91.7	92.6	91.5	91.3	89.2	86.3	82.7		
		MCWB	69.5	72.0	74.6	76.7	78.6	80.3	80.4	80.5	80.2	78.6	75.2	70.9		
	5%	DB	78.9	80.9	84.1	86.7	89.4	91.1	91.4	90.0	89.8	87.7	84.6	80.7		
		MCWB	67.9	70.5	73.2	76.1	78.5	80.1	80.4	80.2	79.6	78.1	74.1	69.9		
	10%	DB	76.9	78.9	82.2	85.7	87.9	89.6	89.9	89.5	88.2	86.1	83.1	78.7		
		MCWB	67.1	69.5	71.9	75.6	78.3	79.7	80.1	80.1	79.3	77.0	73.2	69.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.0	75.8	77.6	80.0	81.9	83.0	83.5	83.4	82.7	81.2	78.8	74.7		
		MCDB	80.8	82.1	84.3	86.0	86.8	88.3	89.5	88.8	88.7	87.1	85.6	81.7		
	2%	WB	71.4	74.1	75.9	78.7	80.9	81.9	82.3	81.6	80.0	77.2	72.9	72.9		
		MCDB	79.0	80.6	83.1	85.0	86.7	87.4	88.0	87.6	87.5	85.7	83.4	79.7		
	5%	WB	69.6	72.3	74.7	77.4	79.9	81.4	81.6	81.6	80.8	79.3	76.0	71.7		
		MCDB	76.6	79.3	81.7	84.4	86.0	87.3	87.6	87.1	87.0	84.9	82.1	78.4		
	10%	WB	67.8	70.2	73.3	76.5	79.2	80.7	80.9	80.9	80.0	78.4	74.8	70.1		
		MCDB	74.8	77.5	80.0	83.6	85.3	87.1	87.2	86.6	86.1	84.0	80.9	76.5		
(35) Mean Daily Temperature Range	MDBR		15.5	15.1	14.2	12.3	10.8	10.1	10.7	10.4	11.1	11.3	13.2	14.6		
	5% DB	MCDBR	17.3	16.7	15.8	13.3	12.1	11.8	12.0	11.8	12.4	12.1	14.0	16.1		
		MCWBR	8.4	8.5	7.9	6.1	5.3	5.1	5.3	5.4	5.5	5.3	6.3	7.5		
	5% WB	MCDBR	15.5	15.5	14.2	12.2	10.8	10.2	10.6	10.7	11.3	10.7	12.4	14.1		
(40) Clear-Sky Solar Irradiance	taub		0.509	0.544	0.662	0.645	0.530	0.494	0.496	0.549	0.583	0.591	0.519	0.529		
	taud		2.018	1.947	1.701	1.782	2.122	2.252	2.239	2.061	1.936	1.871	2.057	1.978		
	Ebn at Noon		237	238	216	224	249	256	256	243	232	222	232	224		
	Edh at Noon		50	57	76	72	51	44	45	54	60	61	48	51		
(44) All-Sky Solar Radiation	RadAvg		1096	1284	1407	1546	1633	1712	1806	1606	1568	1443	1173	1038		
	RadStd		109	130	120	149	176	191	154	176	137	84	85	105		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.67	N/A	N/A	N/A	+0.76	+0.99	N/A	N/A	+234	+223
(47) Regional (19 neighbors)		+0.43	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209	+198

Nomenclature: See separate page