

TAINAN, Taiwan

WMO: 467410

Lat: 22.993N

Lon: 120.205E

Elev: 134

StdP: 14.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.7	54.1	40.4	37.2	54.8	43.9	42.5	56.6	22.4	61.1	19.2	61.0	10.4	10	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	92.3	80.7	91.4	80.5	90.5	80.2	82.7	89.0	82.0	88.5	81.4	88.1	9.4	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	162.1	86.7	80.3	157.8	86.5	79.5	154.0	86.2	46.8	89.0	46.0	88.5	45.3	88.3	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	15.7	13.8	DB	48.9	94.7	2.8	1.5	46.9	95.8	45.2	96.7	43.6	97.5	41.6	98.6
			WB	43.7	83.5	2.9	1.1	41.6	84.3	39.9	84.9	38.3	85.6	36.3	86.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	77.1	65.3	66.9	71.3	77.4	81.8	84.2	85.1	84.5	83.9	80.5	75.2	68.2	(6)
(7)		DBStd	8.12	4.64	5.67	5.42	4.64	3.15	2.84	2.35	2.54	2.49	3.09	3.85	4.81	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	138	53	42	14	2	0	0	0	0	0	0	1	26	(9)
(10)		CDD50	9881	475	473	662	821	986	1025	1088	1068	1017	946	756	564	(10)
(11)		CDD65	4542	62	95	210	373	521	575	623	603	567	481	307	125	(11)
(12)		CDH74	45931	132	350	1087	3004	5625	7089	7967	7455	6732	4477	1690	323	(12)
(13)		CDH80	17247	5	34	169	779	1971	3033	3640	3201	2725	1375	291	24	(13)
(14)	Wind	WSAvg	7.2	8.8	8.3	7.5	6.6	6.2	7.0	6.9	6.8	6.4	6.5	7.0	8.2	(14)
(15)	Precipitation	PrecAvg	62.4	0.7	1.1	1.5	2.9	6.4	13.9	12.8	15.7	5.7	1.1	0.6	0.4	(15)
(16)		PrecMax	122.5	4.1	4.3	6.8	11.8	16.4	56.7	40.9	59.4	19.2	6.4	3.4	1.5	(16)
(17)		PrecMin	20.9	0.0	0.0	0.0	0.0	0.0	1.9	1.7	1.1	0.3	0.0	0.0	0.0	(17)
(18)		PrecStd	20.6	0.8	1.3	1.7	2.9	4.7	10.4	8.3	11.1	5.2	1.8	0.8	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.4	83.6	87.1	90.5	91.9	93.2	93.3	93.1	92.6	90.8	87.1	83.0	(19)
(20)			MCWB	69.7	72.8	75.4	78.2	79.5	81.0	80.9	81.2	80.2	79.2	76.6	72.2	(20)
(21)		2%	DB	77.4	80.6	83.7	87.8	90.0	91.7	92.0	91.7	91.0	89.0	85.0	79.8	(21)
(22)			MCWB	67.9	71.1	73.5	76.8	79.0	80.7	80.9	80.9	79.9	78.6	74.8	70.0	(22)
(23)		5%	DB	75.0	78.2	81.8	86.1	88.8	90.6	91.0	90.6	89.9	87.6	83.3	77.5	(23)
(24)			MCWB	66.3	69.3	72.3	76.2	78.6	80.4	80.8	80.6	79.5	77.8	73.9	68.6	(24)
(25)		10%	DB	72.5	75.8	79.8	84.4	87.5	89.5	90.0	89.4	88.7	86.1	81.5	75.3	(25)
(26)			MCWB	64.7	68.0	71.1	75.2	78.1	80.1	80.4	80.2	79.1	76.7	72.8	67.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.7	74.3	76.5	79.8	81.7	83.4	83.6	83.6	82.8	80.7	78.0	73.8	(27)
(28)			MCDWB	77.8	80.9	84.4	87.1	88.7	89.8	89.2	89.7	89.3	88.5	85.3	80.9	(28)
(29)		2%	WB	69.0	72.5	74.9	78.3	80.7	82.3	82.6	82.5	81.6	79.6	76.3	71.3	(29)
(30)			MCDWB	75.5	79.1	81.8	85.4	87.6	88.9	88.9	88.7	88.4	87.2	82.9	77.8	(30)
(31)		5%	WB	67.2	70.6	73.7	77.3	79.9	81.5	81.9	81.7	80.8	78.8	75.2	69.8	(31)
(32)			MCDWB	73.6	77.2	80.4	84.0	86.7	88.2	88.4	88.0	87.6	86.1	81.4	75.8	(32)
(33)		10%	WB	65.5	68.3	72.2	76.3	79.1	80.8	81.2	81.0	80.0	77.8	73.9	68.3	(33)
(34)			MCDWB	71.3	75.3	78.7	82.9	85.7	87.6	88.0	87.4	86.8	84.7	80.1	74.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.4	13.2	13.2	11.7	10.1	8.9	9.1	8.9	9.6	11.3	12.2	12.6	(35)
(36)			MCDBR	15.4	15.1	14.3	12.8	11.3	10.2	10.3	10.6	10.5	11.6	12.8	14.1	(36)
(37)			MCWBR	8.1	8.1	7.6	6.3	5.0	4.7	4.9	5.0	4.7	5.7	6.3	7.2	(37)
(38)		5% WB	MCDBR	14.4	14.3	13.2	11.9	10.1	9.5	9.6	9.8	9.8	10.6	11.4	12.7	(38)
(39)			MCWBR	8.1	8.5	7.6	6.3	5.2	5.1	5.3	5.3	4.9	5.3	5.9	6.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.504	0.548	0.662	0.654	0.542	0.496	0.501	0.555	0.594	0.597	0.523	0.521	(40)	
(41)		taud	2.010	1.921	1.690	1.756	2.077	2.235	2.211	2.035	1.900	1.842	2.025	1.977	(41)	
(42)		Ebn at Noon	237	236	216	221	246	256	254	242	229	220	230	226	(42)	
(43)		Edh at Noon	51	59	77	74	53	45	46	55	62	63	49	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1054	1214	1343	1482	1604	1689	1814	1619	1574	1439	1140	1017	(44)	
(45)		RadStd	118	145	130	163	184	180	143	179	136	93	96	105	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.43	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209	+198

Nomenclature: See separate page