

TAINAN, Taiwan

WMO: 467410

Lat: 22.993N

Lon: 120.205E

Elev: 41

StdP: 100.84

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	12.3	4.7	5.3	12.6	6.6	6.1	13.7	10.0	16.1	8.6	16.1	4.6	10	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.1	33.5	27.0	33.0	27.0	32.5	26.8	28.2	31.7	27.8	31.4	27.5	31.1	4.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.2	30.4	26.8	22.5	30.3	26.4	22.0	30.1	91.1	31.7	89.2	31.4	87.6	31.3	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.0	6.2	DB	9.4	34.8	1.6	0.9	8.3	35.4	7.3	35.9	6.5	36.4	5.3	37.0	(4)
(5)			WB	6.5	28.6	1.6	0.6	5.3	29.1	4.4	29.4	3.5	29.8	2.4	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	18.5	19.4	21.9	25.2	27.7	29.0	29.5	29.1	28.8	27.0	24.0	20.1
	DBStd	4.51	2.58	3.15	3.01	2.58	1.75	1.58	1.31	1.41	1.39	1.71	2.14	2.67
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	77	29	23	8	1	0	0	0	0	0	0	1	14
	CDD10.0	5489	264	263	368	456	548	569	604	593	565	526	420	313
	CDD18.3	2523	34	53	117	207	289	319	346	335	315	267	171	69
	CDH23.3	25517	73	194	604	1669	3125	3938	4426	4142	3740	2487	939	179
CDH26.7	9582	3	19	94	433	1095	1685	2022	1778	1514	764	162	13	
Wind	WSAvg	3.2	3.9	3.7	3.4	3.0	2.8	3.1	3.1	3.0	2.9	2.9	3.1	3.6
Precipitation	PrecAvg	1585	17	27	37	73	163	354	324	399	144	27	15	9
	PrecMax	3112	103	108	173	300	416	1440	1038	1510	488	163	87	38
	PrecMin	531	0	0	0	0	0	49	44	28	8	0	0	0
	PrecStd	522	21	32	42	73	120	264	212	283	131	45	21	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.9	28.7	30.6	32.5	33.3	34.0	34.1	33.9	33.7	32.6	30.6	28.3
		MCWB	20.9	22.7	24.1	25.7	26.4	27.2	27.2	27.3	26.8	26.2	24.8	22.3
	2%	DB	25.2	27.0	28.7	31.0	32.2	33.2	33.3	33.2	32.8	31.6	29.5	26.5
		MCWB	19.9	21.7	23.1	24.9	26.1	27.1	27.2	27.2	26.6	25.9	23.8	21.1
	5%	DB	23.9	25.7	27.7	30.1	31.6	32.5	32.8	32.6	32.2	30.9	28.5	25.3
		MCWB	19.1	20.7	22.4	24.5	25.9	26.9	27.1	27.0	26.4	25.4	23.3	20.3
	10%	DB	22.5	24.3	26.6	29.1	30.8	31.9	32.2	31.9	31.5	30.1	27.5	24.1
		MCWB	18.2	20.0	21.7	24.0	25.6	26.7	26.9	26.8	26.1	24.8	22.7	19.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.6	23.5	24.7	26.6	27.6	28.5	28.7	28.7	28.2	27.1	25.6	23.2
		MCDB	25.5	27.2	29.1	30.6	31.5	32.1	31.8	32.1	31.8	31.4	29.6	27.2
	2%	WB	20.6	22.5	23.8	25.7	27.1	27.9	28.1	28.1	27.6	26.5	24.6	21.9
		MCDB	24.2	26.2	27.7	29.6	30.9	31.6	31.6	31.5	31.3	30.7	28.3	25.4
	5%	WB	19.5	21.4	23.2	25.2	26.6	27.5	27.7	27.6	27.1	26.0	24.0	21.0
		MCDB	23.1	25.1	26.9	28.9	30.4	31.2	31.3	31.1	30.9	30.1	27.5	24.4
	10%	WB	18.6	20.2	22.4	24.6	26.2	27.1	27.3	27.2	26.7	25.5	23.3	20.2
		MCDB	21.8	24.1	25.9	28.3	29.8	30.9	31.1	30.8	30.4	29.3	26.7	23.3
Mean Daily Temperature Range	5% DB	MDBR	7.4	7.3	7.3	6.5	5.6	5.0	5.1	4.9	5.3	6.3	6.8	7.0
		MCDBR	8.6	8.4	7.9	7.1	6.3	5.7	5.7	5.9	5.8	6.5	7.1	7.8
		MCWBR	4.5	4.5	4.2	3.5	2.8	2.6	2.7	2.8	2.6	3.1	3.5	4.0
	5% WB	MCDBR	8.0	7.9	7.3	6.6	5.6	5.3	5.3	5.4	5.5	5.9	6.3	7.0
		MCWBR	4.5	4.7	4.2	3.5	2.9	2.8	2.9	3.0	2.7	3.0	3.3	3.8
Clear-Sky Solar Irradiance	taub	0.504	0.548	0.662	0.654	0.542	0.496	0.501	0.555	0.594	0.597	0.523	0.521	
	taud	2.010	1.921	1.690	1.756	2.077	2.235	2.211	2.035	1.900	1.842	2.025	1.977	
	Ebn at Noon	748	744	680	697	776	806	802	762	722	692	725	712	
	Edh at Noon	160	185	244	232	167	142	145	173	195	198	156	160	
All-Sky Solar Radiation	RadAvg	3.32	3.83	4.23	4.67	5.06	5.32	5.72	5.11	4.96	4.54	3.60	3.21	
	RadStd	0.37	0.46	0.41	0.51	0.58	0.57	0.45	0.56	0.43	0.29	0.30	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.24	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+116	+110

Nomenclature: See separate page