

HENGCHUN AP, Taiwan

WMO: 467520

Lat: 22.041N

Lon: 120.730E

Elev: 14

StdP: 101.16

Time Zone: 8.00 (E08)

Period: 86-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.3	16.2	9.8	7.5	17.1	10.9	8.1	17.5	12.7	20.2	11.4	20.5	4.0	40	0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	33.2	27.6	32.8	27.4	32.1	27.1	28.6	31.8	28.2	31.4	27.8	31.0	4.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.8	30.9	27.2	23.0	30.5	27.0	22.7	30.3	92.5	32.1	90.8	31.8	89.3	31.1	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	9.7	8.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			10.9	29.9	1.1	0.9	10.1	30.5	9.4	31.0	8.8	31.5	8.0	32.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.7	21.2	21.6	23.8	25.9	27.5	28.3	28.8	28.5	28.2	26.7	25.0	22.3
	DBStd	3.23	2.03	2.24	2.37	2.16	1.57	1.46	1.28	1.11	1.33	1.53	1.87	2.08
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	7	3	2	1	0	0	0	0	0	0	0	0	1
	CDD10.0	5722	348	324	428	477	543	550	582	573	545	518	451	381
	CDD18.3	2688	92	93	171	227	285	300	324	315	295	260	201	124
	CDH23.3	25043	240	332	1037	1935	3033	3476	3935	3690	3244	2378	1313	429
	CDH26.7	8297	14	33	226	566	1059	1329	1591	1384	1138	652	262	43
Wind	WSAvg	3.9	4.3	4.3	4.0	3.6	3.1	3.4	3.2	3.2	2.8	4.5	5.1	4.8
Precipitation	PrecAvg	1982	23	24	17	42	161	358	387	478	313	137	32	14
	PrecMax	3440	72	85	94	198	400	1068	914	980	820	549	199	60
	PrecMin	889	2	0	0	0	25	28	124	78	22	2	0	0
	PrecStd	548	18	23	20	43	109	217	221	252	222	163	42	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	29.0	31.5	33.0	33.2	33.9	34.0	33.7	33.7	32.9	32.0	29.3
		MCWB	22.6	23.9	25.1	26.2	26.8	27.8	27.7	28.1	28.3	27.0	26.5	23.9
	2%	DB	26.9	27.8	30.1	31.8	32.3	32.9	33.1	32.8	32.6	31.8	30.2	28.0
		MCWB	21.8	22.9	24.4	25.6	26.4	27.6	27.8	27.8	27.7	26.3	25.2	22.9
	5%	DB	25.8	26.8	29.0	30.8	31.8	32.0	32.2	32.0	31.9	30.9	29.1	26.9
		MCWB	21.2	22.1	23.7	25.4	26.3	27.4	27.4	27.4	27.1	25.9	24.4	22.1
	10%	DB	24.7	25.4	28.0	29.8	31.0	31.2	31.8	31.2	31.1	29.9	28.1	25.9
		MCWB	20.7	21.3	23.3	24.9	26.3	27.2	27.3	27.2	26.8	25.4	23.7	21.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	24.7	25.9	27.1	28.4	29.1	28.9	29.1	28.9	27.7	26.6	25.1
		MCDB	26.5	27.8	30.3	31.1	31.4	31.9	32.2	32.3	32.5	31.4	30.7	28.5
	2%	WB	22.5	23.6	25.0	26.3	27.5	28.3	28.3	28.3	28.1	26.8	25.9	23.5
		MCDB	25.7	26.7	29.3	30.1	30.9	31.3	31.7	31.4	31.7	30.6	29.6	26.8
	5%	WB	21.6	22.5	24.2	25.8	26.9	27.9	28.0	27.9	27.6	26.2	25.1	22.6
		MCDB	24.8	25.6	28.1	29.5	30.5	30.9	31.4	31.0	31.0	29.8	28.4	25.9
	10%	WB	20.9	21.6	23.6	25.3	26.4	27.4	27.6	27.5	27.1	25.7	24.2	21.9
		MCDB	24.1	24.8	27.3	28.9	29.8	30.3	30.8	30.4	30.2	29.0	27.3	25.1
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.8	6.9	6.8	6.5	5.7	5.5	5.7	6.1	6.4	6.3	6.3
		MCDBR	7.6	8.0	8.0	7.8	7.4	6.5	6.4	6.7	6.9	7.4	7.2	7.0
		MCWBR	4.6	5.0	4.7	4.2	3.9	3.6	3.4	3.7	4.0	4.4	4.3	4.3
	5% WB	MCDBR	6.9	7.3	7.8	7.3	6.8	5.8	5.9	6.0	6.5	6.8	6.6	6.5
		MCWBR	4.6	5.1	4.8	4.3	4.2	3.7	3.5	3.8	4.1	4.6	4.2	4.3
Clear-Sky Solar Irradiance	taub	0.500	0.522	0.642	0.623	0.513	0.490	0.493	0.536	0.556	0.546	0.506	0.524	
	taud	2.059	2.024	1.753	1.841	2.192	2.278	2.261	2.112	2.026	2.009	2.111	2.006	
	Ebn at Noon	759	772	697	721	799	811	808	777	755	740	748	717	
	Edh at Noon	153	168	230	213	149	136	138	160	172	168	145	157	
All-Sky Solar Radiation	RadAvg	3.26	3.94	4.45	5.08	5.36	5.68	5.81	5.20	4.97	4.53	3.59	3.02	
	RadStd	0.33	0.44	0.41	0.48	0.54	0.59	0.52	0.53	0.48	0.29	0.28	0.37	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (14 neighbors)	+0.26	N/A	N/A	N/A	+0.25	+0.32	N/A	N/A	+116	+110	

Nomenclature: See separate page