

PINGTUNG NORTH, Taiwan

WMO: 467580

Lat: 22.700N

Lon: 120.482E

Elev: 97

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	52.0	54.8	47.9	49.5	56.6	50.0	53.6	58.0	15.9	75.7	13.6	74.2	0.8	10	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	93.9	81.1	93.2	80.9	91.8	80.4	82.8	91.0	82.0	90.1	81.4	89.3	9.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.3	87.1	80.0	156.1	86.5	79.1	151.6	85.8	46.9	90.8	46.0	91.1	45.3	89.3	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	13.7	11.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			38.8	85.4	6.1	0.9	34.4	86.0	30.8	86.5	27.3	87.0	22.9	87.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	77.2	67.1	68.5	72.7	77.8	81.6	83.4	83.8	82.8	79.9	74.9	69.0	(6)	
(7)		DBStd	7.15	4.24	4.61	5.25	4.00	2.58	2.79	2.45	2.53	2.26	2.64	3.64	4.35	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	72	28	19	9	1	0	0	0	0	0	0	1	14	(9)
(10)		CDD50	9924	530	517	705	835	981	1001	1062	1047	984	926	748	588	(10)
(11)		CDD65	4520	93	116	249	386	516	551	597	582	534	461	299	136	(11)
(12)		CDH74	43722	527	722	1794	3243	5286	6283	7012	6518	5551	4076	1954	756	(12)
(13)		CDH80	16338	65	141	556	1158	2071	2635	3057	2643	2073	1354	481	104	(13)
(14)	Wind	WSAvg	3.1	2.6	2.9	3.0	3.0	3.3	4.1	4.3	4.1	3.4	2.6	2.1	2.1	(14)
(15)	Precipitation	PrecAvg	70.8	0.6	0.8	0.9	2.7	6.1	15.6	14.6	16.3	9.0	2.4	1.1	0.7	(15)
(16)		PrecMax	108.4	2.2	3.7	3.9	9.5	24.8	38.7	31.6	47.2	30.9	10.9	8.0	6.1	(16)
(17)		PrecMin	37.4	0.0	0.0	0.0	0.0	0.1	1.3	0.2	4.2	2.1	0.0	0.0	0.0	(17)
(18)		PrecStd	19.4	0.6	1.0	1.2	2.8	5.0	10.7	8.4	11.7	6.9	3.0	1.8	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.5	86.3	90.0	92.1	93.6	95.3	95.4	94.8	93.4	91.6	88.2	85.7	(19)
(20)			MCWB	72.3	73.6	76.6	78.1	80.2	81.5	81.2	81.5	81.1	79.1	77.0	73.3	(20)
(21)		2%	DB	82.0	84.0	87.9	90.0	91.9	93.5	93.9	93.2	91.7	89.7	86.6	82.7	(21)
(22)			MCWB	70.2	72.0	75.9	77.4	79.6	81.1	81.1	81.5	80.6	78.7	76.0	71.7	(22)
(23)		5%	DB	79.3	81.9	85.9	88.8	91.0	92.6	93.0	91.7	90.9	88.1	84.6	80.6	(23)
(24)			MCWB	68.3	71.0	74.7	77.1	79.2	80.9	81.0	80.9	80.3	78.0	74.8	70.3	(24)
(25)		10%	DB	77.0	78.8	83.6	86.6	89.3	91.1	91.5	90.6	89.4	86.6	82.7	78.6	(25)
(26)			MCWB	67.2	69.0	73.5	76.1	78.5	80.5	80.6	80.6	79.7	77.4	73.8	69.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	75.4	78.4	80.5	82.3	83.8	83.7	83.5	83.0	80.8	78.8	74.9	(27)
(28)			MCD B	82.2	83.7	88.0	89.2	90.4	92.2	92.0	91.6	90.6	88.5	86.2	83.5	(28)
(29)		2%	WB	71.5	73.1	76.5	78.9	80.9	82.5	82.6	82.3	81.7	79.8	77.3	72.8	(29)
(30)			MCD B	79.7	81.4	86.1	87.7	88.9	90.8	91.2	90.5	89.3	87.2	84.8	80.5	(30)
(31)		5%	WB	69.7	71.5	75.2	77.7	80.1	81.5	81.8	81.6	80.9	78.9	76.0	71.4	(31)
(32)			MCD B	77.0	80.2	84.2	86.4	87.8	89.6	90.1	89.3	88.4	86.0	83.0	78.8	(32)
(33)		10%	WB	68.1	69.6	73.9	76.6	79.3	80.7	81.0	80.8	80.0	78.0	74.6	69.9	(33)
(34)			MCD B	74.9	77.7	82.1	84.8	86.8	88.7	89.0	88.1	86.8	84.7	81.0	76.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.3	19.3	18.4	16.0	14.9	14.0	14.3	13.6	13.7	14.9	16.6	19.1	(35)
(36)			MCDBR	21.7	23.0	21.6	18.3	17.3	16.5	16.7	15.4	15.1	16.0	17.7	20.1	(36)
(37)			MCWBR	11.4	12.6	11.2	8.6	7.7	7.2	6.8	6.6	6.6	6.9	8.7	10.4	(37)
(38)		5% WB	MCDBR	19.7	21.3	20.2	17.0	15.5	15.0	14.9	14.4	14.1	15.1	16.7	18.9	(38)
(39)			MCWBR	11.5	12.3	11.2	8.7	7.6	7.5	7.0	6.8	6.7	7.1	8.7	10.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.504	0.542	0.666	0.652	0.541	0.500	0.501	0.559	0.595	0.597	0.516	0.523	(40)	
(41)		taud	2.014	1.940	1.680	1.754	2.077	2.215	2.204	2.013	1.890	1.844	2.048	1.977	(41)	
(42)		Ebn at Noon	238	238	215	222	246	254	254	240	229	220	233	226	(42)	
(43)		Edh at Noon	50	58	78	74	53	46	46	56	62	63	49	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1109	1293	1404	1523	1603	1684	1781	1586	1551	1435	1175	1050	(44)	
(45)		RadStd	106	127	121	152	177	189	150	168	132	81	83	103	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.43	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209	+198

Nomenclature: See separate page