

HENGCHUN, Taiwan

WMO: 467590

Lat: 22.0039N

Lon: 120.7463E

Elev: 79

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	60.9	62.5	48.1	49.8	63.6	50.1	53.9	64.4	41.3	67.3	29.6	67.9	12.8	30	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	90.9	80.6	90.0	80.2	89.2	79.9	82.5	87.8	81.8	87.3	81.2	86.9	8.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.1	162.1	85.3	80.4	158.1	85.2	79.7	154.6	85.0	46.5	87.7	45.7	87.5	45.1	87.2	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.5	21.4	19.0	58.1	92.8	3.1	1.4	55.8	93.7	54.0	94.6	52.2	95.3	50.0	96.3		
(5)			52.5	83.7	2.5	1.7	50.7	84.9	49.2	85.8	47.8	86.8	45.9	88.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.2	70.2	71.6	74.5	78.3	81.5	83.3	83.8	83.2	82.4	80.3	76.9	72.1
	DBStd	5.70	3.69	3.92	4.12	3.57	2.85	2.60	2.14	2.16	2.23	2.41	2.99	3.75
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	11	5	3	1	0	0	0	0	0	0	0	0	2
	CDD50	10299	627	605	759	849	977	999	1048	1030	972	938	808	687
	CDD65	4834	167	188	295	399	512	549	583	565	522	473	358	223
	CDH74	44212	315	584	1516	3159	5353	6511	7097	6649	5801	4396	2213	618
	CDH80	13783	10	44	235	780	1725	2519	2838	2461	1906	964	267	34
Wind	WSAvg	8.3	10.4	9.2	8.6	7.6	6.5	5.9	6.3	6.0	6.9	9.7	11.0	11.2
Precipitation	PrecAvg	78.0	0.9	0.9	0.7	1.7	6.3	14.1	15.2	18.8	12.3	5.4	1.3	0.6
	PrecMax	135.4	2.8	3.3	3.7	7.8	15.7	42.0	36.0	38.6	32.3	21.6	7.8	2.4
	PrecMin	35.0	0.1	0.0	0.0	0.0	1.0	1.1	4.9	3.1	0.9	0.1	0.0	0.0
	PrecStd	21.6	0.7	0.9	0.8	1.7	4.3	8.5	8.7	9.9	8.7	6.4	1.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.4	83.4	86.4	89.7	91.5	91.8	91.8	91.7	90.9	88.9	86.4	83.2
		MCWB	72.4	73.4	75.8	77.2	80.0	81.3	81.0	80.7	79.9	78.6	76.5	73.4
	2%	DB	79.2	81.4	84.4	87.6	89.7	90.6	90.6	90.4	89.3	87.2	84.6	80.7
		MCWB	70.6	72.5	74.8	76.8	79.2	80.9	80.8	80.4	79.1	77.8	75.4	71.7
	5%	DB	77.3	79.6	82.7	86.1	88.3	89.5	89.6	89.3	88.1	85.9	82.9	78.8
		MCWB	69.1	71.3	73.7	76.5	78.8	80.6	80.5	80.1	78.8	76.7	74.2	70.4
	10%	DB	75.6	77.6	80.8	84.5	87.0	88.4	88.6	88.1	87.0	84.5	81.4	77.3
		MCWB	68.0	70.1	72.4	75.7	78.3	80.4	80.3	80.0	78.3	75.8	73.3	69.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.2	75.7	77.4	79.9	82.5	83.7	83.4	83.0	81.8	80.4	78.3	75.3
		MCDB	79.3	80.5	84.1	86.6	88.3	88.5	87.7	87.1	87.8	86.3	83.8	80.6
	2%	WB	71.7	74.2	76.1	78.6	81.2	82.4	82.3	81.9	80.8	79.1	76.9	73.3
		MCDB	77.6	79.3	82.5	85.1	87.0	87.7	87.7	87.0	86.6	85.3	82.8	78.7
	5%	WB	70.2	72.7	74.8	77.5	80.1	81.7	81.6	81.4	80.1	78.1	75.6	71.8
		MCDB	76.2	78.0	80.9	83.9	86.1	87.2	87.3	86.6	85.7	84.3	81.4	77.8
	10%	WB	68.8	71.1	73.6	76.5	79.2	81.0	81.0	80.7	79.3	77.0	74.3	70.4
		MCDB	74.7	76.7	79.7	82.9	85.2	86.7	86.9	86.0	85.0	83.1	80.3	76.4
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.0	9.6	9.9	9.5	8.5	8.5	8.7	8.6	7.7	7.2	7.2
		MCDBR	10.4	11.5	11.6	12.0	11.2	9.8	9.9	10.5	10.1	9.2	9.2	9.1
		MCWBR	5.9	6.2	6.1	5.6	5.2	4.6	4.5	4.9	4.8	4.7	5.0	5.0
	5% WB	MCDBR	10.2	10.5	11.1	11.2	9.9	8.8	8.6	8.7	9.3	8.5	8.8	8.6
		MCWBR	5.9	6.4	6.4	5.7	5.3	4.7	4.4	4.7	4.8	4.6	5.3	5.3
Clear-Sky Solar Irradiance	taub	0.496	0.517	0.636	0.617	0.509	0.487	0.490	0.531	0.550	0.540	0.503	0.520	
	taud	2.072	2.039	1.768	1.856	2.207	2.290	2.273	2.127	2.043	2.028	2.122	2.017	
	Ebn at Noon	242	246	223	230	254	258	257	248	241	237	239	229	
	Edh at Noon	48	53	72	67	47	43	43	50	54	52	45	49	
All-Sky Solar Radiation	RadAvg	1030	1246	1413	1619	1708	1809	1847	1655	1579	1439	1138	954	
	RadStd	106	140	130	154	172	188	166	166	154	92	89	118	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.47	N/A	N/A	N/A	+0.45	+0.58	N/A	N/A	+209	+198

Nomenclature: See separate page