

HENGCHUN, Taiwan

WMO: 467590

Lat: 22.0039N

Lon: 120.7463E

Elev: 24

StdP: 101.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 16.1	(c) 17.0	(d) 8.9	(e) 7.1	(f) 17.6	(g) 10.1	(h) 7.7	(i) 18.0	(j) 18.5	(k) 19.6	(l) 13.2	(m) 19.9	(n) 5.7	(o) 30	(p) 0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 4.7	(c) 32.7	(d) 27.0	(e) 32.2	(f) 26.8	(g) 31.8	(h) 26.6	(i) 28.1	(j) 31.0	(k) 27.7	(l) 30.7	(m) 27.4	(n) 30.5	(o) 3.6	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.3	23.2	29.6	26.9	22.6	29.5	26.5	22.1	29.5	90.3	30.9	88.4	30.8	87.1	30.7	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.9	9.6	8.5	14.5	33.8	1.7	0.8	13.2	34.3	12.2	34.8	11.2	35.2	10.0	35.7		
			11.4	28.7	1.4	0.9	10.4	29.4	9.5	29.9	8.8	30.4	7.7	31.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.7	21.2	22.0	23.6	25.7	27.5	28.5	28.8	28.5	28.0	26.8	25.0	22.3
	DBStd	3.17	2.05	2.18	2.29	1.98	1.58	1.44	1.19	1.20	1.24	1.34	1.66	2.08
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	6	3	2	1	0	0	0	0	0	0	0	0	1
	CDD10.0	5722	348	336	422	472	543	555	582	572	540	521	449	382
	CDD18.3	2686	93	104	164	222	284	305	324	314	290	263	199	124
	CDH23.3	24562	175	324	842	1755	2974	3617	3943	3694	3223	2442	1229	343
CDH26.7	7657	6	24	131	433	958	1399	1577	1367	1059	536	148	19	
Wind	WSAvg	3.7	4.6	4.1	3.9	3.4	2.9	2.7	2.8	2.7	3.1	4.4	4.9	5.0
Precipitation	PrecAvg	1982	23	24	17	42	161	358	387	478	313	137	32	14
	PrecMax	3440	72	85	94	198	400	1068	914	980	820	549	199	60
	PrecMin	889	2	0	0	0	25	28	124	78	22	2	0	0
	PrecStd	548	18	23	20	43	109	217	221	252	222	163	42	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.5	28.6	30.2	32.1	33.1	33.2	33.2	33.1	32.7	31.6	30.2	28.5
		MCWB	22.5	23.0	24.3	25.1	26.7	27.4	27.2	27.1	26.6	25.9	24.7	23.0
	2%	DB	26.2	27.4	29.1	30.9	32.1	32.5	32.5	32.4	31.8	30.7	29.2	27.0
		MCWB	21.4	22.5	23.8	24.9	26.2	27.2	27.1	26.9	26.2	25.4	24.1	22.1
	5%	DB	25.2	26.4	28.2	30.1	31.3	31.9	32.0	31.8	31.2	29.9	28.3	26.0
		MCWB	20.6	21.8	23.2	24.7	26.0	27.0	27.0	26.7	26.0	24.8	23.4	21.4
	10%	DB	24.2	25.3	27.1	29.1	30.6	31.3	31.4	31.2	30.5	29.2	27.4	25.1
		MCWB	20.0	21.2	22.4	24.3	25.7	26.9	26.8	26.6	25.7	24.3	22.9	20.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	24.3	25.2	26.6	28.0	28.7	28.6	28.3	27.7	26.9	25.7	24.1
		MCDB	26.3	27.0	29.0	30.4	31.3	31.4	30.9	30.6	31.0	30.1	28.8	27.0
	2%	WB	22.1	23.5	24.5	25.9	27.3	28.0	27.9	27.7	27.1	26.2	24.9	22.9
		MCDB	25.3	26.3	28.0	29.5	30.6	31.0	30.9	30.6	30.3	29.6	28.2	25.9
	5%	WB	21.2	22.6	23.8	25.3	26.7	27.6	27.6	27.4	26.7	25.6	24.2	22.1
		MCDB	24.5	25.6	27.2	28.8	30.0	30.7	30.7	30.3	29.8	29.1	27.4	25.4
	10%	WB	20.4	21.7	23.1	24.7	26.2	27.2	27.2	27.1	26.3	25.0	23.5	21.3
		MCDB	23.7	24.8	26.5	28.3	29.6	30.4	30.5	30.0	29.4	28.4	26.8	24.7
Mean Daily Temperature Range	5% DB	MDBR	4.5	5.0	5.3	5.5	5.3	4.7	4.7	4.8	4.8	4.3	4.0	4.0
		MCDBR	5.8	6.4	6.4	6.7	6.2	5.5	5.5	5.9	5.6	5.1	5.1	5.0
		MCWBR	3.3	3.4	3.4	3.1	2.9	2.6	2.5	2.7	2.7	2.6	2.8	2.8
	5% WB	MCDBR	5.6	5.8	6.2	6.2	5.5	4.9	4.8	4.8	5.1	4.7	4.9	4.8
		MCWBR	3.3	3.5	3.6	3.2	2.9	2.6	2.4	2.6	2.7	2.6	2.9	3.0
Clear-Sky Solar Irradiance	taub	0.496	0.517	0.636	0.617	0.509	0.487	0.490	0.531	0.550	0.540	0.503	0.520	
	taud	2.072	2.039	1.768	1.856	2.207	2.290	2.273	2.127	2.043	2.028	2.122	2.017	
	Ebn at Noon	763	776	702	726	802	813	811	781	759	746	752	721	
	Edh at Noon	151	166	226	210	147	134	136	158	169	165	143	156	
All-Sky Solar Radiation	RadAvg	3.25	3.93	4.46	5.10	5.38	5.70	5.82	5.22	4.98	4.54	3.59	3.01	
	RadStd	0.33	0.44	0.41	0.49	0.54	0.59	0.52	0.52	0.48	0.29	0.28	0.37	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (14 neighbors)	+0.26	N/A	N/A	N/A	N/A	+0.25	+0.32	N/A	N/A	+116	+110

Nomenclature: See separate page