

CHIHANG AB, Taiwan

WMO: 467600

Lat: 22.793N

Lon: 121.182E

Elev: 121

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	56.9	58.6	46.7	47.3	59.6	49.0	51.7	60.8	28.4	67.6	24.7	68.8	8.5	340	0.350

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	91.5	82.0	90.0	81.2	89.5	81.0	83.5	89.1	82.6	88.4	82.0	87.8	10.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.1	167.9	88.2	80.9	161.1	87.5	80.4	158.4	87.2	47.8	88.8	46.8	89.1	46.1	87.9	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.8	21.4	18.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	48.7	86.3	1.8	1.7	47.4	87.5	46.4	88.5	45.4	89.5	44.1	90.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.5	68.1	68.0	71.4	75.7	79.5	82.4	83.9	83.7	81.6	78.5	74.3	69.8	(6)
	DBStd	6.77	4.04	4.61	4.93	4.30	3.28	2.83	2.15	2.08	2.57	2.80	3.76	3.88	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	59	18	22	10	0	0	0	0	0	0	0	1	8	(9)
	CDD50	9660	561	505	665	772	915	971	1052	1046	949	883	728	613	(10)
	CDD65	4244	114	107	209	323	450	521	587	581	499	418	279	156	(11)
	CDH74	37811	207	270	883	2119	4110	5875	7269	7030	5218	3205	1263	362	(12)
	CDH80	12306	9	16	113	455	1124	2186	3050	2830	1674	675	155	19	(13)
(14) Wind	WSAvg	7.1	8.4	7.9	7.2	6.5	5.7	5.5	5.6	5.6	6.7	9.0	8.9	8.7	(14)
(15) Precipitation	PrecAvg	76.0	1.7	2.0	1.7	3.1	6.0	9.1	11.5	12.9	13.1	8.6	4.2	2.0	(15)
	PrecMax	123.8	6.9	4.5	3.5	8.6	14.8	26.1	24.6	30.6	39.4	42.6	21.7	10.1	(16)
	PrecMin	49.1	0.4	0.2	0.3	0.4	0.6	0.1	0.7	2.1	1.3	0.8	0.0	0.0	(17)
	PrecStd	17.3	1.3	1.2	0.9	2.0	3.7	6.1	6.7	7.7	9.7	10.2	4.6	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.9	82.4	84.6	88.9	89.9	93.1	92.4	93.4	91.0	89.4	85.7	82.3	(19)
		MCWB	73.1	74.7	77.0	79.5	80.6	82.3	82.7	81.7	82.3	80.7	78.3	74.9	(20)
	2%	DB	78.2	79.1	82.8	86.1	88.1	90.8	91.3	91.2	89.5	86.4	83.6	80.0	(21)
		MCWB	70.9	72.4	76.1	78.7	80.0	81.5	82.1	81.8	81.1	78.6	76.2	72.5	(22)
	5%	DB	76.6	77.2	80.9	84.3	86.6	89.5	90.0	89.8	88.0	84.8	82.0	77.4	(23)
		MCWB	69.9	70.9	74.7	77.4	79.2	81.0	81.3	81.1	80.6	77.4	75.1	70.5	(24)
	10%	DB	74.4	75.2	78.9	82.6	85.7	88.0	89.4	88.8	87.1	83.9	80.1	75.6	(25)
		MCWB	68.3	69.5	73.4	76.3	78.6	80.7	81.0	80.8	80.1	76.7	73.6	69.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.1	75.7	78.9	80.8	82.7	84.4	84.6	84.4	83.8	81.9	79.2	75.6	(27)
		MCDB	79.6	80.6	83.3	86.4	87.8	90.0	90.2	89.8	88.7	87.2	84.0	80.5	(28)
	2%	WB	71.9	73.4	77.1	79.2	80.9	82.7	83.4	82.9	82.4	79.8	77.4	73.5	(29)
		MCDB	77.0	78.0	81.9	84.7	86.6	88.4	89.4	88.6	87.5	85.0	82.2	78.8	(30)
	5%	WB	70.2	71.6	75.5	78.2	79.8	81.9	82.5	82.3	81.3	78.7	75.9	71.6	(31)
		MCDB	75.0	76.4	80.0	83.5	85.4	87.7	88.7	88.2	86.7	83.9	80.6	76.5	(32)
	10%	WB	68.9	69.8	74.0	76.9	78.9	81.0	81.7	81.4	80.4	77.5	74.4	69.9	(33)
		MCDB	73.7	74.4	78.3	81.9	84.2	86.8	87.9	87.4	85.9	82.4	79.0	74.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	10.5	10.2	10.7	10.5	10.7	10.6	10.7	10.2	10.0	9.8	10.6	(35)
		MCDBR	12.8	12.9	12.5	12.7	12.1	12.5	11.5	12.0	11.3	11.1	11.3	12.1	(36)
	5% WB	MCWBR	9.3	9.6	9.4	8.6	7.9	7.7	7.7	7.6	7.5	8.0	8.4	9.0	(37)
		MCWBR	11.5	12.2	12.1	12.4	11.7	11.5	11.0	10.7	10.6	10.3	10.3	11.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.487	0.506	0.615	0.605	0.513	0.470	0.463	0.505	0.527	0.514	0.485	0.502	(40)
		taud	2.082	2.070	1.805	1.882	2.181	2.320	2.337	2.195	2.109	2.103	2.165	2.061	(41)
	Ebn at Noon		243	248	227	233	253	262	264	254	246	243	243	233	(42)
		Edh at Noon	47	51	69	65	48	41	41	47	50	49	43	47	(43)
(44) All-Sky Solar Radiation	RadAvg		887	1069	1189	1356	1530	1719	1855	1665	1524	1337	1010	853	(44)
	RadStd		94	137	150	167	197	182	141	169	147	96	89	113	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.43	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209	+198

Nomenclature: See separate page