

CHIHANG AB, Taiwan

WMO: 467600

Lat: 22.793N

Lon: 121.182E

Elev: 37

StdP: 100.88

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.8	14.8	8.2	6.8	15.3	9.5	7.4	16.0	12.7	19.8	11.0	20.5	3.8	340	0.350

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	33.0	27.8	32.2	27.3	32.0	27.2	28.6	31.7	28.1	31.3	27.8	31.0	4.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.8	24.0	31.2	27.2	23.0	30.9	26.9	22.6	30.6	93.3	31.5	90.9	31.7	89.4	31.0	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	9.6	8.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			9.3	30.1	1.0	1.0	8.6	30.8	8.0	31.4	7.4	31.9	6.7	32.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	20.1	20.0	21.9	24.3	26.4	28.0	28.8	28.7	27.6	25.8	23.5	21.0	(6)
	DBStd	3.76	2.24	2.56	2.74	2.39	1.82	1.57	1.20	1.16	1.43	1.55	2.09	2.16	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	33	10	12	6	0	0	0	0	0	0	0	1	4	(9)
	CDD10.0	5367	312	281	369	429	508	539	584	581	527	491	404	341	(10)
	CDD18.3	2358	63	59	116	179	250	289	326	323	277	232	155	87	(11)
	CDH23.3	21006	115	150	491	1177	2283	3264	4038	3906	2899	1781	702	201	(12)
	CDH26.7	6837	5	9	63	253	624	1214	1694	1572	930	375	86	11	(13)
(14) Wind	WSAvg	3.2	3.8	3.5	3.2	2.9	2.6	2.5	2.5	2.5	3.0	4.0	4.0	3.9	(14)
(15) Precipitation	PrecAvg	1931	44	52	43	78	152	231	293	327	333	219	107	51	(15)
	PrecMax	3144	175	114	88	219	376	663	626	776	1000	1081	550	256	(16)
	PrecMin	1248	9	6	7	10	15	2	17	53	34	21	0	1	(17)
	PrecStd	439	33	30	22	51	93	156	171	195	247	260	117	52	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	28.0	29.2	31.6	32.2	34.0	33.6	34.1	32.8	31.9	29.8	27.9	(19)
		MCWB	22.8	23.7	25.0	26.4	27.0	28.0	28.1	27.6	28.0	27.1	25.7	23.8	(20)
	2%	DB	25.7	26.2	28.2	30.1	31.2	32.7	33.0	32.9	32.0	30.2	28.7	26.7	(21)
		MCWB	21.6	22.4	24.5	25.9	26.7	27.5	27.8	27.7	27.3	25.9	24.6	22.5	(22)
	5%	DB	24.8	25.1	27.2	29.1	30.3	32.0	32.2	32.1	31.1	29.3	27.8	25.2	(23)
		MCWB	21.0	21.6	23.7	25.2	26.2	27.2	27.4	27.3	27.0	25.2	23.9	21.4	(24)
	10%	DB	23.5	24.0	26.1	28.1	29.8	31.1	31.9	31.5	30.6	28.8	26.7	24.2	(25)
		MCWB	20.2	20.8	23.0	24.6	25.9	27.0	27.2	27.1	26.7	24.8	23.1	20.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	24.3	26.1	27.1	28.2	29.1	29.2	29.1	28.8	27.7	26.2	24.2	(27)
		MCDB	26.4	27.0	28.5	30.2	31.0	32.2	32.3	32.1	31.5	30.6	28.9	26.9	(28)
	2%	WB	22.2	23.0	25.1	26.2	27.1	28.2	28.5	28.3	28.0	26.6	25.2	23.0	(29)
		MCDB	25.0	25.6	27.7	29.3	30.3	31.4	31.9	31.5	30.8	29.4	27.9	26.0	(30)
	5%	WB	21.2	22.0	24.2	25.6	26.6	27.7	28.1	27.9	27.4	25.9	24.4	22.0	(31)
		MCDB	23.9	24.7	26.7	28.6	29.7	31.0	31.5	31.2	30.4	28.8	27.0	24.7	(32)
	10%	WB	20.5	21.0	23.3	25.0	26.1	27.2	27.6	27.4	26.9	25.3	23.5	21.1	(33)
		MCDB	23.1	23.6	25.7	27.7	29.0	30.4	31.0	30.8	29.9	28.0	26.1	23.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	5.9	5.6	5.9	5.8	5.9	5.9	6.0	5.7	5.6	5.5	5.9	(35)
		MCDBR	7.1	7.1	7.0	7.1	6.7	7.0	6.4	6.7	6.3	6.2	6.3	6.7	(36)
	5% WB	MCWBR	5.2	5.3	5.2	4.8	4.4	4.3	4.3	4.2	4.2	4.4	4.7	5.0	(37)
		MCWBR	6.4	6.8	6.7	6.9	6.5	6.4	6.1	6.1	5.9	5.9	5.7	6.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.487	0.506	0.615	0.605	0.513	0.470	0.463	0.505	0.527	0.514	0.485	0.502	(40)
		taud	2.082	2.070	1.805	1.882	2.181	2.320	2.337	2.195	2.109	2.103	2.165	2.061	(41)
	Ebn at Noon		767	783	716	733	799	827	833	801	777	766	765	734	(42)
		Edh at Noon	149	160	217	204	151	130	128	147	158	153	136	147	(43)
(44) All-Sky Solar Radiation	RadAvg		2.79	3.37	3.75	4.28	4.82	5.42	5.85	5.25	4.80	4.22	3.18	2.69	(44)
	RadStd		0.30	0.43	0.47	0.53	0.62	0.57	0.44	0.53	0.46	0.30	0.28	0.36	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (21 neighbors)		+0.24	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+116	+110	

Nomenclature: See separate page