

LANYU, Taiwan

WMO: 467620

Lat: 22.0369N

Lon: 121.5583E

Elev: 1063

StdP: 14.14

Time Zone: 8.00 (E08)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	56.8	58.2	47.6	50.8	59.5	49.8	55.2	60.8	43.4	63.4	39.1	62.4	18.4	10	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	84.5	78.8	83.5	78.4	82.6	78.0	80.0	82.5	79.4	81.8	78.9	81.3	10.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	158.4	81.3	78.8	155.4	81.0	78.2	152.2	80.5	44.7	82.7	44.0	82.0	43.4	81.4	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	44.5	38.8	34.1	DB	55.3	86.6	1.8	0.9	54.0	87.2	52.9	87.8	51.9	88.2	50.6	88.9
(5)				WB	51.7	81.6	1.8	0.9	50.4	82.3	49.3	82.8	48.3	83.3	47.0	83.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.2	65.0	67.0	68.5	72.0	76.2	78.9	79.6	79.0	78.0	75.2	71.8	67.1	(6)
(7)		DBStd	5.94	3.67	4.26	4.26	3.67	2.82	2.05	1.68	1.71	1.96	2.32	2.88	3.72	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	117	46	27	18	1	0	0	0	0	0	0	1	24	(9)
(10)		CDD50	8479	465	477	575	660	813	867	917	900	841	780	654	530	(10)
(11)		CDD65	3118	46	84	127	211	348	417	452	435	391	315	204	88	(11)
(12)		CDH74	17299	4	38	115	514	1854	3349	3896	3500	2667	1093	251	18	(12)
(13)		CDH80	1312	0	0	0	5	86	296	427	303	173	20	2	0	(13)
(14)	Wind	WSAvg	16.2	16.0	15.1	14.8	15.0	16.6	18.7	17.0	17.1	14.8	16.3	16.5	16.2	(14)
(15)	Precipitation	PrecAvg	115.7	9.8	7.4	5.2	5.4	9.6	10.5	10.0	12.6	14.6	11.5	10.6	8.7	(15)
(16)		PrecMax	164.3	20.0	16.4	11.2	15.0	20.4	22.4	18.7	32.4	39.8	31.0	22.9	25.4	(16)
(17)		PrecMin	70.8	2.7	2.4	1.5	1.0	1.7	0.9	0.8	3.4	3.5	2.1	2.2	3.0	(17)
(18)		PrecStd	18.5	5.1	3.5	2.4	3.3	5.7	5.9	5.0	7.2	7.9	7.9	6.1	4.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.6	77.3	78.2	80.8	84.0	85.3	85.5	85.4	84.6	81.9	79.9	76.1	(19)
(20)		MCWB	70.4	72.3	73.6	75.9	78.0	79.0	79.3	79.2	78.9	77.1	75.4	71.6	(20)	
(21)		2%	DB	72.7	75.2	76.5	79.2	82.0	83.7	84.4	84.0	83.0	80.4	77.8	74.2	(21)
(22)		MCWB	69.0	71.5	72.7	75.2	77.5	78.5	79.0	78.4	77.9	76.0	73.8	70.4	(22)	
(23)		5%	DB	71.0	73.7	75.2	78.0	80.8	82.7	83.3	82.9	81.9	79.2	76.6	72.8	(23)
(24)		MCWB	67.6	70.7	71.9	74.7	76.7	78.1	78.5	78.0	77.3	75.2	73.1	69.3	(24)	
(25)		10%	DB	69.8	72.4	73.8	76.9	79.8	81.8	82.3	81.8	80.9	78.2	75.4	71.6	(25)
(26)		MCWB	66.6	69.5	70.8	74.1	76.2	77.7	78.0	77.7	76.6	74.5	72.3	68.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.0	74.1	75.3	77.3	79.1	80.7	80.9	80.7	79.9	78.9	76.5	73.8	(27)
(28)		MCDWB	73.5	75.4	76.7	78.7	81.5	82.6	83.6	83.3	83.1	80.3	78.4	74.7	(28)	
(29)		2%	WB	70.2	72.5	73.8	76.3	78.2	79.8	80.0	79.8	78.8	77.4	75.2	72.0	(29)
(30)		MCDWB	71.8	74.2	75.6	77.9	80.6	81.9	82.7	82.1	81.6	79.0	76.6	73.1	(30)	
(31)		5%	WB	68.7	71.1	72.5	75.5	77.5	79.1	79.3	79.1	78.1	76.4	74.1	70.4	(31)
(32)		MCDWB	70.4	73.2	74.6	77.4	79.9	81.4	81.8	81.3	80.6	78.2	75.7	72.0	(32)	
(33)		10%	WB	67.3	69.9	71.2	74.6	76.9	78.3	78.7	78.4	77.4	75.4	73.0	69.0	(33)
(34)		MCDWB	69.3	72.0	73.5	76.7	79.3	80.7	81.2	80.6	79.7	77.4	74.8	71.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.5	5.1	5.4	5.4	5.1	4.6	5.0	5.0	5.0	4.5	4.2	4.3	(35)	
(36)		5% DB	MCDBR	5.8	6.5	6.7	6.3	5.9	5.7	6.4	6.4	6.2	5.6	5.5	5.4	(36)
(37)		MCWBR	4.5	4.9	5.0	4.5	4.3	3.8	4.2	4.4	4.3	4.1	4.4	4.4	(37)	
(38)		5% WB	MCDBR	5.3	6.3	6.7	6.1	5.7	5.2	5.6	5.8	5.7	5.0	5.0	5.3	(38)
(39)		MCWBR	4.9	5.1	5.5	4.7	4.5	4.1	4.1	4.4	4.3	4.0	4.4	4.4	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.450	0.461	0.553	0.544	0.463	0.443	0.443	0.469	0.480	0.470	0.466	0.473	(40)	
(41)		taud	2.199	2.201	1.946	2.030	2.342	2.416	2.411	2.318	2.260	2.241	2.223	2.137	(41)	
(42)		Ebn at Noon	257	263	243	248	266	269	270	264	260	257	250	244	(42)	
(43)		Edh at Noon	42	45	60	56	41	37	38	42	43	43	41	44	(43)	
(44)	All-Sky Solar Radiation	RadAvg	887	1122	1274	1528	1691	1863	1918	1736	1585	1389	1017	820	(44)	
(45)		RadStd	99	158	162	169	182	173	154	165	160	101	98	128	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (15 neighbors)	+0.47	N/A	N/A	N/A	+0.45	+0.58	N/A	N/A	+209	+198	

Nomenclature: See separate page