

LANYU, Taiwan

WMO: 467620

Lat: 22.0369N

Lon: 121.5583E

Elev: 324

StdP: 97.49

Time Zone: 8.00 (E08)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	14.5	8.7	7.3	15.3	9.9	7.9	16.0	19.4	17.4	17.5	16.9	8.2	10	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.8	29.1	26.0	28.6	25.8	28.1	25.5	26.7	28.1	26.3	27.7	26.1	27.4	4.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	22.6	27.4	26.0	22.2	27.2	25.6	21.7	27.0	86.0	28.2	84.4	27.8	83.1	27.4	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.9	17.4	15.2	13.0	30.3	1.0	0.5	12.2	30.7	11.6	31.0	11.1	31.2	10.3	31.6		
			10.9	27.6	1.0	0.5	10.2	27.9	9.6	28.2	9.1	28.5	8.3	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	18.3	19.5	20.3	22.2	24.6	26.1	26.4	26.1	25.6	24.0	22.1	19.5	(6)
(7)		DBStd	3.30	2.04	2.36	2.37	2.04	1.57	1.14	0.93	0.95	1.09	1.29	1.60	2.07	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	65	26	15	10	1	0	0	0	0	0	0	1	13	(9)
(10)		CDD10.0	4711	258	265	319	367	452	482	509	500	467	433	363	294	(10)
(11)		CDD18.3	1732	26	47	71	117	193	232	251	242	217	175	113	49	(11)
(12)		CDH23.3	9611	2	21	64	286	1030	1861	2164	1944	1482	607	139	10	(12)
(13)	CDH26.7	729	0	0	0	3	48	164	237	168	96	11	1	0	(13)	
(14)	Wind	WSAvg	7.2	7.2	6.8	6.6	6.7	7.4	8.3	7.6	7.6	6.6	7.3	7.4	7.3	(14)
(15)	Precipitation	PrecAvg	2940	248	188	131	136	243	266	254	319	372	292	269	222	(15)
(16)		PrecMax	4172	508	416	284	380	517	570	476	823	1012	787	581	646	(16)
(17)		PrecMin	1799	68	60	38	25	43	24	20	86	89	53	55	75	(17)
(18)		PrecStd	470	130	88	61	83	144	150	128	182	201	200	155	116	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.7	25.2	25.6	27.1	28.9	29.6	29.7	29.7	29.2	27.7	26.6	24.5	(19)
(20)		MCWB	21.3	22.4	23.1	24.4	25.6	26.1	26.3	26.2	26.0	25.0	24.1	22.0	(20)	
(21)		2%	DB	22.6	24.0	24.7	26.2	27.8	28.7	29.1	28.9	28.3	26.9	25.5	23.4	(21)
(22)		MCWB	20.6	22.0	22.6	24.0	25.3	25.8	26.1	25.8	25.5	24.4	23.2	21.3	(22)	
(23)		5%	DB	21.7	23.2	24.0	25.5	27.1	28.2	28.5	28.3	27.7	26.2	24.8	22.6	(23)
(24)		MCWB	19.8	21.5	22.2	23.7	24.8	25.6	25.8	25.6	25.1	24.0	22.8	20.7	(24)	
(25)		10%	DB	21.0	22.4	23.2	24.9	26.5	27.7	28.0	27.7	27.1	25.7	24.1	22.0	(25)
(26)		MCWB	19.2	20.8	21.5	23.4	24.5	25.4	25.5	25.4	24.8	23.6	22.4	20.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	23.4	24.1	25.2	26.2	27.0	27.2	27.1	26.6	26.0	24.7	23.2	(27)
(28)		MDCB	23.0	24.1	24.9	25.9	27.5	28.1	28.7	28.5	28.4	26.8	25.8	23.7	(28)	
(29)		2%	WB	21.2	22.5	23.2	24.6	25.7	26.5	26.7	26.5	26.0	25.2	24.0	22.2	(29)
(30)		MDCB	22.1	23.4	24.2	25.5	27.0	27.7	28.2	27.8	27.5	26.1	24.8	22.9	(30)	
(31)		5%	WB	20.4	21.7	22.5	24.2	25.3	26.1	26.3	26.2	25.6	24.7	23.4	21.3	(31)
(32)		MDCB	21.3	22.9	23.6	25.2	26.6	27.4	27.7	27.4	27.0	25.7	24.3	22.2	(32)	
(33)		10%	WB	19.6	21.1	21.8	23.6	24.9	25.7	26.0	25.8	25.2	24.1	22.8	20.5	(33)
(34)		MDCB	20.7	22.2	23.0	24.8	26.3	27.1	27.3	27.0	26.5	25.2	23.8	21.7	(34)	
(35)	Mean Daily Temperature Range		MDBR	2.5	2.8	3.0	3.0	2.9	2.6	2.8	2.8	2.5	2.3	2.4	(35)	
(36)		5% DB	MCDBR	3.2	3.6	3.7	3.5	3.3	3.2	3.5	3.4	3.1	3.1	3.0	(36)	
(37)		MCWBR	2.5	2.7	2.8	2.5	2.4	2.1	2.3	2.4	2.4	2.3	2.4	2.5	(37)	
(38)		5% WB	MCDBR	2.9	3.5	3.7	3.4	3.2	2.9	3.1	3.2	3.2	2.8	2.8	2.9	(38)
(39)		MCWBR	2.7	2.8	3.0	2.6	2.5	2.3	2.3	2.5	2.4	2.2	2.5	2.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.450	0.461	0.553	0.544	0.463	0.443	0.443	0.469	0.480	0.470	0.466	0.473	(40)	
(41)		taud	2.199	2.201	1.946	2.030	2.342	2.416	2.411	2.318	2.260	2.241	2.223	2.137	(41)	
(42)		Ebn at Noon	809	829	767	781	840	849	850	832	819	809	788	768	(42)	
(43)		Edh at Noon	133	141	189	176	128	118	119	131	136	134	129	138	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.80	3.54	4.01	4.82	5.33	5.87	6.05	5.47	5.00	4.38	3.21	2.58	(44)	
(45)		RadStd	0.31	0.50	0.51	0.53	0.57	0.55	0.48	0.52	0.50	0.32	0.31	0.41	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.26	N/A	N/A	N/A	+0.25	+0.32	N/A	N/A	+116	+110

Nomenclature: See separate page