

TAICHUNG WUQI, Taiwan

WMO: 467770

Lat: 24.2561N

Lon: 120.5233E

Elev: 104

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	50.6	52.5	40.0	36.5	53.3	42.4	40.1	54.8	36.3	57.5	34.1	59.4	17.4	30	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	91.1	81.2	90.2	80.9	89.3	80.6	82.5	89.4	81.8	88.8	81.2	88.2	13.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.6	88.1	79.8	155.0	87.6	79.1	151.5	87.2	46.4	89.4	45.7	89.0	45.1	88.6	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.6	28.5	25.8	DB	47.7	95.6	1.8	4.0	46.4	98.5	45.3	100.9	44.3	103.1	43.0	106.1
			WB	42.9	83.7	2.4	0.7	41.2	84.3	39.7	84.7	38.4	85.1	36.6	85.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.8	61.6	61.4	65.9	72.4	77.9	82.3	84.6	84.2	81.3	76.3	71.4	66.0	(6)
(7)		DBStd	9.13	3.92	4.56	5.52	5.99	4.24	3.53	2.09	2.01	3.11	3.23	3.76	4.24	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	347	117	119	57	13	1	0	0	0	0	0	4	36	(9)
(10)		CDD50	8704	360	319	492	673	864	969	1073	1060	940	815	642	497	(10)
(11)		CDD65	3574	12	18	83	235	400	519	608	595	490	350	196	68	(11)
(12)		CDH74	34581	11	37	263	1431	3440	5988	7832	7509	5228	2164	623	55	(12)
(13)		CDH80	12029	0	1	26	211	830	2240	3492	3158	1702	333	32	4	(13)
(14)	Wind	WSAvg	11.7	15.5	14.3	12.2	10.3	8.5	8.2	8.4	10.3	14.9	13.7	15.4	(14)	
(15)	Precipitation	PrecAvg	59.3	1.3	3.3	3.8	5.7	7.7	10.6	8.6	9.4	5.7	1.2	1.0	1.2	(15)
(16)		PrecMax	88.4	4.2	13.3	8.1	20.4	18.9	26.3	22.9	23.4	28.4	9.1	6.6	3.3	(16)
(17)		PrecMin	27.4	0.1	0.1	1.2	0.2	0.9	0.9	1.4	1.0	0.5	0.0	0.0	0.0	(17)
(18)		PrecStd	16.5	0.9	3.2	2.1	4.5	4.9	6.3	5.9	6.4	7.3	2.0	1.5	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.7	78.4	82.9	86.6	89.2	92.1	92.7	92.1	90.3	86.3	82.6	78.3	(19)
(20)		MCWB	67.5	70.0	72.7	76.9	79.4	81.4	81.4	81.3	80.4	78.3	74.7	70.7	(20)	
(21)		2%	DB	71.6	74.5	79.6	84.4	87.4	90.5	91.1	90.9	88.9	84.6	80.8	75.1	(21)
(22)		MCWB	65.3	67.5	71.6	76.3	79.0	80.9	81.4	81.3	79.9	76.9	73.3	69.6	(22)	
(23)		5%	DB	69.3	71.5	76.8	82.6	85.9	89.1	90.1	89.9	87.9	83.3	79.1	73.2	(23)
(24)		MCWB	63.7	65.9	70.0	75.1	78.3	80.6	81.1	80.9	79.4	75.6	72.0	67.7	(24)	
(25)		10%	DB	67.3	68.5	74.4	80.7	84.3	88.0	89.2	88.9	86.7	81.9	77.6	71.7	(25)
(26)		MCWB	62.2	63.3	68.7	74.2	77.2	80.2	80.8	80.5	78.6	74.3	70.8	66.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.9	71.1	74.1	78.1	80.9	83.0	83.1	83.3	81.7	79.6	76.1	72.2	(27)
(28)		MCDWB	74.0	76.4	81.1	84.8	87.2	89.9	90.0	89.9	88.6	85.2	81.1	76.8	(28)	
(29)		2%	WB	65.8	68.7	72.2	76.8	79.7	81.9	82.4	82.4	80.7	77.9	74.4	70.2	(29)
(30)		MCDWB	70.7	74.0	78.6	83.3	86.2	88.8	89.3	89.3	87.7	83.3	79.6	74.1	(30)	
(31)		5%	WB	64.5	66.0	70.6	75.7	78.7	81.1	81.8	81.7	80.0	76.6	73.2	68.4	(31)
(32)		MCDWB	68.9	70.8	76.5	81.9	85.1	88.2	88.8	88.6	86.8	82.2	78.4	72.2	(32)	
(33)		10%	WB	62.8	63.9	68.9	74.5	77.7	80.3	81.2	81.0	79.2	75.4	71.8	67.1	(33)
(34)		MCDWB	66.8	68.2	74.1	80.4	83.7	87.3	88.4	87.9	85.9	81.1	76.7	71.0	(34)	
(35)	Mean Daily Temperature Range		MDBR	9.6	9.0	9.8	9.4	8.9	8.6	9.0	8.7	9.8	9.8	10.3	9.6	(35)
(36)		5% DB	MCDBR	12.0	13.8	13.8	10.4	9.9	9.9	9.9	10.0	10.0	10.5	11.8	11.2	(36)
(37)		MCWBR	8.5	9.3	8.1	6.7	6.8	6.4	6.0	6.1	6.2	6.9	8.0	7.8	(37)	
(38)		5% WB	MCDBR	11.7	12.2	11.7	10.0	9.5	9.4	9.2	9.2	9.5	9.3	10.8	10.4	(38)
(39)		MCWBR	8.5	9.0	7.9	7.1	6.9	6.5	5.8	6.0	6.2	6.6	7.7	7.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.508	0.566	0.684	0.692	0.588	0.537	0.550	0.583	0.576	0.542	0.514	0.508	(40)	
(41)		taud	1.970	1.853	1.628	1.663	1.937	2.095	2.050	1.950	1.943	1.981	2.036	1.987	(41)	
(42)		Ebn at Noon	233	229	209	212	235	245	242	234	233	233	230	227	(42)	
(43)		Edh at Noon	52	62	82	81	61	52	54	60	59	54	49	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	926	1018	1184	1307	1508	1653	1880	1704	1570	1388	1036	919	(44)	
(45)		RadStd	129	148	129	175	226	178	116	164	148	116	98	110	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (28 neighbors)	+0.45	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	+229	+202

Nomenclature: See separate page