

SAMJIYON, Korea, Democratic People's Republic of

WMO: 470050

Lat: 41.817N

Lon: 128.300E

Elev: 1381

StdP: 85.80

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -29.6	(c) -27.3	(d) -31.7	(e) 0.2	(f) -28.8	(g) -29.6	(h) 0.3	(i) -26.6	(j) 6.5	(k) -16.1	(l) 5.5	(m) -16.6	(n) 1.2	(o) 180	(p) 0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	25.2	18.1	23.7	17.3	22.2	16.6	19.8	23.4	18.9	21.9	18.1	20.6	1.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	16.0	21.4	17.9	15.3	20.5	17.2	14.6	19.8	63.4	23.5	60.3	22.1	57.4	20.6	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.8	4.9	4.1	-33.7	28.5	2.9	1.1	-35.8	29.3	-37.4	29.9	-39.1	30.6	-41.1	31.3
			-34.0	21.7	2.8	1.7	-36.0	22.9	-37.7	23.9	-39.2	24.9	-41.3	26.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-16.9	-14.4	-7.9	1.3	8.8	13.5	17.2	16.2	10.2	3.3	-6.9	-14.5
	DBStd	12.89	4.93	5.46	5.61	5.22	4.13	2.98	2.50	3.13	3.64	4.55	6.15	5.51
	HDD10.0	3932	833	683	556	263	72	6	0	2	42	209	506	760
	HDD18.3	6391	1092	916	814	511	296	147	51	80	244	465	756	1018
	CDD10.0	613	0	0	0	2	35	110	224	193	47	2	0	0
	CDD18.3	31	0	0	0	0	1	1	17	13	0	0	0	0
	CDH23.3	174	0	0	0	0	10	19	86	57	1	0	0	0
	CDH26.7	15	0	0	0	0	0	0	8	7	0	0	0	0
Wind	WSAvg	1.5	1.5	1.5	1.6	1.7	1.7	1.2	1.3	1.3	1.4	1.5	1.7	1.7
Precipitation	PrecAvg	1012	15	19	31	56	98	151	250	188	96	46	47	24
	PrecMax	1407	56	71	59	104	194	282	428	317	244	83	132	47
	PrecMin	714	4	4	12	20	35	52	87	62	28	11	15	5
	PrecStd	150	11	16	13	20	36	58	86	66	49	20	25	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.2	2.0	10.0	19.5	24.4	25.4	27.8	27.5	22.5	19.0	9.0	1.4
		MCWB	-4.4	-1.0	3.5	9.8	13.9	16.5	19.7	20.0	15.0	10.1	3.1	-1.3
	2%	DB	-5.1	-1.1	5.8	15.3	21.6	23.6	25.5	24.8	20.6	15.7	5.8	-2.0
		MCWB	-6.6	-3.6	1.1	7.4	12.1	15.4	18.9	18.7	13.9	8.8	2.4	-3.5
	5%	DB	-6.8	-3.3	3.1	12.5	19.2	21.9	23.9	23.0	18.8	13.1	3.6	-4.2
		MCWB	-8.1	-5.3	-0.5	5.8	11.1	14.8	18.0	18.1	13.3	7.2	0.8	-5.6
	10%	DB	-8.8	-5.4	1.0	9.8	16.8	20.1	22.4	21.4	17.1	10.8	1.6	-6.2
		MCWB	-9.9	-7.0	-1.7	4.2	9.8	14.3	17.7	17.3	12.2	5.9	-0.2	-7.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.2	0.3	4.3	10.6	15.1	18.2	21.2	21.0	17.0	11.0	4.7	-0.8
		MCDB	-2.7	1.7	9.3	17.5	20.7	23.0	25.3	25.0	20.2	16.7	7.5	0.8
	2%	WB	-6.4	-3.4	1.5	7.9	13.4	16.7	20.1	19.7	15.5	9.5	2.8	-3.4
		MCDB	-5.2	-1.4	4.8	14.4	19.6	21.2	23.9	23.2	18.6	14.8	5.3	-2.1
	5%	WB	-8.1	-5.3	-0.1	6.3	11.9	15.8	19.2	19.0	14.3	8.0	1.2	-5.5
		MCDB	-6.9	-3.4	2.6	11.7	17.7	20.1	22.5	21.8	17.4	12.1	3.2	-4.4
	10%	WB	-9.9	-7.0	-1.6	4.7	10.6	14.9	18.5	18.2	13.1	6.6	-0.2	-7.2
		MCDB	-8.9	-5.4	1.1	9.1	15.5	18.8	21.1	20.4	15.8	9.9	1.5	-6.2
Mean Daily Temperature Range		MDBR	11.2	11.9	11.5	10.6	11.3	10.7	8.7	9.1	11.6	11.7	9.8	10.1
	5% DB	MCDBR	12.4	12.7	13.0	14.5	15.7	14.6	12.1	11.4	13.9	15.1	11.1	10.6
		MCWBR	10.9	10.4	9.4	8.6	8.3	7.9	6.3	6.0	8.0	8.8	7.8	9.1
	5% WB	MCDBR	12.0	11.9	11.7	13.5	14.0	11.9	9.5	8.9	10.9	13.7	10.0	10.4
		MCWBR	10.7	9.9	8.8	8.8	8.2	7.2	5.6	5.2	6.9	8.5	7.4	9.2
Clear-Sky Solar Irradiance	taub	0.287	0.338	0.402	0.468	0.501	0.510	0.463	0.420	0.376	0.377	0.332	0.293	
	taud	2.147	2.016	1.910	1.862	1.854	1.906	2.125	2.248	2.303	2.166	2.166	2.151	
	Ebn at Noon	843	843	828	801	785	779	814	840	854	794	777	796	
	Edh at Noon	100	136	172	194	201	191	152	131	115	116	99	92	
All-Sky Solar Radiation	RadAvg	2.46	3.45	4.45	4.79	5.20	5.07	4.72	4.61	4.27	3.29	2.24	2.00	
	RadStd	0.14	0.16	0.26	0.31	0.46	0.50	0.48	0.40	0.39	0.29	0.23	0.10	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page