

KANGGYE, Korea, Democratic People's Republic of

WMO: 470200

Lat: 40.967N

Lon: 126.600E

Elev: 1004

StdP: 14.17

Time Zone: 9.00 (E09)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.7	-6.3	-13.8	2.7	-8.7	-10.3	3.3	-5.2	11.1	19.4	9.2	18.4	0.0	270	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	89.1	75.2	86.5	73.7	84.0	72.6	77.9	85.9	76.1	83.8	74.4	81.5	2.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.5	138.5	83.6	73.7	130.1	81.1	72.1	123.4	79.2	42.2	85.8	40.4	84.3	38.8	81.7	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	8.8	7.0	-15.2	93.3	3.9	3.0	-18.0	95.4	-20.3	97.2	-22.5	98.8	-25.4	101.0		
(5)			-15.5	81.2	3.9	3.1	-18.2	83.5	-20.5	85.3	-22.7	87.0	-25.5	89.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	10.3	18.9	33.7	48.6	60.6	69.4	75.0	73.7	63.0	49.1	32.2	16.0	(6)
(7)		DBStd	23.38	8.30	9.19	7.80	7.71	6.07	4.85	3.99	4.58	5.78	7.24	9.46	8.82	(7)
(8)		HDD50	4422	1232	870	505	115	4	0	0	0	1	104	536	1055	(8)
(9)		HDD65	7731	1697	1290	969	493	161	16	0	3	104	493	985	1520	(9)
(10)		CDD50	2969	0	0	1	73	332	583	776	736	391	76	1	0	(10)
(11)		CDD65	803	0	0	0	2	24	148	311	274	44	0	0	0	(11)
(12)		CDH74	5879	0	0	0	36	383	1172	2195	1842	245	6	0	0	(12)
(13)		CDH80	1720	0	0	0	2	80	348	707	557	26	0	0	0	(13)
(14)	Wind	WSAvg	1.1	0.6	1.0	1.5	1.9	1.8	1.2	1.0	0.8	0.9	1.0	1.0	0.6	(14)
(15)	Precipitation	PrecAvg	33.3	0.4	0.5	0.9	1.9	3.0	5.0	9.4	6.8	2.8	1.7	1.4	0.6	(15)
(16)		PrecMax	50.2	1.4	2.1	2.2	4.0	7.9	11.4	21.4	14.9	8.9	3.2	4.1	1.7	(16)
(17)		PrecMin	23.7	0.0	0.1	0.0	0.3	0.8	1.4	4.4	2.7	0.2	0.0	0.2	0.2	(17)
(18)		PrecStd	7.5	0.3	0.5	0.6	0.9	1.6	2.6	4.3	2.8	2.0	0.9	0.8	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.6	46.6	61.7	78.8	86.3	90.7	93.9	92.6	83.2	74.4	58.0	42.5	(19)
MCWB			32.9	40.2	49.5	61.6	66.7	72.3	76.8	78.9	70.2	61.7	49.4	38.7	(20)	
2%		DB	31.5	40.9	55.3	73.0	82.0	87.1	89.5	88.4	79.7	69.3	53.0	36.4	(21)	
		MCWB	28.3	35.4	45.1	57.1	64.6	70.9	76.2	76.5	67.9	57.8	46.0	33.5	(22)	
5%		DB	27.5	36.9	50.8	68.7	78.3	84.0	86.6	85.5	76.8	65.5	49.2	32.7	(23)	
		MCWB	24.9	32.6	41.9	54.6	62.8	69.9	75.1	74.9	65.9	55.2	44.1	30.4	(24)	
10%		DB	24.1	33.7	46.9	64.3	74.7	80.9	83.9	83.0	73.9	61.8	45.6	29.6	(25)	
		MCWB	21.8	30.2	39.8	52.0	60.8	68.5	74.1	73.2	64.3	53.0	41.6	27.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.3	40.6	50.6	64.3	70.3	75.6	80.4	80.9	72.9	63.2	50.8	38.8	(27)
MCD B			35.9	45.4	59.4	76.1	83.0	85.8	89.3	89.3	80.3	72.2	57.5	41.6	(28)	
2%		WB	28.7	36.1	45.8	59.1	66.7	73.3	78.1	78.1	70.0	59.3	47.2	33.6	(29)	
		MCD B	31.3	39.8	53.9	70.2	78.3	84.0	86.5	85.7	77.0	66.9	51.7	35.7	(30)	
5%		WB	25.1	33.0	42.8	55.5	64.3	71.5	76.5	76.2	67.8	56.6	44.7	30.4	(31)	
		MCD B	27.4	36.6	49.9	66.7	75.7	81.3	84.5	83.7	74.2	63.8	48.8	32.4	(32)	
10%		WB	21.9	30.3	40.0	52.5	62.1	69.7	75.0	74.4	65.8	53.9	41.5	27.5	(33)	
		MCD B	24.1	33.7	46.5	62.4	72.0	78.7	82.1	81.2	72.1	60.3	45.2	29.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	20.6	21.2	19.1	21.8	22.4	19.5	15.4	16.2	19.7	21.3	16.3	17.8	(35)
MCDBR			21.0	21.3	25.0	30.5	30.1	25.8	20.7	19.9	22.3	26.9	21.3	17.6	(36)	
MCWBR			18.2	16.6	16.2	17.2	15.3	12.8	10.6	10.4	12.0	15.6	15.0	15.2	(37)	
5% WB		MCDBR	20.5	19.5	23.1	27.3	26.2	22.0	17.4	17.5	19.1	23.8	19.4	17.2	(38)	
		MCWBR	18.0	15.6	16.0	16.8	14.7	12.3	10.5	10.4	11.7	15.2	14.5	15.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.385	0.468	0.552	0.627	0.661	0.706	0.640	0.561	0.495	0.522	0.454	0.396	(40)	
taud		1.913	1.753	1.651	1.585	1.569	1.553	1.733	1.906	1.990	1.825	1.887	1.932	(41)		
Ebn at Noon		225	221	218	213	211	202	214	228	234	203	198	208	(42)		
Edh at Noon		42	58	72	82	85	87	72	59	50	53	43	38	(43)		
(44)	All-Sky Solar Radiation	RadAvg	792	1072	1385	1525	1714	1615	1414	1430	1370	1051	689	639	(44)	
(45)		RadStd	42	69	82	114	146	169	166	156	128	80	83	43	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+1.35	+1.42	N/A	N/A	+130	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page