

HAIKOU MEILAN INTL, China

WMO: 470311

Lat: 19.935N

Lon: 110.459E

Elev: 75

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.7	52.0	42.4	40.0	56.6	44.8	44.0	56.8	18.9	65.1	18.0	65.4	5.1	350	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	14.4	96.4	80.4	94.8	80.3	93.2	80.3	83.0	89.9	82.4	88.8	81.8	88.1	7.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	161.7	85.2	80.8	160.5	85.1	80.5	158.6	84.9	47.1	89.8	46.2	90.4	45.4	89.7	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	16.9	14.4	DB	45.2	99.0	3.3	2.7	42.8	100.9	40.9	102.4	39.0	103.9	36.6	105.8
			WB	43.7	84.9	2.9	1.6	41.7	86.0	40.0	87.0	38.4	87.9	36.3	89.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.6	64.0	67.7	73.0	78.6	82.9	84.6	84.4	83.3	81.8	78.1	73.6	67.1	
	DBStd	8.51	5.97	8.02	7.00	5.41	3.60	2.89	2.75	2.43	2.61	2.94	4.65	5.46	
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	219	92	61	19	0	0	0	0	0	0	0	5	42	
	CDD50	9719	436	496	712	859	1020	1039	1066	1031	953	870	708	529	
	CDD65	4463	62	138	265	410	555	589	601	566	503	405	263	106	
	CDH74	40688	142	672	1628	3344	5631	6694	6774	5991	4976	3193	1356	287	
	CDH80	15500	20	187	506	1232	2292	2965	2935	2390	1790	872	282	29	
Wind	WSAvg	6.9	7.9	7.4	7.4	7.1	6.1	5.4	5.7	5.3	6.2	7.8	8.0	8.6	
Precipitation	PrecAvg	77.6	1.1	1.6	2.1	3.7	8.1	8.0	8.5	11.1	13.0	13.8	4.0	2.6	
	PrecMax	106.4	5.8	7.0	9.3	12.5	17.2	17.5	17.0	21.1	31.5	56.3	8.5	7.7	
	PrecMin	47.4	0.0	0.2	0.2	0.6	4.0	3.3	4.0	2.7	4.0	0.7	0.2	0.2	
	PrecStd	14.4	1.1	1.5	1.8	2.6	2.9	3.4	3.2	4.0	6.5	11.5	2.4	1.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.6	91.0	91.8	96.4	96.9	98.5	98.5	96.7	93.6	89.8	89.2	82.7	
		MCWB	72.8	73.7	77.0	79.5	80.7	80.2	78.7	79.3	79.9	78.1	77.5	73.2	
	2%	DB	77.2	84.6	89.2	93.1	94.8	95.4	95.3	93.5	91.7	87.9	86.0	80.3	
		MCWB	70.1	73.4	76.7	79.3	80.4	80.9	80.4	80.6	79.9	77.2	75.9	72.1	
	5%	DB	75.0	82.0	85.7	89.9	93.0	93.6	93.4	91.7	89.9	86.2	83.8	77.1	
		MCWB	68.9	72.6	75.2	78.2	80.2	80.9	80.5	80.3	79.5	76.0	75.1	70.5	
	10%	DB	71.8	77.3	82.5	87.5	91.0	91.7	91.5	89.8	88.1	84.5	80.7	75.0	
		MCWB	67.8	71.1	74.0	77.7	79.5	80.5	79.8	80.0	79.2	75.6	73.6	69.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.2	75.7	79.0	81.9	83.5	84.3	83.6	83.8	82.9	80.8	79.2	76.1
			MCDB	79.7	84.8	87.8	91.1	90.8	92.3	91.4	90.6	88.7	85.0	84.5	79.9
		2%	WB	71.3	74.4	77.6	80.2	82.3	82.9	82.6	82.6	81.7	79.6	77.7	74.0
			MCDB	75.5	81.7	85.8	88.3	89.2	90.0	89.2	88.4	87.3	84.1	83.0	77.7
5%		WB	70.1	73.1	76.1	79.2	81.3	82.2	81.8	81.8	80.9	78.7	76.4	72.0	
		MCDB	73.3	79.2	82.9	86.6	88.2	88.9	88.2	87.5	86.5	83.2	81.2	75.3	
10%		WB	68.9	72.1	74.9	78.3	80.5	81.4	81.0	80.9	80.1	77.8	75.2	70.7	
		MCDB	71.6	77.1	80.3	85.0	87.2	88.0	87.4	86.8	85.4	82.3	78.9	73.6	
Mean Daily Temperature Range	5% DB	MDBR	10.7	11.9	12.7	13.2	14.5	14.4	14.0	13.6	12.8	12.7	11.8	10.8	
		MCDBR	14.6	16.8	16.7	16.9	17.2	16.8	16.7	16.5	15.5	15.5	15.9	15.3	
		MCWBR	7.7	6.6	6.7	6.1	6.5	6.3	6.1	6.7	6.3	6.7	7.2	7.9	
		MCDDBR	12.0	15.2	15.6	15.7	15.9	14.9	14.3	14.1	13.7	12.3	13.4	12.1	
	5% WB	MCWBR	6.8	6.8	7.1	6.6	6.9	6.3	6.0	6.6	6.3	6.2	6.7	7.2	
Clear-Sky Solar Irradiance	taub		0.574	0.591	0.706	0.672	0.514	0.486	0.469	0.517	0.570	0.642	0.579	0.594	
	taud		1.820	1.822	1.622	1.740	2.189	2.288	2.326	2.166	1.981	1.760	1.870	1.798	
	Ebn at Noon		222	228	208	218	253	258	263	252	237	213	219	210	
	Edh at Noon		63	66	84	75	48	43	41	48	57	69	59	62	
All-Sky Solar Radiation	RadAvg		862	1056	1238	1488	1700	1712	1722	1607	1437	1251	1032	849	
	RadStd		175	193	136	167	147	163	150	119	128	106	117	131	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	-1.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page