

SHIJIAZHUANG ZHENGDING INTL, China

WMO: 470312

Lat: 38.281N

Lon: 114.697E

Elev: 71

StdP: 100.47

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.2	-10.0	-27.8	0.3	-1.4	-24.8	0.4	-1.3	9.5	-2.2	7.7	-0.3	1.6	320	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	36.2	22.3	34.8	22.9	33.1	23.0	27.6	31.4	26.6	30.2	25.8	29.3	3.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.7	30.0	25.9	21.3	29.2	24.9	20.1	28.3	88.4	31.9	83.7	30.6	79.7	29.8	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.4	5.3	DB	-13.9	39.3	1.8	2.0	-15.2	40.7	-16.2	41.9	-17.2	43.0	-18.6	44.4	
			WB	-14.9	29.4	1.6	1.2	-16.0	30.3	-17.0	31.0	-17.9	31.7	-19.0	32.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	-3.2	0.3	7.6	14.4	20.5	25.6	27.3	25.5	20.8	14.4	5.5	-1.1
	DBStd	11.08	2.69	3.38	4.21	3.67	3.16	2.90	2.28	2.40	2.86	3.40	4.18	2.91
	HDD10.0	1278	409	272	98	7	0	0	0	0	4	143	346	(8)
	HDD18.3	2771	668	505	332	126	14	0	0	12	127	383	604	(9)
	CDD10.0	2447	0	0	24	139	326	469	535	479	324	142	9	0
	CDD18.3	899	0	0	1	7	82	219	277	221	86	6	0	0
	CDH23.3	9278	0	0	19	147	924	2461	2986	1987	661	93	0	0
	CDH26.7	4024	0	0	4	33	340	1263	1402	776	190	16	0	0
(14) Wind	WSAvg	2.2	2.0	2.2	2.8	2.9	2.7	2.5	2.1	1.7	1.8	1.9	2.0	2.1
(15) Precipitation	PrecAvg	551	4	8	13	25	39	68	150	133	63	26	17	4
	PrecMax	918	18	35	48	57	80	131	362	413	110	80	60	20
	PrecMin	320	0	0	0	6	9	25	63	44	9	4	0	0
	PrecStd	124	5	7	15	14	19	32	70	76	32	19	18	5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	15.9	25.8	30.2	35.1	39.0	38.8	35.1	32.8	28.8	21.0	11.9
		MCWB	1.9	5.6	12.5	18.7	19.0	20.7	22.4	26.8	20.3	17.3	10.4	3.9
	2%	DB	6.9	12.2	22.1	27.1	32.2	36.9	36.2	33.1	30.2	25.9	17.8	9.2
		MCWB	0.1	3.9	11.2	16.4	19.2	20.5	24.2	25.7	20.5	15.4	9.8	1.9
	5%	DB	4.9	9.8	19.0	24.9	30.1	35.0	34.8	32.0	28.9	23.9	14.9	6.9
		MCWB	-0.8	2.9	9.5	14.9	18.9	20.7	24.6	24.9	19.8	14.1	8.0	1.0
	10%	DB	2.8	7.1	16.0	22.8	28.1	33.1	33.0	30.9	27.1	21.2	12.8	4.8
		MCWB	-1.8	1.3	7.8	14.2	18.0	20.9	24.6	24.6	19.6	13.5	7.5	-0.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	6.7	15.2	20.7	23.8	24.9	29.1	29.0	23.8	19.5	12.3	4.5
		MCDB	8.5	13.4	20.9	27.3	30.1	32.7	34.0	32.1	28.4	24.0	17.4	9.1
	2%	WB	0.9	4.6	12.6	18.8	22.4	23.9	27.9	27.7	22.7	17.5	10.9	2.8
		MCDB	5.1	11.0	20.5	24.4	28.6	31.3	32.3	31.0	26.7	22.2	14.7	8.0
	5%	WB	-0.4	3.2	10.5	16.9	21.1	23.1	26.9	26.8	21.8	16.3	9.5	1.5
		MCDB	3.9	8.8	17.6	22.0	26.9	30.3	30.8	29.9	25.7	20.4	13.8	6.0
	10%	WB	-1.6	1.7	8.4	15.1	19.7	22.3	26.0	25.9	21.0	15.2	8.1	0.3
		MCDB	2.1	6.4	15.0	20.6	25.3	29.2	29.9	28.9	25.0	18.9	11.5	3.7
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	11.5	13.4	13.2	13.3	12.5	9.5	8.9	11.1	11.8	11.1	10.8
		MCDBR	14.8	16.1	18.2	17.4	17.0	16.3	13.0	10.9	14.1	15.4	14.5	14.4
		MCWBR	9.7	9.6	9.6	9.1	8.0	5.0	4.5	5.0	5.8	6.6	8.1	9.0
	5% WB	MCDBR	13.3	14.4	16.8	15.2	14.2	12.4	9.8	8.8	10.5	11.5	12.3	12.8
		MCWBR	9.1	9.0	9.5	9.3	8.1	5.1	4.7	4.7	5.4	5.9	7.4	8.3
(40) Clear-Sky Solar Irradiance	taub	0.480	0.557	0.559	0.611	0.651	0.794	0.790	0.770	0.699	0.642	0.518	0.472	(40)
	taud	1.836	1.701	1.725	1.666	1.627	1.442	1.489	1.504	1.578	1.632	1.815	1.890	(41)
	Ebn at Noon	636	638	699	695	678	586	583	578	584	559	592	609	(42)
	Edh at Noon	154	201	215	241	256	308	292	281	247	213	156	137	(43)
(44) All-Sky Solar Radiation	RadAvg	2.50	3.13	4.53	5.40	5.94	5.38	4.75	4.59	4.07	3.29	2.59	2.28	(44)
	RadStd	0.20	0.39	0.41	0.35	0.46	0.49	0.31	0.38	0.34	0.36	0.41	0.24	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page