

ANJU, Korea, Democratic People's Republic of

WMO: 470500

Lat: 39.617N

Lon: 125.650E

Elev: 89

StdP: 14.65

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.9	6.6	-10.3	3.2	8.8	-6.1	4.0	12.0	20.4	19.4	19.0	19.1	2.5	320	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.5	87.4	76.9	85.2	75.7	83.3	74.7	79.7	85.1	78.1	82.8	76.9	81.2	5.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.1	146.3	83.5	76.8	139.9	81.6	75.5	133.7	80.1	43.4	85.3	41.8	82.9	40.5	81.4	88.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	17.0	14.3	-2.5	90.8	5.1	2.0	-6.2	92.3	-9.2	93.5	-12.0	94.6	-15.8	96.1
			-2.8	82.8	5.1	2.7	-6.4	84.7	-9.4	86.3	-12.2	87.8	-15.9	89.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.9	20.5	26.8	38.2	50.2	61.8	70.6	76.2	76.8	67.8	55.3	39.8	24.7	(6)
	DBStd	20.53	7.42	7.21	6.31	6.40	4.97	3.86	3.52	3.84	4.84	6.68	8.61	7.92	(7)
	HDD50	3138	913	649	369	74	1	0	0	0	29	318	785		(8)
	HDD65	6188	1378	1069	832	443	124	5	0	0	28	304	755	1250	(9)
	CDD50	3450	0	0	3	81	365	618	812	830	535	193	13	0	(10)
	CDD65	1024	0	0	0	0	23	173	347	365	113	3	0	0	(11)
	CDH74	6552	0	0	0	5	164	888	2324	2675	479	17	0	0	(12)
	CDH80	1417	0	0	0	0	21	153	528	673	41	1	0	0	(13)
(14) Wind	WSAvg	4.0	3.1	4.0	4.8	5.2	4.7	3.9	4.1	3.6	3.0	3.5	3.9	3.7	(14)
(15) Precipitation	PrecAvg	44.0	0.3	0.8	0.9	2.0	3.4	4.5	14.0	9.8	4.3	2.0	1.8	0.6	(15)
	PrecMax	75.2	1.1	4.2	2.8	4.1	9.4	10.6	39.8	31.0	13.6	4.2	6.2	1.9	(16)
	PrecMin	26.1	0.0	0.0	0.0	0.0	0.5	1.3	2.9	2.0	0.7	0.0	0.2	0.1	(17)
	PrecStd	12.4	0.3	1.1	0.6	1.2	2.0	2.2	7.3	6.4	3.6	1.2	1.5	0.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	48.5	62.4	74.2	82.6	87.1	90.8	90.9	84.0	76.2	62.9	45.0	(19)
		MCWB	35.6	41.2	50.9	58.8	65.4	70.4	80.6	80.6	71.9	64.3	56.2	40.8	(20)
	2%	DB	37.2	43.3	56.0	69.4	78.3	83.7	87.2	87.9	80.9	71.7	58.9	41.3	(21)
		MCWB	34.0	37.1	46.6	55.8	64.9	70.2	77.0	78.4	69.9	61.5	52.8	38.2	(22)
	5%	DB	34.5	40.1	51.8	65.5	75.0	81.5	84.9	85.8	79.0	68.4	55.4	38.6	(23)
		MCWB	31.2	35.1	44.4	53.6	62.4	69.6	76.2	77.2	68.6	59.1	50.3	35.4	(24)
	10%	DB	31.8	37.3	48.4	61.9	72.1	79.2	82.9	83.7	76.8	65.5	52.2	36.0	(25)
		MCWB	28.8	32.8	41.6	51.3	60.8	68.6	75.6	76.0	67.2	57.7	47.2	32.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.6	44.2	52.5	61.9	70.1	75.4	82.7	82.1	75.6	66.9	57.6	42.0	(27)
		MCDB	39.6	48.2	58.6	69.8	77.3	82.3	89.6	88.5	79.9	73.6	61.4	44.0	(28)
	2%	WB	34.3	38.2	48.5	57.7	66.8	73.1	79.8	80.0	72.7	63.1	53.8	38.6	(29)
		MCDB	36.7	42.0	55.0	65.5	74.8	79.8	85.0	85.9	78.2	69.0	57.5	41.1	(30)
	5%	WB	31.7	35.6	44.9	55.0	64.5	71.5	78.2	78.6	70.8	60.9	50.8	35.9	(31)
		MCDB	34.1	39.3	50.9	62.6	72.4	78.2	82.5	83.8	76.3	66.6	54.8	38.3	(32)
	10%	WB	29.1	33.4	42.3	52.7	62.5	70.2	76.9	77.4	69.3	58.9	48.0	33.3	(33)
		MCDB	31.6	36.8	47.6	60.4	69.9	76.4	80.9	82.1	74.9	64.2	51.7	35.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.4	15.5	15.5	17.8	17.4	15.0	11.3	12.5	16.9	17.8	14.2	13.2	(35)
		MCDBR	15.6	17.1	20.7	23.0	22.1	19.1	15.1	14.6	18.0	20.1	17.4	12.8	(36)
	5% WB	MCWBR	12.5	12.0	13.2	12.4	11.1	9.1	8.0	7.9	9.2	11.4	12.7	10.8	(37)
		MCWBR	14.4	15.7	19.4	19.9	19.6	15.1	12.1	12.3	15.1	17.8	15.3	12.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.406	0.482	0.544	0.622	0.643	0.718	0.694	0.587	0.512	0.537	0.489	0.418	(40)
		taud	1.959	1.818	1.729	1.628	1.632	1.554	1.648	1.869	1.977	1.815	1.863	1.958	(41)
	Ebn at Noon		224	222	223	216	216	200	203	223	231	203	193	207	(42)
		Edh at Noon	42	56	67	79	80	87	79	62	52	55	46	39	(43)
(44) All-Sky Solar Radiation	RadAvg		771	1017	1384	1610	1808	1670	1338	1424	1399	1091	735	654	(44)
	RadStd		50	73	102	128	158	174	172	165	116	71	75	45	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+88	N/A

Nomenclature: See separate page