

CHEORWON, Korea, Republic of

WMO: 470950

Lat: 38.1478N

Lon: 127.3042E

Elev: 155

StdP: 99.47

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.3	-15.0	-24.3	0.4	-11.2	-22.2	0.5	-10.9	7.0	-2.0	6.2	-1.3	0.8	20	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.7	31.4	23.9	30.1	23.1	28.8	22.3	25.7	29.0	24.9	28.1	24.2	27.1	2.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.7	20.1	27.3	24.0	19.3	26.7	23.3	18.5	26.2	80.2	29.2	77.1	28.1	74.3	27.3	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	5.9	5.2	-20.3	33.3	3.2	1.1	-22.6	34.0	-24.4	34.7	-26.2	35.2	-28.6	36.0		
(5)			-20.7	26.6	3.1	0.8	-22.9	27.2	-24.8	27.7	-26.5	28.2	-28.8	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	-5.6	-2.2	3.7	10.5	16.6	21.2	24.1	24.4	19.3	12.5	4.7	-2.9	(6)
(7)		DBStd	10.96	4.59	4.24	3.67	3.74	2.68	2.15	2.21	2.42	2.77	3.74	4.42	4.54	(7)
(8)		HDD10.0	1646	482	342	197	38	0	0	0	0	0	19	166	401	(8)
(9)		HDD18.3	3348	741	576	453	236	68	4	0	1	21	182	409	659	(9)
(10)		CDD10.0	1860	0	0	2	53	203	337	437	446	278	97	7	0	(10)
(11)		CDD18.3	521	0	0	0	1	12	91	178	188	49	2	0	0	(11)
(12)		CDH23.3	3683	0	0	0	18	157	608	1204	1407	279	10	0	0	(12)
(13)		CDH26.7	914	0	0	0	1	18	131	313	419	33	0	0	0	(13)
(14)	Wind	WSAvg	1.7	1.4	1.6	2.1	2.4	2.2	1.9	1.9	1.7	1.6	1.4	1.5	1.3	(14)
(15)	Precipitation	PrecAvg	1407	17	27	34	70	101	138	432	325	138	52	47	25	(15)
(16)		PrecMax	2215	53	83	90	157	291	399	995	828	450	174	122	73	(16)
(17)		PrecMin	688	1	1	5	12	13	40	144	56	12	8	11	3	(17)
(18)		PrecStd	310	13	21	23	36	54	87	212	205	113	39	25	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	12.1	18.4	25.7	28.7	31.4	33.0	29.2	24.6	18.2	9.7	(19)	
(20)			MCWB	3.6	6.2	9.7	13.8	16.2	19.8	25.3	25.1	21.4	16.3	12.5	6.2	(20)
(21)		2%	DB	4.7	9.0	15.5	22.9	26.7	29.6	31.2	31.8	27.6	22.6	15.7	7.6	(21)
(22)			MCWB	1.6	3.6	8.2	12.7	15.7	19.6	24.1	24.8	20.4	15.4	10.8	4.6	(22)
(23)		5%	DB	3.2	6.7	13.2	20.6	25.2	28.2	29.7	30.5	26.3	20.8	14.0	5.7	(23)
(24)			MCWB	0.3	2.5	6.4	11.5	15.3	19.3	23.5	24.3	19.5	14.4	10.0	3.0	(24)
(25)		10%	DB	1.7	4.7	11.1	18.6	23.5	26.8	28.4	29.1	25.0	19.2	12.2	4.0	(25)
(26)			MCWB	-0.7	1.0	5.5	10.6	14.6	18.8	23.1	23.6	18.7	13.4	8.7	1.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	7.6	11.9	17.0	19.2	22.9	26.6	27.0	24.0	18.6	14.0	7.5	(27)
(28)			MCDWB	6.2	9.6	15.5	21.3	23.6	26.9	30.2	31.0	27.0	21.7	16.4	8.9	(28)
(29)		2%	WB	2.3	4.5	9.4	14.5	18.0	21.9	25.6	25.9	22.5	16.8	12.2	4.9	(29)
(30)			MCDWB	4.2	8.2	13.6	19.5	22.8	25.6	28.9	29.3	25.2	20.3	14.6	6.9	(30)
(31)		5%	WB	0.8	2.9	7.5	13.0	16.9	21.1	24.8	25.2	21.4	15.7	10.6	3.3	(31)
(32)			MCDWB	2.5	6.0	11.8	18.1	21.6	24.8	27.7	28.5	24.3	19.0	13.2	5.4	(32)
(33)		10%	WB	-0.4	1.5	5.9	11.5	16.0	20.4	24.2	24.6	20.2	14.6	9.0	1.8	(33)
(34)			MCDWB	1.4	4.2	10.4	17.0	20.9	24.2	26.9	27.7	23.3	18.1	11.4	3.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.2	11.4	11.5	12.8	11.6	9.7	6.8	7.7	10.3	12.3	10.6	10.2	(35)
(36)			MCDBR	11.1	13.4	15.2	16.4	15.0	12.6	9.4	9.7	11.7	13.4	12.7	10.9	(36)
(37)			MCWBR	8.1	8.5	8.3	7.4	5.5	4.3	3.7	3.8	5.1	6.3	7.9	7.9	(37)
(38)		5% WB	MCDWR	9.2	11.4	12.8	12.8	10.8	8.7	6.9	7.9	8.4	10.9	10.2	10.1	(38)
(39)			MCWBR	7.3	8.0	8.1	6.9	5.2	3.9	3.2	3.6	4.4	6.1	7.4	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.407	0.469	0.553	0.607	0.613	0.680	0.653	0.561	0.489	0.485	0.460	0.407	(40)	
(41)		taud	1.947	1.841	1.724	1.659	1.687	1.614	1.726	1.948	2.067	1.950	1.947	1.990	(41)	
(42)		Ebn at Noon	720	724	705	699	706	659	672	728	758	702	658	687	(42)	
(43)		Edh at Noon	136	174	215	243	241	259	230	180	151	154	136	123	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.44	3.27	4.17	4.89	5.49	5.13	3.94	4.17	4.05	3.50	2.39	2.18	(44)	
(45)		RadStd	0.17	0.23	0.41	0.40	0.53	0.48	0.58	0.56	0.46	0.25	0.26	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+98	N/A
(47) Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+105	+57

Nomenclature: See separate page